

FOULUM, Denmark

WMO: 060690

Lat: 56.4931N

Lon: 9.5708E

Elev: 190

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	18.6	10.6	9.5	15.8	14.5	11.6	19.7	29.5	41.2	26.9	41.0	4.3	0	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.4	78.0	64.5	74.6	63.4	71.1	62.0	66.5	74.0	64.5	71.5	62.9	69.4	10.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.6	88.7	69.6	61.8	82.9	67.7	60.2	78.5	65.9	31.2	74.2	29.7	71.8	28.5	69.6	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	20.7	18.4		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.4	33.0	33.7	37.9	44.5	51.2	56.3	60.7	61.2	55.4	48.6	39.7	34.2
	DBStd	11.74	7.52	6.83	5.95	6.20	5.14	4.86	4.82	4.31	4.32	5.26	6.21	7.76
	HDD50	2491	527	456	377	189	47	4	0	0	6	86	309	490
	HDD65	6816	992	876	841	616	429	265	153	135	289	507	758	955
	CDD50	1196	0	0	1	23	84	194	332	347	168	45	2	0
	CDD65	42	0	0	0	0	0	5	20	17	0	0	0	0
	CDH74	337	0	0	0	1	5	46	171	112	2	0	0	0
	CDH80	39	0	0	0	0	0	6	22	11	0	0	0	0
	WSAvg	8.6	10.1	10.5	9.9	8.5	8.4	7.9	7.1	7.3	7.7	8.6	8.9	8.9
	PrecAvg	29.6	2.6	1.9	2.0	1.6	2.0	2.5	2.6	3.0	2.8	3.2	2.7	2.7
(15) Precipitation	PrecMax	36.9	5.3	4.8	4.3	3.7	3.5	4.8	4.0	5.6	6.2	6.9	5.7	5.4
	PrecMin	19.8	0.3	0.5	0.3	0.2	0.4	0.2	0.8	1.0	0.9	0.7	0.9	0.8
	PrecStd	3.9	1.3	1.0	1.0	0.9	0.8	1.0	1.1	1.2	1.4	1.3	1.1	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.2	48.5	57.1	70.5	73.4	80.2	83.1	81.4	72.9	62.1	55.1	51.9
		MCWB	47.5	45.9	48.3	57.8	59.8	64.2	66.8	65.5	62.4	57.8	53.4	50.3
	2%	DB	46.5	46.0	52.0	64.1	68.2	73.7	78.6	77.3	68.6	59.9	51.8	49.7
		MCWB	45.0	44.0	46.7	54.1	57.0	63.6	65.3	64.1	61.1	56.7	50.0	48.3
	5%	DB	44.6	44.4	48.5	59.4	64.7	69.4	75.0	73.8	65.2	57.8	49.9	47.1
		MCWB	43.1	42.7	44.8	51.3	55.7	60.8	64.1	62.8	59.2	55.4	48.5	45.8
	10%	DB	42.9	42.8	45.8	54.8	61.2	65.9	71.1	70.2	62.6	56.2	48.1	44.6
		MCWB	41.4	41.2	43.1	49.0	54.1	58.6	62.5	61.9	57.9	54.2	46.7	43.2
	0.4%	WB	47.8	46.5	50.3	59.4	62.5	67.3	70.0	67.9	63.9	59.6	53.0	50.3
		MCDB	49.0	47.9	54.5	67.3	69.0	74.2	78.6	76.3	69.9	61.1	54.6	51.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.3	44.7	47.3	54.7	59.2	64.1	67.3	65.6	62.0	57.4	50.3	48.3
		MCDB	46.4	45.8	51.1	62.6	65.1	71.3	75.0	73.3	67.2	58.8	51.4	49.5
	5%	WB	43.3	43.0	45.2	52.2	56.7	61.9	64.9	64.1	60.3	55.7	48.5	46.0
		MCDB	44.3	44.2	47.8	58.4	62.7	68.8	71.8	71.1	64.2	57.3	49.5	47.0
	10%	WB	41.7	41.4	43.5	49.9	54.6	59.5	63.1	62.6	58.6	54.4	46.8	43.4
		MCDB	42.8	42.6	45.6	54.2	60.3	64.9	69.9	68.3	61.4	56.1	47.9	44.5
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	7.5	10.3	13.5	14.5	14.0	15.3	14.4	11.9	9.8	7.2	7.2
		MCDBR	7.3	7.8	14.8	20.2	21.0	20.1	22.0	20.0	15.9	10.7	7.8	7.6
		MCWBR	7.5	6.9	10.1	11.8	12.5	11.6	11.0	9.2	9.7	8.3	7.3	7.6
	5% WB	MCDBR	7.3	7.7	13.5	19.0	18.1	18.1	18.8	16.6	14.1	9.8	7.5	7.7
		MCWBR	7.5	7.1	9.9	11.7	12.1	11.3	10.6	9.2	9.2	8.1	7.3	7.7
(40) Clear-Sky Solar Irradiance	taub		0.310	0.332	0.352	0.388	0.381	0.373	0.391	0.392	0.368	0.347	0.325	0.296
	taud		2.222	2.277	2.303	2.259	2.323	2.365	2.336	2.347	2.401	2.390	2.292	2.209
	Ebn at Noon		179	227	254	262	272	275	267	258	248	220	174	152
	Edh at Noon		17	24	30	37	37	36	36	34	28	22	16	14
(44) All-Sky Solar Radiation	RadAvg		142	328	759	1262	1658	1792	1638	1294	890	453	176	101
	RadStd		26	47	70	154	155	148	185	106	94	54	28	11

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-214	-290	N/A	N/A

Nomenclature: See separate page