

AARHUS, Denmark

WMO: 060700

Lat: 56.3083N

Lon: 10.6256E

Elev: 82

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.6	19.9	11.5	9.9	20.1	15.2	11.9	23.5	30.7	42.8	27.3	41.7	3.1	270	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	79.0	63.9	75.9	62.7	73.1	61.6	66.9	73.4	65.2	71.3	63.6	69.9	9.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.6	91.6	69.2	62.9	85.9	67.9	61.1	80.6	66.4	31.5	73.3	30.1	71.2	29.0	69.8	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	21.1	18.6	8.5	83.3	6.0	2.8	4.1	85.4	0.6	87.1	-2.8	88.7	-7.2	90.7
			8.0	69.8	5.9	2.2	3.8	71.3	0.3	72.6	-3.0	73.8	-7.4	75.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	33.9	34.2	37.3	44.5	51.9	57.6	62.3	62.3	56.1	48.5	41.4	36.0	(6)
	DBStd	11.86	6.64	6.81	6.42	6.07	5.73	4.83	4.90	4.42	4.72	5.73	5.79	7.47	(7)
	HDD50	2361	500	442	394	184	43	2	0	0	7	94	261	434	(8)
	HDD65	6544	965	862	858	615	407	227	114	108	269	512	708	899	(9)
	CDD50	1355	0	0	1	19	103	231	381	381	189	47	3	0	(10)
	CDD65	63	0	0	0	0	2	6	30	24	1	0	0	0	(11)
	CDH74	480	0	0	0	1	11	59	258	148	3	0	0	0	(12)
	CDH80	48	0	0	0	0	0	6	31	11	0	0	0	0	(13)
(14) Wind	WSAvg	8.6	9.4	9.7	9.7	8.7	8.5	8.8	7.9	7.7	8.2	8.4	8.6	8.5	(14)
(15) Precipitation	PrecAvg	26.5	2.0	1.5	1.5	1.5	2.2	2.6	2.4	3.0	2.6	2.8	2.2	2.1	(15)
	PrecMax	33.7	3.7	3.4	3.3	3.7	4.5	6.0	4.6	6.9	7.0	4.5	4.6	4.4	(16)
	PrecMin	18.9	0.2	0.6	0.3	0.2	0.7	0.1	0.2	0.6	0.4	1.0	0.4	0.4	(17)
	PrecStd	3.5	1.0	0.7	0.9	0.9	0.9	1.3	1.3	1.5	1.6	0.9	0.9	1.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.9	50.9	56.8	68.7	75.5	80.2	83.8	81.2	73.2	63.7	55.9	52.2	(19)
		MCWB	46.8	47.0	48.7	55.6	60.8	64.1	67.1	64.7	62.3	58.0	53.1	49.4	(20)
	2%	DB	46.4	47.3	52.2	62.6	70.7	74.9	79.9	78.4	69.5	60.0	53.4	49.7	(21)
		MCWB	44.8	44.9	45.2	52.1	58.2	61.8	64.3	63.7	60.5	55.9	51.0	47.9	(22)
	5%	DB	44.5	45.2	48.8	58.7	66.6	71.2	76.9	74.9	66.5	57.8	51.3	47.4	(23)
		MCWB	42.9	43.0	43.5	50.0	56.2	59.9	63.2	62.8	59.3	54.6	49.1	45.8	(24)
	10%	DB	42.7	43.2	46.3	55.0	63.5	67.8	73.6	71.6	64.3	56.2	49.6	45.6	(25)
		MCWB	41.2	41.3	42.6	47.9	54.3	58.3	62.0	62.0	58.2	53.4	47.6	44.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.2	47.8	50.0	57.8	63.1	67.6	69.7	68.4	65.2	59.6	53.8	50.2	(27)
		MCDB	48.2	49.4	54.7	66.4	71.2	76.2	79.3	74.1	68.6	62.4	55.5	51.4	(28)
	2%	WB	44.9	45.6	46.6	53.2	60.1	63.7	67.3	66.7	62.9	57.0	51.5	47.9	(29)
		MCDB	45.9	46.9	49.9	60.3	68.1	70.9	75.5	71.6	67.0	59.1	53.1	49.2	(30)
	5%	WB	43.0	43.4	44.6	51.0	57.6	61.5	65.4	65.2	60.9	55.4	49.5	45.9	(31)
		MCDB	44.0	44.7	47.4	56.7	64.6	68.3	72.7	70.5	65.1	57.2	50.8	46.9	(32)
	10%	WB	41.3	41.4	42.9	48.9	55.3	59.6	63.5	63.8	59.2	54.1	47.7	44.2	(33)
		MCDB	42.3	43.0	45.6	53.9	61.6	66.0	70.6	69.5	63.1	56.0	49.1	45.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	8.4	11.6	15.2	16.4	15.7	16.5	15.2	13.2	10.4	8.1	7.9	(35)
		MCDBR	7.6	9.0	15.6	20.9	21.9	21.7	22.2	20.4	16.1	10.8	8.2	7.4	(36)
	5% WB	MCWBR	7.3	7.3	10.0	11.9	11.9	11.1	10.5	9.7	9.3	8.2	7.7	7.1	(37)
		MCWBR	7.5	8.9	13.2	18.4	18.6	18.5	19.1	16.6	14.2	9.6	7.9	7.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.313	0.336	0.356	0.391	0.385	0.376	0.397	0.397	0.371	0.352	0.330	0.299	(40)
		taud	2.265	2.313	2.325	2.281	2.364	2.413	2.374	2.380	2.437	2.418	2.316	2.238	(41)
	Ebn at Noon		182	228	254	261	271	275	266	257	248	221	174	155	(42)
		Edh at Noon	17	24	30	36	36	34	35	33	27	22	16	14	(43)
(44) All-Sky Solar Radiation	RadAvg		131	314	770	1295	1700	1837	1700	1342	938	458	173	95	(44)
	RadStd		26	55	71	149	151	140	176	100	94	58	28	12	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.26	+2.16	N/A	N/A	N/A	N/A	-329	-446	+171	N/A	(46)
(47)	Regional (65 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-288	N/A	N/A	(47)

Nomenclature: See separate page