

AARHUS, Denmark

WMO: 060700

Lat: 56.3083N

Lon: 10.6256E

Elev: 25

StdP: 101.03

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.1	-6.7	-11.4	1.4	-6.6	-9.3	1.7	-4.7	13.7	6.0	12.2	5.4	1.4	270	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	26.1	17.7	24.4	17.1	22.8	16.5	19.4	23.0	18.4	21.9	17.6	21.1	4.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.1	20.7	17.1	12.3	19.9	16.2	11.5	19.1	55.4	23.0	52.2	21.8	49.5	21.0	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.9	9.4	8.3	-13.1	28.5	3.4	1.6	-15.5	29.7	-17.4	30.6	-19.3	31.5	-21.8	32.6
			-13.3	21.0	3.3	1.2	-15.7	21.9	-17.6	22.6	-19.5	23.2	-21.9	24.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	1.0	1.2	3.0	6.9	11.1	14.2	16.8	16.8	13.4	9.1	5.2	2.2
	DBStd	6.59	3.69	3.78	3.57	3.37	3.18	2.68	2.72	2.46	2.62	3.19	3.22	4.15
	HDD10.0	1312	278	246	219	102	24	1	0	0	4	52	145	241
	HDD18.3	3636	536	479	477	342	226	126	63	60	149	284	393	499
	CDD10.0	753	0	0	1	11	57	128	212	212	105	26	2	0
	CDD18.3	35	0	0	0	0	1	3	17	13	1	0	0	0
	CDH23.3	267	0	0	0	1	6	33	143	82	2	0	0	0
	CDH26.7	27	0	0	0	0	0	3	17	6	0	0	0	0
Wind	WSAvg	3.9	4.2	4.3	4.3	3.9	3.8	3.9	3.5	3.4	3.7	3.8	3.8	3.8
Precipitation	PrecAvg	672	52	39	39	38	55	67	60	75	65	72	57	54
	PrecMax	857	95	86	83	95	115	153	117	176	179	114	118	111
	PrecMin	480	5	14	7	5	18	3	6	14	11	26	11	9
	PrecStd	88	26	19	22	24	23	32	32	39	41	24	24	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	10.5	13.8	20.4	24.2	26.8	28.8	27.4	22.9	17.6	13.3	11.2
		MCWB	8.2	8.3	9.3	13.1	16.0	17.8	19.5	18.2	16.8	14.5	11.7	9.7
	2%	DB	8.0	8.5	11.2	17.0	21.5	23.9	26.6	25.8	20.8	15.6	11.9	9.8
		MCWB	7.1	7.2	7.4	11.2	14.6	16.5	18.0	17.6	15.8	13.3	10.6	8.9
	5%	DB	7.0	7.3	9.3	14.9	19.2	21.8	24.9	23.8	19.2	14.4	10.7	8.6
		MCWB	6.1	6.1	6.4	10.0	13.4	15.5	17.3	17.1	15.2	12.6	9.5	7.7
	10%	DB	6.0	6.2	7.9	12.8	17.5	19.9	23.1	22.0	18.0	13.4	9.8	7.5
		MCWB	5.1	5.1	5.9	8.8	12.4	14.6	16.7	16.7	14.5	11.9	8.7	6.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	8.8	10.0	14.3	17.3	19.8	20.9	20.2	18.4	15.3	12.1	10.1
		MCDB	9.0	9.7	12.6	19.1	21.8	24.6	26.3	23.4	20.4	16.9	13.0	10.8
	2%	WB	7.2	7.5	8.1	11.8	15.6	17.6	19.6	19.3	17.1	13.9	10.8	8.8
		MCDB	7.7	8.3	9.9	15.7	20.0	21.6	24.2	22.0	19.4	15.1	11.7	9.6
	5%	WB	6.1	6.3	7.0	10.5	14.2	16.4	18.5	18.4	16.0	13.0	9.7	7.7
		MCDB	6.7	7.0	8.6	13.7	18.1	20.2	22.6	21.4	18.4	14.0	10.5	8.3
	10%	WB	5.1	5.2	6.1	9.4	13.0	15.3	17.5	17.6	15.1	12.3	8.7	6.8
		MCDB	5.7	6.1	7.6	12.1	16.5	18.9	21.4	20.8	17.3	13.3	9.5	7.4
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.7	6.4	8.5	9.1	8.7	9.2	8.5	7.3	5.8	4.5	4.4
		MCDBR	4.2	5.0	8.6	11.6	12.2	12.1	12.4	11.3	8.9	6.0	4.6	4.1
		MCWBR	4.1	4.0	5.6	6.6	6.6	6.2	5.8	5.4	5.2	4.6	4.3	4.0
	5% WB	MCDBR	4.2	4.9	7.3	10.2	10.4	10.3	10.6	9.2	7.9	5.4	4.4	4.0
		MCWBR	4.2	4.2	5.3	6.3	6.2	6.0	5.8	5.4	5.2	4.5	4.2	4.0
Clear-Sky Solar Irradiance	taub	0.313	0.336	0.356	0.391	0.385	0.376	0.397	0.397	0.371	0.352	0.330	0.299	
	taud	2.265	2.313	2.325	2.281	2.364	2.413	2.374	2.380	2.437	2.418	2.316	2.238	
	Ebn at Noon	575	719	801	824	855	867	838	811	782	696	550	488	
	Edh at Noon	54	75	95	114	112	108	110	103	85	68	51	43	
All-Sky Solar Radiation	RadAvg	0.41	0.99	2.43	4.08	5.36	5.79	5.36	4.23	2.96	1.45	0.54	0.30	
	RadStd	0.08	0.17	0.23	0.47	0.48	0.44	0.55	0.32	0.29	0.18	0.09	0.04	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (65 neighbors)	+0.70	+1.20	N/A	N/A	N/A	N/A	-183	-248	+95	N/A
		+0.38	N/A	N/A	N/A	N/A	N/A	-160	N/A	N/A	

Nomenclature: See separate page