

FORNAES FYR, Denmark

WMO: 060710

Lat: 56.443N

Lon: 10.957E

Elev: 26

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	20.0	23.5	15.1	11.8	22.8	18.6	14.0	26.4	41.7	35.0	39.4	34.0	12.2	270	0.763

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	73.2	66.4	71.2	64.8	69.2	63.1	67.9	72.2	65.9	70.0	64.0	67.9	10.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	96.1	70.9	64.0	89.4	69.0	62.2	83.8	67.0	32.2	72.2	30.7	70.1	29.3	68.0	72.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
35.4	31.3	27.6	DB	18.8	76.6	6.4	2.1	14.2	78.1	10.4	79.3	6.8	80.5	2.2	82.0
			WB	18.2	69.5	5.7	2.7	14.1	71.5	10.7	73.1	7.5	74.6	3.3	76.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	35.1	34.9	37.1	42.5	51.1	56.9	61.2	60.8	55.6	48.9	41.5	37.0
	DBStd	10.88	6.37	6.27	5.38	4.61	4.69	4.96	4.42	4.38	4.03	4.33	4.75	5.19
	HDD50	2291	460	423	400	228	41	3	0	0	6	71	257	402
	HDD65	6616	925	843	864	674	431	245	135	146	281	499	706	867
	CDD50	1186	0	0	0	4	76	211	346	336	175	37	1	0
	CDD65	37	0	0	0	0	0	4	16	17	0	0	0	0
	CDH74	32	0	0	0	0	0	3	19	10	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.5	16.8	16.8	16.0	13.7	12.2	11.5	11.6	12.7	14.0	15.8	16.1	16.5
Precipitation	PrecAvg	25.6	2.0	1.5	1.5	1.5	2.1	2.6	2.3	2.9	2.5	2.7	2.2	2.0
	PrecMax	33.1	3.6	3.3	3.2	3.6	4.0	6.1	4.6	6.8	6.9	4.4	4.4	4.1
	PrecMin	18.0	0.2	0.5	0.3	0.2	0.7	0.1	0.2	0.5	0.4	0.9	0.4	0.4
	PrecStd	3.4	1.0	0.7	0.8	0.9	0.8	1.3	1.2	1.5	1.5	0.9	0.9	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.4	50.6	52.8	60.8	67.0	73.6	76.5	75.3	67.6	59.1	54.4	51.0
		MCWB	47.0	48.5	48.7	53.6	60.1	65.1	68.6	67.7	63.6	55.7	52.5	49.4
	2%	DB	46.8	48.4	48.3	54.7	63.7	70.7	73.7	73.0	65.0	57.1	51.4	48.2
		MCWB	45.3	46.5	45.4	49.9	57.9	63.1	66.7	66.8	60.8	54.7	49.4	46.8
	5%	DB	45.2	45.8	45.9	51.7	61.3	68.3	71.5	71.1	63.1	55.9	49.7	46.2
		MCWB	43.7	44.2	43.5	48.2	56.3	61.4	64.9	65.5	59.3	53.9	47.9	44.6
	10%	DB	43.2	43.7	43.9	49.5	58.8	65.7	69.4	68.7	61.7	54.8	47.9	44.2
		MCWB	41.6	42.2	41.8	46.7	54.4	59.9	63.2	63.5	58.2	52.8	46.4	42.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.5	48.8	49.1	54.1	60.6	66.9	70.2	69.9	64.4	57.3	52.9	49.7
		MCDB	48.6	50.1	52.3	58.9	66.2	72.0	74.8	73.4	66.8	58.0	54.4	50.5
	2%	WB	45.6	46.9	46.1	50.5	58.8	64.4	68.3	68.0	62.0	55.8	49.8	46.9
		MCDB	46.8	48.3	47.7	53.9	63.0	68.9	73.0	71.8	64.0	56.6	51.0	48.0
	5%	WB	43.9	44.2	43.8	48.6	56.9	62.3	65.9	66.3	60.5	54.6	48.2	44.8
		MCDB	45.0	45.5	45.5	51.2	60.5	67.1	70.0	70.3	62.3	55.5	49.5	45.9
	10%	WB	41.7	42.3	42.0	47.0	54.8	60.4	64.1	64.2	59.2	53.2	46.6	43.0
		MCDB	42.9	43.6	43.6	49.3	58.2	64.9	68.3	67.8	61.2	54.4	47.9	44.1
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.7	6.2	7.9	9.5	11.2	11.7	10.6	8.6	6.8	5.8	6.2
		MCDBR	7.1	7.8	9.8	11.1	11.9	14.3	13.1	11.8	10.5	8.0	7.6	7.6
		MCWBR	7.1	7.2	8.1	7.5	8.3	9.2	8.3	7.7	7.1	6.7	7.3	7.6
	5% WB	MCDBR	7.3	7.8	9.2	9.8	10.2	12.9	11.8	10.7	7.7	6.9	6.9	7.5
		MCWBR	7.3	7.3	8.1	7.2	7.9	9.4	8.4	7.6	6.5	6.5	6.9	7.8
Clear-Sky Solar Irradiance	taub	0.313	0.336	0.356	0.392	0.385	0.376	0.398	0.398	0.371	0.352	0.331	0.300	
	taud	2.267	2.313	2.329	2.287	2.373	2.424	2.381	2.385	2.443	2.415	2.314	2.239	
	Ebn at Noon	181	227	254	261	271	275	266	257	248	220	173	153	
	Edh at Noon	17	24	30	36	35	34	35	32	27	22	16	13	
All-Sky Solar Radiation	RadAvg	128	310	765	1291	1702	1840	1702	1341	935	455	171	94	
	RadStd	26	56	71	148	149	141	175	102	94	58	28	12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	-211	-302	N/A	N/A

Nomenclature: See separate page