

AARHUS SYD, Denmark

WMO: 060740

Lat: 56.0803N

Lon: 10.1353E

Elev: 180

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.3	21.7	12.7	10.6	20.5	16.7	12.9	24.3	27.8	40.1	26.0	40.2	4.8	270	0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	78.1	65.2	74.9	64.1	72.0	62.8	67.2	74.3	65.6	71.9	63.9	69.9	8.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	92.1	69.9	63.0	86.7	68.4	61.4	82.0	66.8	31.7	74.2	30.5	72.2	29.3	69.9	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	20.2	18.1	10.1	82.7	6.5	2.4	5.4	84.4	1.6	85.8	-2.1	87.1	-6.8	88.8
			9.9	70.0	6.4	2.0	5.3	71.5	1.5	72.6	-2.0	73.8	-6.7	75.2
				DB										
				WB										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.3	33.7	34.1	38.0	45.1	52.0	57.6	61.7	61.3	56.0	48.2	41.9	37.0
	DBStd	11.43	6.83	6.57	6.54	5.31	5.55	4.28	4.56	4.25	4.25	5.36	5.60	6.81
	HDD50	2282	505	447	372	163	41	2	0	0	5	95	248	404
	HDD65	6508	970	867	837	597	405	225	125	130	270	520	694	868
	CDD50	1294	0	0	1	16	102	230	363	351	186	41	4	0
	CDD65	43	0	0	0	0	1	2	23	16	1	0	0	0
	CDH74	337	0	0	0	0	4	40	202	88	3	0	0	0
	CDH80	25	0	0	0	0	0	2	16	7	0	0	0	0
Wind	WSAvg	8.7	10.4	10.0	9.7	8.7	8.0	7.7	7.0	7.2	7.8	8.6	9.3	9.9
Precipitation	PrecAvg	27.4	2.3	1.7	1.7	1.5	2.0	2.5	2.5	3.0	2.6	2.8	2.4	2.3
	PrecMax	34.8	4.6	3.8	3.6	3.5	3.8	5.4	4.1	6.4	5.9	5.8	5.4	4.7
	PrecMin	18.5	0.2	0.4	0.3	0.1	0.4	0.2	0.5	1.1	0.6	1.2	0.6	0.7
	PrecStd	3.9	1.1	0.9	0.9	0.8	0.9	1.2	1.1	1.4	1.5	1.1	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.7	51.1	57.2	66.5	73.9	78.7	82.2	80.7	73.4	63.3	55.9	51.9
		MCWB	47.3	47.2	49.2	54.7	61.4	63.6	66.4	65.8	63.7	58.5	53.6	50.0
	2%	DB	47.2	47.3	52.7	61.6	69.8	74.3	79.0	76.5	69.2	59.7	53.6	49.6
		MCWB	45.4	44.7	46.5	52.0	59.6	63.4	65.5	65.0	61.4	56.3	51.8	48.1
	5%	DB	45.0	45.1	49.1	58.0	66.1	70.7	76.2	73.0	66.4	57.7	51.3	47.5
		MCWB	43.1	42.9	44.4	50.0	57.9	61.4	64.7	63.5	59.8	54.9	49.7	45.9
	10%	DB	43.2	42.9	46.4	54.7	62.9	67.4	72.9	70.1	64.0	55.8	49.5	45.8
		MCWB	41.5	40.9	43.1	48.6	55.5	59.4	63.6	61.9	58.6	53.4	48.0	44.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	47.8	50.9	57.2	64.4	67.8	70.0	68.4	64.9	59.5	54.4	50.4
		MCDB	49.6	49.9	55.2	64.6	71.1	74.5	78.5	76.3	69.5	61.9	55.7	51.4
	2%	WB	45.6	45.4	47.3	53.1	61.1	65.0	67.8	66.5	62.6	57.3	52.0	48.2
		MCDB	46.9	47.1	51.1	58.9	66.7	71.5	75.4	72.8	67.8	58.9	53.3	49.5
	5%	WB	43.5	43.0	45.2	51.1	58.8	62.5	66.1	64.8	61.1	55.3	50.0	46.3
		MCDB	44.8	44.7	47.8	56.2	64.7	68.7	73.0	70.5	65.1	57.0	51.1	47.1
	10%	WB	41.6	41.2	43.6	49.2	56.4	60.4	64.3	63.4	59.5	53.9	48.2	44.5
		MCDB	42.9	42.8	46.0	53.9	61.9	66.0	70.9	68.6	62.9	55.5	49.3	45.7
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.4	10.8	14.3	15.8	15.9	16.4	15.1	13.6	10.3	7.7	7.1
		MCDBR	7.6	8.8	15.1	20.2	20.8	22.1	22.7	19.1	17.2	12.0	8.1	7.4
		MCWBR	7.5	7.2	10.0	12.1	12.3	13.0	11.4	9.6	10.5	9.1	7.3	7.2
	5% WB	MCDBR	7.8	8.5	13.1	18.0	18.4	19.8	19.6	16.8	15.6	10.6	7.6	7.2
		MCWBR	7.8	7.3	9.4	11.7	11.9	12.9	11.2	9.6	10.3	8.7	7.2	7.1
Clear-Sky Solar Irradiance	taub	0.313	0.334	0.356	0.391	0.384	0.377	0.396	0.395	0.371	0.351	0.329	0.299	
	taud	2.259	2.304	2.311	2.265	2.339	2.385	2.351	2.363	2.416	2.410	2.314	2.237	
	Ebn at Noon	184	229	254	261	272	275	266	258	248	222	177	157	
	Edh at Noon	17	24	30	37	36	35	36	33	28	22	16	14	
All-Sky Solar Radiation	RadAvg	140	327	772	1290	1685	1813	1676	1329	927	463	179	101	
	RadStd	26	52	71	152	156	140	178	99	94	57	29	11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (63 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	-205	-293	N/A	N/A

Nomenclature: See separate page