

AARHUS SYD, Denmark

WMO: 060740

Lat: 56.0803N

Lon: 10.1353E

Elev: 55

StdP: 100.67

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.2	-5.7	-10.7	1.5	-6.4	-8.5	1.8	-4.3	12.4	4.5	11.6	4.6	2.1	270	0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	25.6	18.5	23.9	17.8	22.2	17.1	19.6	23.5	18.6	22.2	17.7	21.0	4.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	21.1	17.2	12.4	20.2	16.4	11.7	19.3	55.9	23.4	53.0	22.3	50.2	21.1	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.0	8.1	-12.2	28.1	3.6	1.3	-14.8	29.1	-16.9	29.9	-18.9	30.6	-21.6	31.6		
(5)			-12.3	21.1	3.6	1.1	-14.8	21.9	-16.9	22.6	-18.9	23.2	-21.5	24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	1.0	1.1	3.3	7.3	11.1	14.2	16.5	16.3	13.4	9.0	5.5	2.8	(6)
(7)		DBStd	6.35	3.79	3.65	3.64	2.95	3.08	2.38	2.54	2.36	2.36	2.98	3.11	3.79	(7)
(8)		HDD10.0	1268	281	248	207	91	23	1	0	0	3	53	138	224	(8)
(9)		HDD18.3	3616	539	482	465	332	225	125	69	72	150	289	386	482	(9)
(10)		CDD10.0	719	0	0	1	9	57	128	202	195	103	23	2	0	(10)
(11)		CDD18.3	24	0	0	0	0	1	1	13	9	1	0	0	0	(11)
(12)		CDH23.3	187	0	0	0	0	2	22	112	49	2	0	0	0	(12)
(13)		CDH26.7	14	0	0	0	0	0	1	9	4	0	0	0	0	(13)
(14)	Wind	WSAvg	3.9	4.7	4.5	4.4	3.9	3.6	3.5	3.1	3.2	3.5	3.8	4.2	4.4	(14)
(15)	Precipitation	PrecAvg	695	58	44	42	38	50	64	63	76	67	72	62	59	(15)
(16)		PrecMax	883	117	97	91	89	97	138	103	162	150	147	138	119	(16)
(17)		PrecMin	469	4	10	7	3	9	4	13	28	16	30	16	18	(17)
(18)		PrecStd	98	29	22	22	21	23	31	28	36	39	28	27	29	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	10.6	14.0	19.2	23.3	25.9	27.9	27.1	23.0	17.4	13.3	11.0	(19)
(20)			MCWB	8.5	8.5	9.6	12.6	16.4	17.6	19.1	18.8	17.6	14.7	12.0	10.0	(20)
(21)		2%	DB	8.4	8.5	11.5	16.5	21.0	23.5	26.1	24.7	20.7	15.4	12.0	9.8	(21)
(22)			MCWB	7.4	7.0	8.0	11.1	15.3	17.4	18.6	18.3	16.4	13.5	11.0	8.9	(22)
(23)		5%	DB	7.2	7.3	9.5	14.5	19.0	21.5	24.6	22.8	19.1	14.3	10.7	8.6	(23)
(24)			MCWB	6.2	6.0	6.9	10.0	14.4	16.4	18.2	17.5	15.4	12.7	9.8	7.7	(24)
(25)		10%	DB	6.2	6.1	8.0	12.6	17.2	19.7	22.7	21.1	17.8	13.2	9.7	7.7	(25)
(26)			MCWB	5.3	5.0	6.2	9.2	13.0	15.2	17.6	16.6	14.8	11.9	8.9	6.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	8.8	10.5	14.0	18.0	19.9	21.1	20.2	18.3	15.3	12.4	10.2	(27)
(28)			MCDWB	9.8	10.0	12.9	18.1	21.7	23.6	25.8	24.6	20.8	16.6	13.2	10.8	(28)
(29)		2%	WB	7.6	7.4	8.5	11.7	16.2	18.3	19.9	19.1	17.0	14.0	11.1	9.0	(29)
(30)			MCDWB	8.3	8.4	10.6	15.0	19.3	22.0	24.1	22.7	19.9	15.0	11.8	9.7	(30)
(31)		5%	WB	6.4	6.1	7.3	10.6	14.9	17.0	18.9	18.2	16.1	13.0	10.0	7.9	(31)
(32)			MCDWB	7.1	7.0	8.8	13.5	18.2	20.4	22.8	21.4	18.4	13.9	10.6	8.4	(32)
(33)		10%	WB	5.3	5.1	6.4	9.6	13.6	15.8	18.0	17.4	15.3	12.2	9.0	7.0	(33)
(34)			MCDWB	6.0	6.0	7.8	12.2	16.6	18.9	21.6	20.3	17.2	13.0	9.6	7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	4.1	6.0	7.9	8.8	8.9	9.1	8.4	7.5	5.7	4.3	3.9	(35)
(36)			MCDBR	4.2	4.9	8.4	11.2	11.6	12.3	12.6	10.6	9.6	6.7	4.5	4.1	(36)
(37)			MCWBR	4.2	4.0	5.5	6.7	6.9	7.2	6.3	5.3	5.9	5.1	4.1	4.0	(37)
(38)		5% WB	MCDBR	4.3	4.7	7.3	10.0	10.2	11.0	10.9	9.3	8.7	5.9	4.2	4.0	(38)
(39)			MCWBR	4.3	4.1	5.2	6.5	6.6	7.2	6.2	5.3	5.7	4.8	4.0	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.313	0.334	0.356	0.391	0.384	0.377	0.396	0.395	0.371	0.351	0.329	0.299	(40)	
(41)		taud	2.259	2.304	2.311	2.265	2.339	2.385	2.351	2.363	2.416	2.410	2.314	2.237	(41)	
(42)		Ebn at Noon	580	723	802	824	856	867	839	813	783	699	557	495	(42)	
(43)		Edh at Noon	55	76	96	116	115	111	113	105	87	69	52	44	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.44	1.03	2.43	4.07	5.31	5.71	5.28	4.19	2.92	1.46	0.56	0.32	(44)	
(45)		RadStd	0.08	0.16	0.23	0.48	0.49	0.44	0.56	0.31	0.29	0.18	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	-114	-163	N/A	N/A

Nomenclature: See separate page