

BLAAVANDSHUK FYR, Denmark

WMO: 060810

Lat: 55.5575N

Lon: 8.0828E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.1	22.6	13.9	11.2	22.7	17.5	13.3	24.7	43.9	40.7	40.1	39.9	11.0	70	0.812

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	76.2	65.5	72.2	64.2	69.2	63.0	67.4	73.1	65.6	70.6	64.0	68.1	13.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.2	93.4	70.1	63.6	88.1	68.2	62.1	83.7	66.6	31.8	73.2	30.5	70.7	29.3	68.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.5	33.6	30.2	15.4	81.7	5.7	3.6	11.3	84.3	8.0	86.5	4.8	88.5	0.7	91.1		
(5)			14.9	70.2	5.6	2.2	10.8	71.8	7.5	73.1	4.4	74.3	0.3	75.9	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	35.6	35.1	38.0	44.5	51.3	57.0	61.7	62.5	57.8	50.9	43.8	38.7	(6)	(7)
	DBStd	10.99	6.25	5.74	4.75	4.92	5.22	4.10	4.41	3.82	3.93	5.24	5.82	6.86	(7)	(8)
	HDD50	2058	448	416	371	180	41	1	0	0	1	54	194	352	(8)	(9)
	HDD65	6206	913	836	836	616	427	244	126	99	217	438	637	817	(9)	(10)
	CDD50	1377	0	0	0	14	82	209	362	386	236	81	7	0	(10)	(11)
	CDD65	50	0	0	0	0	2	3	23	20	2	0	0	0	(11)	(12)
	CDH74	198	0	0	0	0	11	14	115	54	4	0	0	0	(12)	(13)
	CDH80	20	0	0	0	0	1	1	15	3	0	0	0	0	(13)	(14)
	WSAvg	15.8	17.4	16.2	15.4	13.9	14.5	15.4	14.3	15.1	16.2	16.8	17.3	17.1	(14)	(15)
	PrecAvg	30.2	2.5	2.2	1.8	1.5	1.6	2.2	2.2	3.0	3.5	3.7	3.2	2.9	(15)	(16)
(16) Precipitation	PrecMax	38.4	4.9	4.0	3.8	2.8	2.8	4.1	4.9	5.4	7.2	7.7	5.7	5.6	(16)	(17)
	PrecMin	20.2	0.2	0.6	0.3	0.1	0.6	0.1	0.6	0.7	1.4	1.5	1.5	1.3	(17)	(18)
	PrecStd	4.6	1.3	1.0	1.0	0.7	0.7	1.3	1.3	1.3	1.8	1.4	1.3	1.3	(18)	(19)
															(19)	(20)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	45.2	54.1	65.2	75.2	75.6	82.0	79.6	72.9	61.9	56.3	50.6	(20)	(21)
		MCWB	45.9	42.9	47.2	54.1	62.3	62.4	67.4	68.0	64.0	58.9	54.6	48.8	(21)	(22)
	2%	DB	45.8	43.7	46.8	60.5	69.0	70.0	77.3	75.0	67.9	60.2	54.1	48.9	(22)	(23)
		MCWB	44.0	42.0	43.7	51.5	57.6	60.8	66.4	66.1	62.0	57.3	52.2	47.2	(23)	(24)
	5%	DB	44.2	42.6	44.8	56.0	63.9	66.2	72.6	71.3	65.2	59.1	52.5	47.6	(24)	(25)
		MCWB	42.4	41.2	42.7	49.5	55.9	60.3	65.1	65.2	60.7	56.3	50.3	46.1	(25)	(26)
	10%	DB	43.0	41.7	43.5	52.1	59.4	63.3	68.9	68.7	63.5	57.6	50.7	46.4	(26)	(27)
		MCWB	41.5	40.5	41.7	47.5	53.9	59.0	63.7	63.8	59.6	55.1	48.4	44.7	(27)	(28)
	0.4%	WB	46.6	43.8	46.8	56.4	64.1	65.4	69.7	69.8	65.5	59.8	54.9	49.2	(28)	(29)
		MCDB	47.5	44.5	51.5	63.4	72.9	71.2	77.6	75.4	70.4	61.1	55.7	49.8	(29)	(30)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.4	42.5	44.6	52.6	59.3	62.7	67.5	67.7	63.0	57.8	52.7	47.8	(30)	(31)
		MCDB	45.4	43.3	46.0	58.1	65.6	67.0	73.8	72.5	66.2	59.1	53.8	48.5	(31)	(32)
	5%	WB	43.0	41.6	43.2	50.3	56.9	61.0	65.7	65.9	61.7	56.6	50.6	46.3	(32)	(33)
		MCDB	43.9	42.3	44.3	54.5	62.2	65.0	71.0	70.4	64.4	57.9	52.0	47.3	(33)	(34)
	10%	WB	41.7	40.8	42.1	48.1	54.4	59.3	64.0	64.3	60.3	55.3	48.9	45.1	(34)	(35)
		MCDB	42.7	41.5	43.1	51.0	58.5	62.9	68.4	68.0	62.9	56.8	50.4	46.1	(35)	(36)
	5% DB	MDBR	5.4	5.3	6.6	9.2	9.1	7.9	8.3	7.9	7.7	6.7	5.8	5.8	(36)	(37)
		MCDBR	4.5	4.5	8.4	17.4	18.9	15.3	17.1	13.6	11.2	6.6	4.2	4.1	(37)	(38)
		MCWBR	4.9	4.1	6.3	10.1	10.7	9.3	9.1	8.0	7.5	6.3	5.0	4.4	(38)	(39)
		MCWBR	4.3	3.9	7.2	14.1	15.6	12.3	13.9	11.5	8.9	6.2	4.2	4.0	(39)	(40)
(40) Clear-Sky Solar Irradiance	taub		0.327	0.344	0.364	0.397	0.387	0.385	0.397	0.400	0.380	0.359	0.336	0.313	(40)	(41)
		taud	2.247	2.305	2.312	2.270	2.369	2.397	2.379	2.377	2.412	2.384	2.300	2.245	(41)	(42)
	Ebn at Noon		181	228	253	260	271	273	267	258	246	220	177	157	(42)	(43)
		Edh at Noon	18	25	31	37	36	35	35	33	28	23	17	15	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		151	348	775	1302	1714	1801	1695	1364	921	470	188	109	(44)	(45)
	RadStd		25	50	72	139	159	140	167	100	91	56	27	12	(45)	(46)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page