

SYDFYNS TASINGE ISL, Denmark

WMO: 061240

Lat: 55.0144N

Lon: 10.5694E

Elev: 20

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.4	23.2	14.4	11.4	22.3	18.0	13.6	24.9	27.7	40.9	25.1	40.1	7.4	40	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	79.0	66.5	75.9	65.4	72.9	63.8	68.4	75.7	66.6	73.1	65.1	71.1	9.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.3	71.6	64.1	89.8	69.6	62.6	85.0	68.2	32.6	76.0	31.2	73.2	30.0	71.4	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.3	21.4	19.1	DB	14.6	83.8	6.1	2.8	10.1	85.8	6.6	87.4	3.1	88.9	-1.3	90.9	(4)
(5)			WB	13.9	71.5	6.0	1.9	9.6	72.9	6.1	74.0	2.7	75.1	-1.7	76.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	34.5	34.5	38.8	46.0	53.6	59.1	63.6	63.7	58.1	50.4	43.1	38.1		
	DBStd	11.75	6.34	6.07	5.73	5.34	5.12	4.40	4.69	4.03	4.29	5.31	5.25	6.26		
	HDD50	2068	480	435	348	143	21	1	0	0	1	59	211	369		
	HDD65	6033	945	855	813	571	355	184	85	75	209	451	656	834		
	CDD50	1598	0	0	0	22	133	273	423	424	245	73	5	0		
	CDD65	86	0	0	0	0	1	6	43	33	3	0	0	0		
	CDH74	460	0	0	0	0	6	37	269	140	8	0	0	0		
	CDH80	49	0	0	0	0	0	1	33	15	0	0	0	0		
	WSAvg	9.3	10.3	9.7	10.1	9.3	9.0	9.3	8.7	8.5	8.8	8.8	9.4	10.2		
	PrecAvg	26.5	2.4	1.8	1.6	1.4	1.7	2.6	2.4	2.7	2.5	2.5	2.4	2.3		
	PrecMax	32.7	5.0	3.9	3.7	3.7	3.4	5.2	4.8	5.9	6.0	6.2	5.3	5.0		
(15) Precipitation	PrecMin	18.5	0.0	0.2	0.4	0.2	0.6	0.1	0.7	0.7	0.6	0.9	0.4	0.8		
	PrecStd	3.9	1.3	0.8	0.8	0.8	0.8	1.3	1.3	1.5	1.5	1.1	1.3	1.0		
	DB	49.2	48.4	55.8	67.1	73.9	78.4	83.6	81.9	75.1	64.8	56.5	51.1			
	MCWB	47.6	45.2	49.2	55.7	62.4	65.9	69.0	67.1	64.2	59.3	54.8	49.6			
	2% DB	46.4	46.0	51.2	61.6	69.5	74.3	80.0	78.0	70.9	61.2	53.9	49.2			
(23) Mean Coincident Wet Bulb Temperatures	MCWB	44.9	43.7	46.1	52.7	59.8	64.4	67.0	66.1	62.8	57.6	52.4	47.8			
	5% DB	44.8	44.0	48.0	58.0	66.6	70.9	77.1	74.6	67.8	59.2	51.9	47.5			
	MCWB	43.3	42.1	44.4	50.6	57.8	62.3	66.1	64.6	61.4	56.4	50.3	46.2			
	10% DB	43.0	42.2	45.9	54.8	63.6	67.9	73.8	71.5	65.2	57.4	50.2	45.7			
	MCWB	41.7	40.6	43.3	49.1	56.1	60.5	64.5	63.5	59.8	54.9	48.7	44.5			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	48.2	46.1	50.1	56.6	64.4	69.0	71.2	69.7	66.4	60.9	55.2	50.2			
	MCDB	49.2	47.4	54.2	64.3	71.3	75.7	78.6	76.8	71.1	63.4	55.9	50.8			
	2% WB	45.3	44.0	46.9	53.8	61.5	65.7	69.1	67.4	63.9	58.4	52.6	48.1			
	MCDB	46.2	45.5	49.8	60.0	67.4	71.5	76.6	74.3	68.5	60.4	53.5	48.8			
	5% WB	43.5	42.5	45.2	51.6	59.1	63.6	67.3	66.0	62.4	56.8	50.5	46.4			
(31) Mean Daily Temperature Range	MCDB	44.5	43.8	47.3	56.4	64.5	69.2	74.5	72.1	66.8	58.6	51.6	47.2			
	10% WB	41.7	40.9	43.7	49.7	56.9	61.6	65.5	64.7	60.8	55.3	48.9	44.6			
	MCDB	42.8	42.2	45.6	54.1	62.2	66.7	72.0	70.2	64.7	57.1	50.0	45.5			
	5% DB	6.2	6.5	9.4	12.6	14.4	14.0	14.2	12.9	11.3	8.7	6.5	5.9			
	MCDBR	6.3	8.0	12.7	17.7	19.9	19.1	20.1	17.9	15.2	10.3	6.6	5.9			
(36) Clear-Sky Solar Irradiance	MCWBR	6.2	6.3	9.0	10.7	11.7	11.3	9.5	8.4	8.7	7.5	6.0	6.0			
	5% WB	6.2	7.7	11.4	15.9	17.3	17.2	18.1	15.3	13.8	9.7	6.2	5.8			
	MCDBR	6.3	6.4	8.5	10.3	11.2	11.2	9.6	8.4	8.6	7.5	6.0	5.9			
	taub	0.321	0.341	0.368	0.403	0.395	0.390	0.409	0.409	0.383	0.360	0.339	0.309			
	taud	2.288	2.310	2.275	2.228	2.336	2.381	2.343	2.353	2.404	2.412	2.342	2.272			
(42) All-Sky Solar Radiation	Ebn at Noon	190	231	252	259	269	272	263	255	246	223	183	166			
	Edh at Noon	18	25	32	39	37	36	36	34	29	23	17	15			
	RadAvg	149	344	780	1316	1682	1796	1671	1340	960	489	193	107			
(45)	RadStd	24	56	74	158	172	125	184	92	94	62	27	9			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (63 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-286	N/A	N/A

Nomenclature: See separate page