

ABED, Denmark

WMO: 061410

Lat: 54.8275N

Lon: 11.3289E

Elev: 30

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.0	22.8	13.6	11.0	21.6	17.4	13.2	24.7	41.9	42.8	33.8	41.9	6.8	110	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	80.4	65.9	77.2	65.2	74.0	63.6	68.4	76.5	66.6	73.7	65.1	71.6	10.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	94.6	71.3	63.9	89.1	69.7	62.5	84.5	68.2	32.6	76.7	31.2	73.5	30.1	72.2	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.2	24.3	21.1	13.1	85.7	6.3	2.6	8.6	87.6	4.9	89.1	1.3	90.5	-3.3	92.4
			12.5	71.4	6.3	2.0	8.0	72.8	4.3	74.0	0.8	75.1	-3.7	76.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	34.3	34.8	39.0	46.3	53.9	59.2	63.9	63.7	58.0	50.0	43.0	37.9	(6)
	DBStd	11.90	6.87	6.09	6.32	5.51	5.47	4.57	4.85	4.27	4.54	5.51	5.42	6.29	(7)
	HDD50	2077	486	426	343	137	22	1	0	0	1	68	216	377	(8)
	HDD65	6030	951	846	806	561	346	182	82	77	213	464	660	842	(9)
	CDD50	1621	0	0	1	26	143	277	432	424	242	70	6	0	(10)
	CDD65	98	0	0	0	0	2	8	48	36	4	0	0	0	(11)
	CDH74	673	0	0	0	1	15	64	392	187	14	0	0	0	(12)
	CDH80	98	0	0	0	0	2	4	63	29	0	0	0	0	(13)
(14) Wind	WSAvg	10.2	12.2	11.8	11.3	10.4	9.6	8.9	8.1	8.6	9.2	10.1	10.9	11.8	(14)
(15) Precipitation	PrecAvg	23.7	2.0	1.5	1.5	1.3	1.6	2.1	2.3	2.5	2.3	2.0	2.3	2.2	(15)
	PrecMax	28.3	3.7	3.3	3.5	3.1	3.3	4.8	5.6	6.9	5.9	4.6	5.0	4.1	(16)
	PrecMin	16.3	0.0	0.1	0.4	0.2	0.2	0.0	0.5	0.6	0.4	0.9	0.6	1.0	(17)
	PrecStd	3.4	1.0	0.6	0.8	0.6	0.8	1.1	1.2	1.7	1.4	0.7	1.2	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.7	49.5	58.0	69.6	75.8	80.0	85.1	83.6	76.1	65.8	56.8	51.2	(19)
		MCWB	48.1	46.1	50.0	56.0	63.3	67.0	68.5	67.1	63.9	59.7	54.7	49.3	(20)
	2%	DB	46.8	47.2	53.4	63.4	71.2	75.6	81.5	79.1	72.1	61.9	54.2	49.3	(21)
		MCWB	45.1	44.6	47.0	52.8	59.8	64.8	66.8	65.7	62.6	57.7	52.3	47.7	(22)
	5%	DB	45.2	44.9	49.6	59.4	67.8	71.9	78.6	75.4	68.8	59.5	52.2	47.4	(23)
		MCWB	43.6	43.0	45.5	50.7	57.9	62.8	65.6	64.0	61.0	56.4	50.4	45.9	(24)
	10%	DB	43.5	42.9	47.2	56.0	64.5	68.9	75.1	72.4	65.8	57.6	50.4	45.7	(25)
		MCWB	42.0	41.3	44.2	49.3	56.4	60.7	64.5	63.1	59.7	54.9	48.5	44.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	47.2	51.3	57.2	65.3	69.6	71.1	69.8	65.8	61.0	55.5	50.2	(27)
		MCDB	49.3	48.8	56.5	66.6	73.1	77.4	80.6	79.7	71.8	64.5	56.6	50.9	(28)
	2%	WB	45.6	44.8	48.2	54.2	62.0	66.4	69.1	67.3	63.6	58.4	52.7	48.0	(29)
		MCDB	46.6	46.6	51.6	61.4	68.6	73.1	78.0	73.8	69.1	60.7	53.9	49.0	(30)
	5%	WB	43.8	43.2	46.2	52.1	59.5	64.0	67.3	65.9	62.2	56.8	50.6	46.1	(31)
		MCDB	45.0	44.7	49.1	57.7	65.0	70.2	75.2	72.4	67.5	59.0	52.0	47.3	(32)
	10%	WB	42.1	41.4	44.3	49.8	57.4	62.0	65.5	64.5	60.7	55.3	48.7	44.5	(33)
		MCDB	43.4	42.9	46.7	54.8	62.8	67.6	72.5	70.6	65.0	57.4	50.0	45.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	6.7	10.1	13.8	14.9	15.2	16.0	14.3	12.5	9.5	7.0	6.0	(35)
		MCDBR	6.4	8.4	14.2	19.9	20.4	20.8	22.5	19.1	16.9	11.3	7.2	6.5	(36)
	5% WB	MCWBR	6.4	6.9	9.9	11.6	11.6	12.0	10.2	8.3	9.3	8.3	6.5	6.3	(37)
		MCWBR	6.3	8.2	13.0	17.6	17.1	18.7	19.7	15.9	15.1	10.6	6.9	6.5	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.340	0.368	0.403	0.395	0.390	0.410	0.410	0.382	0.359	0.339	0.310	(40)
		taud	2.300	2.317	2.277	2.233	2.336	2.377	2.338	2.347	2.409	2.417	2.353	2.285	(41)
	Ebn at Noon	Ebn at Noon	193	233	252	259	269	272	263	255	247	224	184	169	(42)
		Edh at Noon	18	25	32	39	37	36	36	34	29	23	17	15	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	151	346	774	1315	1679	1788	1666	1337	961	494	196	108	(44)
	RadStd	RadStd	23	57	73	158	177	122	186	92	94	63	27	8	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (64 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-293	N/A	N/A

Nomenclature: See separate page