

ABED, Denmark

WMO: 061410

Lat: 54.8275N

Lon: 11.3289E

Elev: 9

StdP: 101.22

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-5.1	-10.2	1.6	-5.8	-8.1	1.9	-4.1	18.7	6.0	15.1	5.5	3.1	110	0.625

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	26.9	18.8	25.1	18.4	23.4	17.6	20.2	24.7	19.2	23.2	18.4	22.0	4.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.5	21.8	17.7	12.7	20.9	16.9	12.1	20.1	58.0	24.8	54.8	23.0	52.0	22.3	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.1	10.8	9.4	-10.5	29.8	3.5	1.4	-13.0	30.9	-15.1	31.7	-17.0	32.5	-19.6	33.6		
(5)			-10.8	21.9	3.5	1.1	-13.3	22.7	-15.4	23.3	-17.3	23.9	-19.8	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.3	1.6	3.9	8.0	12.2	15.1	17.7	17.6	14.5	10.0	6.1	3.3
	DBStd	6.61	3.82	3.38	3.51	3.06	3.04	2.54	2.69	2.37	2.52	3.06	3.01	3.49
	HDD10.0	1154	270	237	191	76	12	1	0	0	1	38	120	209
	HDD18.3	3350	528	470	448	312	192	101	46	43	118	258	367	468
	CDD10.0	901	0	0	1	14	79	154	240	236	134	39	3	0
	CDD18.3	54	0	0	0	0	1	4	27	20	2	0	0	0
	CDH23.3	374	0	0	0	1	8	36	218	104	8	0	0	0
	CDH26.7	54	0	0	0	0	1	2	35	16	0	0	0	0
Wind	WSAvg	4.6	5.4	5.3	5.1	4.7	4.3	4.0	3.6	3.8	4.1	4.5	4.9	5.3
Precipitation	PrecAvg	602	50	38	38	34	41	54	58	64	59	52	59	56
	PrecMax	720	94	85	88	78	85	121	143	175	150	116	126	103
	PrecMin	413	0	2	9	5	6	0	13	14	10	23	16	25
	PrecStd	86	25	16	20	14	20	29	31	42	36	19	30	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	9.7	14.4	20.9	24.3	26.7	29.5	28.6	24.5	18.8	13.8	10.7
		MCWB	9.0	7.8	10.0	13.4	17.4	19.5	20.3	19.5	17.7	15.4	12.6	9.6
	2%	DB	8.2	8.4	11.9	17.5	21.8	24.2	27.5	26.2	22.3	16.6	12.4	9.6
		MCWB	7.3	7.0	8.3	11.6	15.5	18.2	19.3	18.7	17.0	14.3	11.3	8.7
	5%	DB	7.4	7.2	9.8	15.2	19.9	22.2	25.9	24.1	20.4	15.3	11.2	8.6
		MCWB	6.4	6.1	7.5	10.4	14.4	17.1	18.7	17.8	16.1	13.6	10.2	7.7
	10%	DB	6.4	6.1	8.5	13.3	18.0	20.5	23.9	22.5	18.8	14.2	10.2	7.6
		MCWB	5.6	5.2	6.8	9.6	13.6	15.9	18.1	17.3	15.4	12.7	9.2	6.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	8.5	10.7	14.0	18.5	20.9	21.7	21.0	18.8	16.1	13.0	10.1
		MCDB	9.6	9.3	13.6	19.2	22.8	25.2	27.0	26.5	22.1	18.0	13.7	10.5
	2%	WB	7.5	7.1	9.0	12.3	16.7	19.1	20.6	19.6	17.6	14.6	11.5	8.9
		MCDB	8.1	8.1	10.9	16.4	20.3	22.8	25.5	23.2	20.6	15.9	12.2	9.5
	5%	WB	6.6	6.2	7.9	11.2	15.3	17.8	19.6	18.8	16.8	13.8	10.3	7.8
		MCDB	7.2	7.1	9.5	14.3	18.3	21.2	24.0	22.4	19.7	15.0	11.1	8.5
	10%	WB	5.6	5.2	6.8	9.9	14.1	16.7	18.6	18.1	16.0	12.9	9.3	6.9
		MCDB	6.4	6.0	8.2	12.7	17.1	19.8	22.5	21.5	18.3	14.1	10.0	7.6
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.7	5.6	7.7	8.3	8.4	8.9	7.9	7.0	5.3	3.9	3.3
		MCDBR	3.6	4.7	7.9	11.1	11.3	11.5	12.5	10.6	9.4	6.3	4.0	3.6
		MCWBR	3.6	3.8	5.5	6.4	6.5	6.7	5.6	4.6	5.2	4.6	3.6	3.5
	5% WB	MCDBR	3.5	4.6	7.2	9.8	9.5	10.4	11.0	8.8	8.4	5.9	3.9	3.6
		MCWBR	3.6	3.9	5.3	6.3	6.1	6.5	5.6	4.7	5.0	4.6	3.6	3.6
Clear-Sky Solar Irradiance	taub	0.319	0.340	0.368	0.403	0.395	0.390	0.410	0.410	0.382	0.359	0.339	0.310	
	taud	2.300	2.317	2.277	2.233	2.336	2.377	2.338	2.347	2.409	2.417	2.353	2.285	
	Ebn at Noon	609	734	796	817	849	857	830	805	780	706	581	532	
	Edh at Noon	57	79	102	122	116	113	115	108	90	71	55	47	
All-Sky Solar Radiation	RadAvg	0.47	1.09	2.44	4.14	5.29	5.64	5.25	4.21	3.03	1.56	0.62	0.34	
	RadStd	0.07	0.18	0.23	0.50	0.56	0.39	0.59	0.29	0.30	0.20	0.08	0.03	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (64 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-163	N/A	N/A	N/A

Nomenclature: See separate page