

LOLLAND FALSTER MARIBO, Denmark

WMO: 061430

Lat: 54.699N

Lon: 11.440E

Elev: 5

StdP: 101.27

Time Zone: 1.00 (EUC)

Period: 86-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.1	-6.6	-12.0	1.3	-8.1	-9.4	1.7	-6.0	15.4	5.4	14.1	4.5	4.5	90	0.695

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	26.4	19.6	24.2	18.7	22.2	17.8	20.6	24.5	19.5	23.0	18.5	21.8	4.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	13.9	22.3	18.1	13.0	21.1	17.2	12.3	20.0	59.1	24.7	55.4	23.2	52.3	21.7	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.0	11.5	10.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	0.8	1.3	2.9	6.5	10.9	14.3	16.6	17.0	13.2	8.8	4.7	1.9
	DBStd	6.60	4.13	3.77	3.14	3.20	2.75	2.78	2.61	3.00	2.34	3.01	3.06	3.47
	HDD10.0	1360	286	245	221	115	21	1	0	0	3	58	161	251
	HDD18.3	3714	544	478	478	355	231	126	68	65	153	296	410	509
	CDD10.0	728	0	0	0	9	48	129	204	216	100	21	1	0
	CDD18.3	41	0	0	0	0	0	4	14	23	1	0	0	0
	CDH23.3	246	0	0	0	0	1	26	93	125	2	0	0	0
	CDH26.7	37	0	0	0	0	0	3	18	16	0	0	0	0
Wind	WSAvg	5.5	6.0	6.2	6.4	5.8	5.3	4.9	4.9	4.8	5.2	5.5	5.5	5.7
Precipitation	PrecAvg	596	50	37	37	33	42	55	57	64	59	52	57	54
	PrecMax	720	95	83	87	77	86	122	141	177	143	112	127	102
	PrecMin	405	0	2	8	3	10	1	15	15	13	23	14	24
	PrecStd	87	24	16	19	15	20	29	31	40	35	19	30	22
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	8.7	11.9	19.1	22.2	26.1	29.2	29.2	22.1	17.2	12.5	9.8
		MCWB	8.1	8.0	9.6	13.9	17.2	19.4	21.2	20.3	18.4	15.9	11.4	9.3
	2%	DB	7.2	7.3	9.8	16.0	20.0	23.5	26.1	27.0	19.2	15.1	10.6	8.2
		MCWB	6.6	6.7	8.2	12.4	15.5	18.0	19.6	19.5	16.1	13.6	9.6	7.7
	5%	DB	6.4	6.5	8.1	13.7	17.9	21.8	23.9	24.9	18.0	14.1	9.5	7.1
		MCWB	5.9	5.9	7.0	11.0	13.7	17.1	18.5	19.1	15.4	12.8	8.8	6.8
	10%	DB	5.7	5.8	7.0	11.5	15.9	19.8	21.9	22.9	16.9	13.1	8.3	6.2
		MCWB	5.3	5.2	6.1	9.3	12.8	16.4	17.6	18.4	14.5	11.8	7.8	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	8.3	9.9	14.7	17.6	20.5	22.2	21.9	18.9	15.8	11.7	9.3
		MCDB	8.3	8.7	11.1	18.1	21.9	23.9	27.4	26.1	21.1	16.8	12.6	9.5
	2%	WB	6.7	6.8	8.3	12.6	15.8	18.9	20.7	20.6	17.0	14.2	10.0	7.9
		MCDB	7.0	7.2	9.4	15.3	19.4	22.1	25.0	24.4	18.5	15.1	10.5	8.1
	5%	WB	6.0	6.0	7.1	11.2	14.2	17.8	19.5	19.6	15.7	13.1	8.8	6.8
		MCDB	6.3	6.3	7.9	13.5	17.0	20.7	22.7	23.5	17.3	13.9	9.3	7.1
	10%	WB	5.1	5.1	6.1	9.7	13.0	16.6	18.3	18.7	14.9	12.2	7.9	5.9
		MCDB	5.5	5.6	6.7	11.3	15.3	19.2	21.2	22.4	16.3	13.0	8.2	6.2
Mean Daily Temperature Range	5% DB	MDBR	3.3	3.4	4.7	6.3	7.4	7.2	7.8	7.8	5.7	4.9	3.5	3.2
		MCDBR	3.5	3.5	6.4	9.2	10.3	10.6	11.4	10.4	7.2	5.3	3.8	2.8
		MCWBR	3.3	3.2	5.2	6.2	6.4	5.9	5.8	4.6	4.4	4.1	3.7	2.8
	5% WB	MCDBR	3.4	3.5	5.8	8.9	9.3	9.5	10.1	9.7	6.7	4.6	3.8	2.8
		MCWBR	3.3	3.2	4.9	6.1	6.2	5.9	5.9	4.9	4.6	4.0	3.8	2.8
Clear-Sky Solar Irradiance	taub	0.319	0.341	0.369	0.404	0.396	0.392	0.411	0.411	0.382	0.360	0.340	0.310	
	taud	2.304	2.319	2.275	2.233	2.339	2.379	2.340	2.349	2.412	2.419	2.358	2.290	
	Ebn at Noon	613	735	796	817	849	856	829	804	780	707	585	536	
	Edh at Noon	57	79	102	122	116	113	115	108	89	71	55	47	
All-Sky Solar Radiation	RadAvg	0.48	1.10	2.43	4.14	5.29	5.62	5.24	4.21	3.03	1.57	0.63	0.34	
	RadStd	0.07	0.18	0.23	0.50	0.57	0.38	0.59	0.29	0.30	0.20	0.08	0.03	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-163	N/A	N/A

Nomenclature: See separate page