

VINDEBAEK KYST, Denmark

WMO: 061470

Lat: 54.8789N

Lon: 12.1842E

Elev: 3

StdP: 101.29

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.3	-3.8	-8.5	1.8	-4.0	-6.7	2.1	-2.6	15.3	4.5	14.3	3.1	5.3	40	0.702

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	23.9	19.5	22.4	18.7	21.3	17.9	20.3	22.9	19.3	21.6	18.6	20.6	4.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.1	22.0	18.4	13.2	20.8	17.6	12.6	20.0	58.5	22.9	55.1	21.8	52.6	20.6	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.1	12.6	11.4	-7.2	27.4	2.8	2.1	-9.2	28.9	-10.9	30.1	-12.4	31.3	-14.5	32.8		
(5)			-7.5	21.8	2.5	1.3	-9.3	22.8	-10.8	23.5	-12.2	24.3	-14.0	25.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	1.9	1.8	3.7	7.3	11.5	15.0	17.8	17.7	14.9	10.7	6.8	3.8
	DBStd	6.31	3.09	2.98	2.99	2.54	2.54	2.07	2.19	1.98	2.13	2.52	2.79	3.22
	HDD10.0	1089	251	229	196	86	14	0	0	0	0	22	99	192
	HDD18.3	3283	509	462	454	331	213	102	38	34	106	237	346	451
	CDD10.0	888	0	0	0	6	59	150	241	240	146	43	3	0
	CDD18.3	39	0	0	0	0	0	2	20	16	1	0	0	0
	CDH23.3	68	0	0	0	0	0	6	39	23	0	0	0	0
	CDH26.7	4	0	0	0	0	0	1	2	2	0	0	0	0
Wind	WSAvg	5.8	7.1	6.2	6.0	5.4	5.1	5.0	4.8	5.1	5.7	6.1	6.6	6.9
Precipitation	PrecAvg	613	53	36	36	32	45	57	55	66	59	53	59	57
	PrecMax	802	89	60	96	70	103	131	154	210	165	104	134	116
	PrecMin	428	2	2	7	13	7	1	4	9	18	30	6	18
	PrecStd	87	25	12	20	13	24	28	32	42	36	19	31	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	8.6	12.7	16.8	20.5	23.9	26.2	26.0	21.3	17.2	13.6	10.3
		MCWB	8.4	7.1	9.3	11.7	15.9	19.3	20.7	21.0	18.2	15.1	12.6	9.3
	2%	DB	7.8	7.4	9.7	13.7	18.1	21.1	24.3	23.4	19.8	15.9	12.2	9.4
		MCWB	6.8	6.1	7.3	10.4	14.5	17.1	19.8	19.3	17.2	14.3	11.2	8.4
	5%	DB	7.0	6.4	8.3	12.0	16.6	19.9	23.0	22.0	18.8	14.9	11.1	8.6
		MCWB	6.1	5.3	6.4	9.5	13.8	16.0	19.1	18.5	16.3	13.5	10.2	7.6
	10%	DB	6.1	5.4	7.3	10.8	15.4	18.9	21.8	20.9	18.0	14.1	10.3	7.6
		MCWB	5.3	4.4	5.8	8.5	12.9	15.7	18.4	17.7	15.7	12.7	9.4	6.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	7.5	9.3	12.1	16.7	19.9	22.2	21.4	18.9	15.7	12.9	9.7
		MCDB	9.4	8.4	12.3	15.1	19.5	22.6	24.9	24.6	20.5	16.7	13.5	10.2
	2%	WB	7.1	6.4	7.7	10.8	15.3	18.2	20.9	20.0	17.8	14.6	11.4	8.6
		MCDB	7.7	7.2	9.2	12.9	17.4	20.4	23.3	22.4	19.4	15.6	12.0	9.3
	5%	WB	6.2	5.4	6.7	9.7	14.2	17.0	19.7	19.2	16.9	13.7	10.3	7.8
		MCDB	6.8	6.3	8.0	11.6	15.9	19.0	22.2	21.3	18.4	14.8	11.0	8.4
	10%	WB	5.3	4.6	5.9	8.8	13.2	16.1	18.9	18.4	16.2	12.9	9.5	6.8
		MCDB	6.0	5.3	7.1	10.5	15.0	18.2	21.2	20.3	17.6	13.9	10.2	7.5
Mean Daily Temperature Range	5% DB	MDBR	3.0	3.0	4.0	5.0	5.6	6.2	6.1	5.5	4.6	3.7	2.9	2.9
		MCDBR	3.4	4.0	5.8	6.8	7.3	8.0	7.9	6.8	5.3	4.3	2.9	3.1
		MCWBR	3.2	3.1	4.0	4.4	4.8	5.0	4.7	4.0	3.5	3.3	2.8	3.1
	5% WB	MCDBR	3.4	3.8	5.6	6.5	6.7	7.0	7.0	6.2	4.8	4.2	2.8	3.1
		MCWBR	3.3	3.2	4.1	4.6	4.9	4.9	4.6	4.2	3.5	3.3	2.8	3.1
Clear-Sky Solar Irradiance	taub	0.320	0.341	0.368	0.399	0.392	0.388	0.408	0.409	0.379	0.361	0.341	0.311	
	taud	2.314	2.326	2.289	2.269	2.356	2.394	2.354	2.361	2.426	2.414	2.355	2.294	
	Ebn at Noon	610	733	797	822	853	860	832	806	784	703	578	530	
	Edh at Noon	56	78	101	117	114	111	114	107	88	71	55	47	
All-Sky Solar Radiation	RadAvg	0.47	1.08	2.42	4.17	5.33	5.70	5.29	4.26	3.05	1.54	0.61	0.33	
	RadStd	0.07	0.18	0.23	0.49	0.56	0.41	0.61	0.30	0.28	0.21	0.09	0.03	

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (69 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.38	N/A	N/A	N/A	N/A	-161	N/A	N/A

Nomenclature: See separate page