

GEDSER, Denmark

WMO: 061490

Lat: 54.5686N

Lon: 11.9436E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.1	24.7	14.9	11.7	23.4	18.4	13.9	26.3	58.0	38.6	49.3	40.3	11.9	110	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	74.0	66.8	71.7	65.6	69.8	64.5	68.1	72.2	66.7	70.3	65.3	68.7	10.5	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	97.5	70.6	65.1	92.9	69.1	63.7	88.5	67.8	32.4	72.2	31.3	70.4	30.2	68.9	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.7	33.6	29.6	DB	17.3	78.2	5.1	1.9	13.6	79.5	10.6	80.6	7.7	81.7	4.0	83.1	(4)
(5)			WB	16.3	69.8	4.3	2.2	13.2	71.4	10.6	72.7	8.2	74.0	5.1	75.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.7	34.5	34.5	38.0	44.6	52.7	59.4	63.8	63.9	59.0	51.0	43.8	38.2		
	DBStd	11.64	5.88	4.96	5.00	4.20	4.37	3.90	3.82	3.42	4.18	4.75	4.94	5.52		
	HDD50	2080	482	433	373	168	22	0	0	0	0	46	191	365		
	HDD65	6017	947	853	838	612	381	174	70	60	182	435	635	830		
	CDD50	1607	0	0	0	6	106	281	429	432	271	77	5	0		
	CDD65	70	0	0	0	0	0	5	34	27	4	0	0	0		
	CDH74	61	0	0	0	0	0	7	38	16	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	14.9	17.4	16.0	15.0	13.6	12.7	13.6	12.8	12.8	13.9	15.9	17.0	18.1		
	PrecAvg	24.1	2.0	1.6	1.4	1.3	1.8	2.4	2.2	2.6	2.3	2.1	2.2	2.2		
(15) Precipitation	PrecMax	33.4	3.5	3.5	3.1	3.0	4.3	5.6	9.6	8.4	5.8	4.5	4.8	4.6		
	PrecMin	17.6	0.0	0.7	0.3	0.2	0.4	0.0	0.3	0.5	0.8	1.1	0.2	0.7		
	PrecStd	3.8	0.9	0.7	0.7	0.6	1.0	1.4	1.7	1.5	1.3	0.8	1.2	1.0		
	PrecStd	3.8	0.9	0.7	0.7	0.6	1.0	1.4	1.7	1.5	1.3	0.8	1.2	1.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.5	45.2	49.5	59.5	68.4	74.5	77.7	76.2	71.3	61.9	55.8	49.1		
		MCWB	45.5	43.0	45.1	52.8	60.0	66.9	69.0	67.9	64.5	58.6	53.9	47.4		
	2%	DB	45.0	43.2	46.6	54.6	64.2	70.0	74.7	73.2	68.5	59.8	53.3	47.6		
		MCWB	43.4	41.5	43.5	49.5	58.2	63.6	67.6	66.3	63.2	57.2	51.5	46.1		
	5%	DB	43.6	42.0	44.9	52.2	61.7	67.3	72.6	71.0	66.5	58.2	51.7	46.2		
		MCWB	42.2	40.5	42.6	48.3	56.8	61.7	66.2	65.3	62.1	55.7	50.0	44.8		
	10%	DB	42.0	40.7	43.6	50.1	59.2	65.3	70.5	69.2	64.8	56.9	50.3	44.7		
		MCWB	40.8	39.4	41.8	46.9	55.2	60.4	65.1	64.5	60.7	54.7	48.6	43.4		
	0.4%	WB	46.1	43.6	46.1	53.2	62.0	67.7	70.6	69.6	66.5	59.9	54.5	47.7		
		MCDB	47.2	44.4	48.4	57.7	66.4	73.1	75.5	74.1	69.1	61.2	55.5	48.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	43.7	42.0	44.2	50.7	59.5	64.8	68.7	67.8	64.2	57.6	52.1	46.4		
		MCDB	44.6	43.0	45.6	53.5	62.9	68.5	73.4	71.0	67.4	59.1	53.2	47.3		
	5%	WB	42.3	40.7	43.1	48.9	57.6	62.9	67.2	66.4	62.6	56.2	50.3	45.0		
		MCDB	43.3	41.6	44.4	51.5	60.6	66.3	71.4	69.6	65.8	57.7	51.5	45.8		
	10%	WB	41.0	39.6	42.1	47.3	55.7	61.3	65.6	65.2	61.3	55.0	48.8	43.7		
		MCDB	41.8	40.6	43.3	49.7	58.6	64.5	69.4	68.3	64.4	56.6	50.0	44.6		
	5% DB	MDBR	5.0	4.5	5.9	7.8	8.5	8.8	8.3	7.6	7.2	5.7	4.9	4.7		
		MCDBR	4.5	4.7	7.4	11.5	12.4	12.4	12.2	10.5	8.9	6.1	3.9	4.6		
		MCWBR	4.4	4.0	5.5	7.4	7.9	8.1	7.0	6.6	5.9	5.0	4.0	4.6		
		MCWBR	4.5	4.5	6.7	10.5	11.6	10.9	10.9	9.3	8.0	5.7	3.9	4.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.5	4.1	5.3	7.2	8.1	7.7	6.9	6.5	5.9	4.9	4.0	4.6		
		MCWBR	4.5	4.1	5.3	7.2	8.1	7.7	6.9	6.5	5.9	4.9	4.0	4.6		
		MCWBR	4.5	4.1	5.3	7.2	8.1	7.7	6.9	6.5	5.9	4.9	4.0	4.6		
		MCWBR	4.5	4.1	5.3	7.2	8.1	7.7	6.9	6.5	5.9	4.9	4.0	4.6		
(40) Clear-Sky Solar Irradiance	taub		0.320	0.342	0.370	0.401	0.394	0.390	0.410	0.410	0.380	0.362	0.341	0.312		
	taud		2.318	2.329	2.282	2.259	2.356	2.392	2.353	2.362	2.427	2.422	2.365	2.302		
	Ebn at Noon		196	234	252	261	270	272	264	256	249	224	187	171		
	Edh at Noon		18	25	32	38	36	35	36	34	28	23	17	15		
(44) All-Sky Solar Radiation	RadAvg		152	348	761	1315	1681	1794	1665	1343	966	498	200	108		
	RadStd		22	60	70	154	181	124	189	94	90	67	26	10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (62 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-279	N/A	N/A

Nomenclature: See separate page