

GEDSER, Denmark

WMO: 061490

Lat: 54.5686N

Lon: 11.9436E

Elev: 5

StdP: 101.26

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.1	-4.0	-9.5	1.7	-4.8	-7.6	2.0	-3.2	25.9	3.7	22.1	4.6	5.3	110	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.2	23.3	19.3	22.1	18.7	21.0	18.0	20.1	22.3	19.3	21.3	18.5	20.4	4.7	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	13.9	21.5	18.4	13.3	20.6	17.6	12.6	19.9	57.5	22.4	54.8	21.3	52.4	20.5	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.0	13.2	DB	-8.2	25.7	2.8	1.1	-10.2	26.4	-11.9	27.0	-13.5	27.6	-15.6	28.4	(4)
(5)			WB	-8.7	21.0	2.4	1.2	-10.5	21.9	-11.9	22.6	-13.2	23.3	-15.0	24.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.4	1.4	3.3	7.0	11.5	15.2	17.7	17.7	15.0	10.5	6.6	3.5	(6)	
	DBStd	6.47	3.27	2.76	2.78	2.33	2.43	2.17	2.12	1.90	2.32	2.64	2.75	3.07	(7)	
	HDD10.0	1156	268	241	207	93	12	0	0	0	0	26	106	203	(8)	
	HDD18.3	3343	526	474	466	340	212	97	39	33	101	242	353	461	(9)	
	CDD10.0	893	0	0	0	3	59	156	238	240	151	43	3	0	(10)	
	CDD18.3	39	0	0	0	0	0	3	19	15	2	0	0	0	(11)	
	CDH23.3	34	0	0	0	0	0	4	21	9	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.7	7.8	7.1	6.7	6.1	5.7	6.1	5.7	5.7	6.2	7.1	7.6	8.1	(14)	
(15) Precipitation	PrecAvg	613	50	40	35	32	45	60	57	65	58	53	55	55	(15)	
	PrecMax	849	89	90	80	77	110	141	243	213	148	114	122	116	(16)	
	PrecMin	447	0	17	7	6	9	1	7	13	21	27	6	19	(17)	
	PrecStd	97	23	17	18	15	25	35	44	39	32	21	30	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.6	7.3	9.7	15.3	20.2	23.6	25.4	24.5	21.8	16.6	13.2	9.5	(19)	
		MCWB	7.5	6.1	7.3	11.5	15.6	19.4	20.6	19.9	18.1	14.8	12.2	8.5	(20)	
	2%	DB	7.2	6.2	8.1	12.6	17.9	21.1	23.7	22.9	20.3	15.5	11.8	8.6	(21)	
		MCWB	6.3	5.3	6.4	9.7	14.5	17.6	19.8	19.0	17.3	14.0	10.8	7.8	(22)	
	5%	DB	6.4	5.5	7.2	11.2	16.5	19.6	22.5	21.7	19.2	14.5	11.0	7.9	(23)	
		MCWB	5.7	4.7	5.9	9.1	13.8	16.5	19.0	18.5	16.7	13.2	10.0	7.1	(24)	
	10%	DB	5.6	4.8	6.5	10.1	15.1	18.5	21.4	20.7	18.2	13.8	10.2	7.1	(25)	
		MCWB	4.9	4.1	5.4	8.3	12.9	15.8	18.4	18.0	16.0	12.6	9.2	6.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	6.4	7.8	11.8	16.6	19.8	21.4	20.9	19.2	15.5	12.5	8.7	(27)	
		MCDB	8.4	6.9	9.1	14.3	19.1	22.9	24.2	23.4	20.6	16.2	13.1	9.1	(28)	
	2%	WB	6.5	5.5	6.8	10.4	15.3	18.2	20.4	19.9	17.9	14.2	11.1	8.0	(29)	
		MCDB	7.0	6.1	7.5	12.0	17.2	20.3	23.0	21.7	19.7	15.1	11.8	8.5	(30)	
	5%	WB	5.7	4.8	6.2	9.4	14.2	17.2	19.6	19.1	17.0	13.4	10.2	7.2	(31)	
		MCDB	6.3	5.3	6.9	10.9	15.9	19.0	21.9	20.9	18.8	14.3	10.8	7.7	(32)	
	10%	WB	5.0	4.2	5.6	8.5	13.1	16.3	18.7	18.4	16.3	12.8	9.3	6.5	(33)	
		MCDB	5.4	4.8	6.3	9.8	14.8	18.1	20.8	20.2	18.0	13.7	10.0	7.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.8	2.5	3.3	4.3	4.7	4.9	4.6	4.2	4.0	3.2	2.7	2.6	(35)	
		MCDBR	2.5	2.6	4.1	6.4	6.9	6.9	6.8	5.8	5.0	3.4	2.2	2.6	(36)	
	5% WB	MCWBR	2.5	2.2	3.0	4.1	4.4	4.5	3.9	3.7	3.3	2.8	2.2	2.6	(37)	
		MCWBR	2.5	2.5	3.7	5.8	6.5	6.1	6.0	5.2	4.5	3.2	2.2	2.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.320	0.342	0.370	0.401	0.394	0.390	0.410	0.410	0.380	0.362	0.341	0.312	(40)	
		taud	2.318	2.329	2.282	2.259	2.356	2.392	2.353	2.362	2.427	2.422	2.365	2.302	(41)	
	Ebn at Noon		617	737	796	822	852	858	831	806	785	707	588	540	(42)	
		Edh at Noon	57	78	102	119	114	111	114	107	88	72	55	47	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.48	1.10	2.40	4.15	5.30	5.65	5.25	4.23	3.04	1.57	0.63	0.34	(44)	
	RadStd		0.07	0.19	0.22	0.49	0.57	0.39	0.60	0.30	0.28	0.21	0.08	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (62 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-155	N/A	N/A

Nomenclature: See separate page