

OMOE FYR, Denmark

WMO: 061510

Lat: 55.1592N

Lon: 11.1347E

Elev: 10

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.6	25.1	16.3	12.5	24.6	19.1	14.4	26.1	61.4	40.7	54.0	42.0	15.9	50	0.792

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	75.9	67.4	73.3	66.3	71.1	65.0	68.7	73.9	67.1	72.1	65.6	70.1	10.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	97.8	72.2	65.0	92.4	70.1	63.7	88.3	68.6	32.9	74.1	31.6	72.3	30.5	70.4	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 43.3	35.6	31.2	DB	20.0	80.5	3.8	4.7	17.3	83.9	15.1	86.6	13.0	89.2	10.3	92.6	
(5)			WB	18.7	71.0	3.7	2.1	16.1	72.5	13.9	73.8	11.8	74.9	9.1	76.5	(4)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	35.2	34.9	38.4	45.7	53.9	60.1	64.9	64.8	59.5	51.6	44.5	39.0	
	DBStd	11.72	5.63	4.92	4.90	4.32	4.55	3.84	4.34	3.59	3.73	4.59	4.71	5.35	
	HDD50	1945	458	423	360	141	14	0	0	0	0	37	170	342	
	HDD65	5777	923	843	825	580	343	153	57	48	169	414	615	807	
	CDD50	1750	0	0	0	12	136	302	463	458	285	88	6	0	
	CDD65	104	0	0	0	0	0	5	55	41	3	0	0	0	
	CDH74	176	0	0	0	0	0	5	122	49	0	0	0	0	
	CDH80	9	0	0	0	0	0	0	6	3	0	0	0	0	
Wind	WSAvg	16.6	19.7	17.9	16.3	14.6	14.2	15.5	13.5	13.8	15.9	17.9	19.6	19.9	
Precipitation	PrecAvg	24.1	2.0	1.5	1.4	1.3	1.6	2.4	2.3	2.6	2.4	2.3	2.2	2.1	
	PrecMax	30.3	4.0	2.6	3.0	2.8	3.1	5.2	4.9	5.8	6.5	4.6	4.6	3.9	
	PrecMin	15.7	0.2	0.2	0.3	0.3	0.5	0.0	0.2	0.9	0.5	0.9	0.4	0.8	
	PrecStd	3.6	0.9	0.5	0.7	0.6	0.7	1.3	1.1	1.5	1.4	0.9	1.0	0.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	45.7	50.8	60.7	69.8	75.1	80.8	78.6	71.7	63.0	55.6	49.7	
		MCWB	45.6	43.2	46.4	54.0	62.2	66.6	69.5	68.8	65.3	59.3	54.0	47.9	
	2%	DB	45.5	43.8	47.4	56.6	66.0	71.1	77.3	74.9	68.8	60.4	53.4	47.6	
		MCWB	43.6	41.9	44.0	50.7	59.1	63.8	68.0	67.2	63.2	57.5	51.8	46.0	
	5%	DB	44.0	42.4	45.4	54.0	63.5	68.6	74.5	72.6	66.5	58.6	51.8	46.5	
		MCWB	42.4	40.9	42.8	49.2	57.7	62.3	66.7	66.0	61.9	56.3	50.2	45.2	
	10%	DB	42.5	41.1	43.9	51.6	60.9	66.3	72.0	70.3	64.7	57.3	50.5	45.2	
		MCWB	41.2	39.8	41.8	47.9	56.2	60.9	65.8	64.8	60.7	55.1	48.9	43.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	44.0	46.7	54.3	63.7	67.9	71.5	70.1	66.3	60.3	54.5	48.3
			MCDB	47.6	45.1	49.9	59.7	68.9	74.0	78.7	75.4	70.2	62.7	55.3	49.3
2%		WB	44.0	42.3	44.5	51.7	60.3	64.8	69.3	68.2	64.0	58.1	52.2	46.6	
		MCDB	45.1	43.3	46.5	55.6	64.4	69.2	74.8	73.4	67.3	59.8	53.1	47.3	
5%		WB	42.7	41.1	43.2	49.8	58.4	63.2	67.7	66.8	62.6	56.7	50.5	45.4	
		MCDB	43.8	42.2	44.9	53.1	62.4	67.2	72.8	71.4	65.7	58.3	51.6	46.3	
10%		WB	41.3	39.9	42.2	48.3	56.5	61.6	66.3	65.5	61.3	55.5	49.1	44.0	
		MCDB	42.4	41.0	43.6	51.3	60.0	65.4	71.2	69.5	64.1	57.0	50.3	45.0	
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.4	6.0	8.3	9.2	9.6	9.7	8.3	7.4	5.6	4.4	4.3	
		MCDBR	4.6	5.1	7.7	11.5	12.8	13.4	13.5	11.7	9.7	6.7	4.4	4.2	
		MCWBR	4.4	4.1	5.5	7.5	8.3	8.5	7.6	6.8	6.4	5.3	4.4	4.0	
	5% WB	MCDBR	4.5	5.0	7.4	10.5	11.8	12.0	12.7	10.5	9.1	6.4	4.3	4.0	
		MCWBR	4.4	4.2	5.6	7.2	8.1	8.4	7.6	6.8	6.4	5.3	4.5	4.1	
Clear-Sky Solar Irradiance	taub	0.319	0.340	0.367	0.402	0.394	0.388	0.408	0.408	0.381	0.359	0.339	0.309		
	taud	2.288	2.311	2.282	2.236	2.333	2.378	2.340	2.348	2.406	2.411	2.341	2.269		
	Ebn at Noon	190	231	252	259	269	272	263	255	247	223	181	165		
	Edh at Noon	18	25	32	38	37	36	36	34	28	23	17	15		
All-Sky Solar Radiation	RadAvg	148	341	784	1317	1683	1802	1675	1342	959	485	191	106		
	RadStd	24	55	74	157	169	127	183	91	93	62	28	9		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (67 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-293	N/A	N/A	

Nomenclature: See separate page