

ROESNAES FYR, Denmark

WMO: 061590

Lat: 55.7436N

Lon: 10.8694E

Elev: 49

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.8	25.9	16.7	12.8	26.0	19.5	14.7	27.3	47.7	37.1	43.8	39.0	16.0	90	0.856

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	75.6	66.6	73.1	65.5	70.9	64.4	68.2	73.5	66.6	71.4	65.2	69.8	10.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	96.2	71.5	64.6	91.4	70.0	63.2	86.9	68.4	32.5	73.6	31.3	71.6	30.2	69.8	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
42.5	36.9	33.3	DB	21.7	79.8	3.4	2.5	19.3	81.6	17.2	83.1	15.3	84.6	12.8	86.4
			WB	20.1	70.6	3.1	2.1	17.9	72.1	16.0	73.3	14.3	74.5	12.0	76.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	35.4	34.7	38.2	45.5	53.6	59.5	64.5	64.7	59.1	51.5	44.2	39.0
	DBStd	11.58	4.98	4.76	4.60	4.64	4.70	4.07	4.45	3.76	3.74	4.23	4.51	5.30
	HDD50	1968	452	429	367	150	17	0	0	0	0	33	178	342
	HDD65	5855	917	849	832	585	356	170	65	52	181	418	623	807
	CDD50	1692	0	0	0	15	128	285	450	456	273	81	4	0
	CDD65	102	0	0	0	0	1	5	50	43	3	0	0	0
	CDH74	154	0	0	0	0	3	4	84	61	2	0	0	0
	CDH80	5	0	0	0	0	0	0	4	1	0	0	0	0
Wind	WSAvg	17.9	20.9	19.1	17.6	15.2	15.2	16.2	14.8	16.2	18.0	19.4	20.6	21.3
Precipitation	PrecAvg	22.5	1.7	1.4	1.3	1.3	1.5	2.5	2.2	2.6	2.3	2.1	1.9	2.0
	PrecMax	31.0	3.3	2.6	3.0	2.7	2.8	5.5	4.4	6.1	5.5	3.9	4.9	4.0
	PrecMin	15.4	0.0	0.3	0.4	0.2	0.6	0.2	0.4	0.8	0.5	0.9	0.3	0.8
	PrecStd	3.5	0.8	0.6	0.7	0.7	0.6	1.3	1.2	1.4	1.3	0.8	0.9	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.3	45.5	50.9	62.5	70.8	74.4	79.9	79.0	72.4	62.3	54.9	49.8
		MCWB	44.4	43.4	45.9	51.9	59.6	65.3	68.4	68.0	64.1	58.0	53.0	48.1
	2%	DB	45.1	43.2	47.2	58.1	65.9	70.4	76.2	75.5	68.6	59.5	53.1	48.0
		MCWB	42.8	41.6	43.5	50.7	58.0	63.2	67.4	66.4	62.5	56.2	51.1	46.5
	5%	DB	43.5	41.9	45.2	54.6	62.8	67.9	73.6	72.8	65.9	58.1	51.5	46.8
		MCWB	41.7	40.5	42.3	49.1	56.9	61.9	66.3	65.4	60.9	55.3	49.5	45.5
	10%	DB	42.0	40.7	43.6	51.9	60.3	65.7	71.4	70.6	64.0	56.8	50.0	45.5
		MCWB	40.6	39.4	41.4	47.5	55.5	60.2	65.0	64.4	59.8	54.3	48.1	44.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.8	44.0	46.4	54.5	62.1	67.0	70.8	70.0	65.7	59.2	53.8	48.7
		MCDB	45.7	44.9	49.8	60.7	67.4	71.9	77.5	75.9	69.6	60.9	54.7	49.3
	2%	WB	43.1	42.1	44.1	51.6	59.7	64.5	68.6	68.0	63.4	57.1	51.6	46.9
		MCDB	44.1	42.8	46.1	56.2	64.0	68.9	74.2	73.2	67.0	58.9	52.6	47.6
	5%	WB	41.8	40.8	42.9	49.7	57.8	62.7	67.1	66.5	61.7	55.8	49.8	45.8
		MCDB	42.8	41.6	44.7	53.4	61.6	66.4	72.3	71.1	65.2	57.6	51.1	46.6
	10%	WB	40.5	39.5	41.7	48.1	55.8	61.1	65.7	65.2	60.3	54.8	48.3	44.3
		MCDB	41.6	40.5	43.3	51.3	59.6	64.8	70.5	69.4	63.4	56.6	49.8	45.3
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.4	5.8	7.9	8.8	8.7	8.8	8.0	6.5	4.9	4.0	4.1
		MCDBR	4.8	5.1	7.9	12.1	12.5	11.8	11.9	11.5	9.4	6.0	4.3	4.2
		MCWBR	4.9	4.3	5.6	7.8	8.3	8.0	7.4	6.9	6.1	4.8	4.3	4.3
	5% WB	MCDBR	4.7	4.8	7.3	10.4	11.0	10.8	10.8	9.7	8.5	5.7	4.1	4.2
		MCWBR	4.8	4.4	5.5	7.2	7.8	8.0	7.4	6.9	6.2	5.0	4.3	4.4
Clear-Sky Solar Irradiance	taub	0.316	0.338	0.361	0.395	0.389	0.382	0.402	0.402	0.376	0.355	0.335	0.303	
	taud	2.285	2.317	2.309	2.263	2.356	2.404	2.362	2.371	2.425	2.418	2.331	2.253	
	Ebn at Noon	187	230	253	261	271	274	265	257	247	222	178	160	
	Edh at Noon	17	24	31	37	36	35	36	33	28	22	17	14	
All-Sky Solar Radiation	RadAvg	141	330	787	1312	1691	1822	1689	1345	951	471	181	101	
	RadStd	25	53	73	154	157	134	179	93	93	60	29	10	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (69 neighbors)	DBAvg	+0.70	N/A	N/A	N/A	N/A	-209	-304	N/A	N/A

Nomenclature: See separate page