

ROESNAES FYR, Denmark

WMO: 061590

Lat: 55.7436N

Lon: 10.8694E

Elev: 15

StdP: 101.14

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.5	-3.4	-8.5	1.8	-3.3	-6.9	2.1	-2.6	21.3	2.8	19.6	3.9	7.2	90	0.856

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.5	24.2	19.2	22.8	18.6	21.6	18.0	20.1	23.1	19.2	21.9	18.5	21.0	4.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	13.7	22.0	18.1	13.1	21.1	17.3	12.4	20.2	57.6	23.1	54.8	22.0	52.3	21.0	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	16.5	14.9	DB	-5.7	26.6	1.9	1.4	-7.1	27.6	-8.2	28.4	-9.3	29.2	-10.7	30.2	(4)
(5)			WB	-6.6	21.5	1.7	1.2	-7.8	22.3	-8.9	23.0	-9.8	23.6	-11.1	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	1.9	1.5	3.4	7.5	12.0	15.3	18.1	18.2	15.0	10.8	6.8	3.9	(6)	
	DBStd	6.43	2.77	2.64	2.56	2.58	2.61	2.26	2.47	2.09	2.08	2.35	2.51	2.95	(7)	
	HDD10.0	1093	251	238	204	83	9	0	0	0	0	18	99	190	(8)	
	HDD18.3	3253	509	472	462	325	198	94	36	29	101	232	346	448	(9)	
	CDD10.0	940	0	0	0	8	71	158	250	253	152	45	2	0	(10)	
	CDD18.3	57	0	0	0	0	1	3	28	24	2	0	0	0	(11)	
	CDH23.3	86	0	0	0	0	2	2	47	34	1	0	0	0	(12)	
	CDH26.7	3	0	0	0	0	0	0	2	1	0	0	0	0	(13)	
(14) Wind	WSAvg	8.0	9.4	8.5	7.9	6.8	6.8	7.2	6.6	7.3	8.1	8.7	9.2	9.5	(14)	
(15) Precipitation	PrecAvg	572	42	35	34	33	38	63	55	65	58	53	48	51	(15)	
	PrecMax	787	83	67	76	69	70	139	111	154	139	100	124	101	(16)	
	PrecMin	392	0	7	9	6	16	5	9	21	13	23	8	21	(17)	
	PrecStd	88	21	14	19	17	16	33	30	35	32	21	24	21	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	7.5	10.5	16.9	21.5	23.6	26.6	26.1	22.4	16.8	12.7	9.9	(19)	
		MCWB	6.9	6.4	7.7	11.1	15.3	18.5	20.2	20.0	17.8	14.4	11.6	9.0	(20)	
	2%	DB	7.3	6.2	8.4	14.5	18.8	21.4	24.6	24.2	20.4	15.3	11.7	8.9	(21)	
		MCWB	6.0	5.3	6.4	10.4	14.4	17.3	19.6	19.1	16.9	13.5	10.6	8.1	(22)	
	5%	DB	6.4	5.5	7.3	12.5	17.1	19.9	23.1	22.7	18.8	14.5	10.8	8.2	(23)	
		MCWB	5.4	4.7	5.7	9.5	13.8	16.6	19.0	18.6	16.1	13.0	9.7	7.5	(24)	
	10%	DB	5.5	4.8	6.5	11.1	15.7	18.7	21.9	21.5	17.8	13.8	10.0	7.5	(25)	
		MCWB	4.8	4.1	5.2	8.6	13.0	15.6	18.3	18.0	15.4	12.4	8.9	6.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	6.7	8.0	12.5	16.7	19.5	21.6	21.1	18.7	15.1	12.1	9.3	(27)	
		MCDB	7.6	7.2	9.9	15.9	19.7	22.2	25.3	24.4	20.9	16.0	12.6	9.6	(28)	
	2%	WB	6.2	5.6	6.7	10.9	15.4	18.1	20.4	20.0	17.5	14.0	10.9	8.3	(29)	
		MCDB	6.7	6.0	7.8	13.5	17.8	20.5	23.4	22.9	19.4	14.9	11.5	8.6	(30)	
	5%	WB	5.4	4.9	6.1	9.8	14.3	17.0	19.5	19.2	16.5	13.2	9.9	7.7	(31)	
		MCDB	6.0	5.3	7.0	11.9	16.4	19.1	22.4	21.7	18.4	14.2	10.6	8.1	(32)	
	10%	WB	4.7	4.2	5.4	8.9	13.2	16.2	18.7	18.4	15.7	12.7	9.1	6.8	(33)	
		MCDB	5.3	4.7	6.3	10.7	15.3	18.2	21.4	20.8	17.5	13.7	9.9	7.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.3	2.4	3.2	4.4	4.9	4.9	4.9	4.5	3.6	2.7	2.2	2.3	(35)	
		MCDBR	2.7	2.8	4.4	6.7	7.0	6.5	6.6	6.4	5.2	3.3	2.4	2.4	(36)	
	5% WB	MCWBR	2.7	2.4	3.1	4.4	4.6	4.5	4.1	3.8	3.4	2.7	2.4	2.4	(37)	
		MCWBR	2.6	2.7	4.1	5.8	6.1	6.0	6.0	5.4	4.7	3.1	2.3	2.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.316	0.338	0.361	0.395	0.389	0.382	0.402	0.402	0.376	0.355	0.335	0.303	(40)	
		taud	2.285	2.317	2.309	2.263	2.356	2.404	2.362	2.371	2.425	2.418	2.331	2.253	(41)	
	Ebn at Noon		589	725	799	822	853	863	834	809	780	699	561	505	(42)	
		Edh at Noon	55	77	97	117	113	109	112	105	87	69	53	45	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.44	1.04	2.48	4.13	5.33	5.75	5.32	4.24	3.00	1.49	0.57	0.32	(44)	
	RadStd		0.08	0.17	0.23	0.49	0.50	0.42	0.56	0.29	0.29	0.19	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (69 neighbors)		+0.39	N/A	N/A	N/A	N/A	N/A	-116	-169	N/A	N/A

Nomenclature: See separate page