

VAERLOSE, Denmark

WMO: 061600

Lat: 55.767N

Lon: 12.343E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	18.6	10.1	9.2	19.3	13.7	11.1	22.2	32.4	40.3	27.7	40.4	3.1	20	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	80.3	65.3	77.1	64.5	73.7	63.3	68.2	74.3	66.4	73.3	64.9	71.8	8.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	96.6	70.6	64.3	90.5	68.8	62.5	84.8	67.1	32.5	73.9	31.0	72.6	29.9	71.3	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.6	22.6	20.0	DB	4.0	84.1	5.8	3.4	-0.1	86.5	-3.5	88.5	-6.7	90.4	-10.9	92.9	(4)
(5)			WB	3.8	71.5	5.8	2.4	-0.4	73.2	-3.9	74.6	-7.1	76.0	-11.4	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	32.6	33.5	36.0	44.5	51.4	57.4	62.5	62.9	55.8	47.8	40.1	34.1		
	DBStd	12.44	7.08	6.77	6.22	6.61	4.90	4.69	5.08	5.18	4.93	6.18	5.92	7.25		
	HDD50	2587	540	462	433	191	43	2	0	0	8	113	301	494		
	HDD65	6792	1005	882	898	615	422	234	113	105	277	534	748	959		
	CDD50	1353	0	0	1	26	86	223	387	401	182	44	3	0		
	CDD65	82	0	0	0	0	0	5	35	41	1	0	0	0		
	CDH74	664	0	0	0	4	2	48	319	287	4	0	0	0		
	CDH80	94	0	0	0	0	0	6	61	27	0	0	0	0		
	WSAvg	9.1	9.8	11.0	10.6	9.2	8.8	9.2	7.7	7.8	8.3	9.1	9.0	9.0		
	PrecAvg	26.4	2.0	1.6	1.5	1.5	1.9	2.7	2.6	3.0	2.6	2.6	2.3	2.2		
(15) Precipitation	PrecMax	34.3	3.8	3.5	3.0	3.1	3.4	6.2	7.4	7.9	6.2	5.0	4.6	4.3		
	PrecMin	17.4	0.1	0.2	0.4	0.3	0.5	0.1	0.1	0.8	0.6	1.5	0.7	0.9		
	PrecStd	4.1	1.1	0.7	0.8	0.7	0.9	1.5	1.7	1.7	1.6	1.1	0.8	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.9	49.9	55.6	72.0	71.7	79.2	85.9	82.8	73.8	63.9	55.5	51.6		
		MCWB	46.6	47.0	47.1	58.7	58.6	65.0	66.7	66.4	63.1	58.0	53.6	49.7		
	2%	DB	45.4	47.8	50.8	64.0	68.4	73.8	80.9	80.2	70.4	60.4	52.8	47.7		
		MCWB	44.2	46.3	45.5	53.9	57.5	62.2	65.3	65.5	61.5	56.8	50.7	46.6		
	5%	DB	43.1	45.8	48.1	59.3	65.8	70.5	77.4	77.2	67.4	57.6	50.5	45.5		
		MCWB	42.1	44.5	44.6	51.3	55.3	60.9	64.5	64.6	59.5	55.0	48.6	44.4		
	10%	DB	41.3	43.2	45.5	55.6	62.4	67.6	73.9	73.9	64.4	56.1	48.4	44.0		
		MCWB	40.3	41.6	42.7	48.9	54.0	59.0	63.4	63.9	58.4	53.8	47.0	43.0		
	0.4%	WB	47.3	48.0	50.0	60.2	62.4	68.9	70.9	71.2	66.4	60.1	54.0	49.9		
		MCDB	48.3	48.5	51.9	69.1	69.0	76.4	78.7	77.1	71.7	62.1	55.6	51.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.4	46.3	46.8	55.6	59.0	64.6	68.6	68.0	63.1	57.5	51.2	46.5		
		MCDB	45.2	47.3	49.0	62.0	66.2	70.8	75.4	73.3	67.7	59.3	52.5	47.3		
	5%	WB	42.3	44.3	45.0	52.5	56.7	62.4	66.6	66.5	61.0	56.0	49.1	44.5		
		MCDB	42.9	45.1	47.4	57.8	62.5	68.5	73.8	73.2	65.2	57.7	50.2	45.2		
	10%	WB	40.4	41.8	42.9	50.0	54.9	60.2	64.9	65.1	59.3	54.4	47.1	42.8		
		MCDB	41.0	43.0	45.1	54.0	60.1	66.0	72.1	72.0	63.2	56.1	48.1	43.6		
	5% DB	MDBR	8.2	8.7	11.9	15.2	16.3	15.1	16.5	16.5	13.9	11.3	8.6	8.2		
		MCDBR	7.6	8.8	15.7	20.2	23.1	20.9	23.5	21.8	17.9	11.7	8.4	7.6		
		MCWBR	7.4	7.6	11.3	12.0	13.3	12.1	10.9	9.6	10.3	8.8	7.6	7.6		
		MCWBR	7.5	8.4	13.8	17.9	18.6	18.4	19.2	18.7	15.9	11.0	8.5	7.6		
(35) Mean Daily Temperature Range	5% WB	MCWBR	7.5	7.7	11.0	11.4	11.9	11.5	10.5	9.8	10.1	8.9	8.0	7.7		
	taub		0.314	0.336	0.359	0.393	0.389	0.383	0.405	0.405	0.375	0.356	0.336	0.304		
		taud	2.285	2.309	2.308	2.271	2.342	2.386	2.343	2.350	2.416	2.402	2.325	2.258		
(42) Clear-Sky Solar Irradiance	Ebn at Noon		187	230	254	261	270	273	264	255	248	221	177	160		
		Edh at Noon	17	24	31	37	36	35	36	34	28	22	17	14		
	RadAvg		140	331	770	1312	1694	1802	1673	1343	950	465	178	95		
(45) All-Sky Solar Radiation	RadStd		26	53	82	162	166	141	199	101	95	67	31	10		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (63 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-286	N/A	N/A

Nomenclature: See separate page