

HESSELOE, Denmark

WMO: 061650

Lat: 56.196N

Lon: 11.710E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.0	24.5	14.0	11.2	25.9	17.2	13.1	26.1	60.0	39.3	53.6	39.3	14.9	60	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	73.7	67.0	71.6	65.9	69.8	64.8	68.1	72.3	66.8	70.9	65.5	69.5	9.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	97.4	70.4	65.1	92.9	69.5	63.7	88.6	68.5	32.4	72.4	31.4	70.9	30.4	69.6	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
43.0	35.0	29.9		DB	21.9	78.1	3.4	1.3	19.4	79.1	17.4	79.8	15.4	80.6	12.9	81.5
				WB	20.2	69.6	2.7	1.1	18.3	70.4	16.7	71.1	15.1	71.7	13.2	72.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	35.1	33.9	37.2	45.1	52.9	59.6	64.5	64.5	59.4	50.7	43.6	37.7
	DBStd	11.90	5.83	4.97	4.53	4.19	4.03	3.93	3.96	3.50	3.69	4.80	4.71	5.84
	HDD50	2112	462	452	397	156	17	0	0	0	0	51	196	381
	HDD65	6015	927	872	862	597	374	169	60	52	171	443	642	846
	CDD50	1663	0	0	0	9	108	287	451	450	282	73	3	0
	CDD65	90	0	0	0	0	0	6	45	36	3	0	0	0
	CDH74	44	0	0	0	0	0	5	26	13	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	15.4	18.2	17.3	15.5	13.2	13.3	13.2	11.7	12.9	14.7	17.4	19.5	18.0
Precipitation	PrecAvg	22.1	1.6	1.2	1.3	1.3	1.5	2.3	2.1	2.6	2.1	2.2	1.9	2.0
	PrecMax	29.8	3.6	2.5	2.7	3.1	2.4	4.8	5.4	5.7	5.7	4.7	4.1	4.0
	PrecMin	14.2	0.1	0.2	0.2	0.2	0.5	0.0	0.3	0.9	0.3	0.5	0.4	0.4
	PrecStd	3.5	0.8	0.6	0.7	0.7	0.6	1.3	1.2	1.3	1.2	1.0	0.8	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.7	44.3	49.5	59.1	66.6	73.3	76.7	75.6	70.5	61.7	54.2	49.9
		MCWB	45.9	42.1	45.3	52.1	58.5	66.5	67.1	67.2	64.0	58.5	52.4	48.2
	2%	DB	45.9	43.1	46.0	55.3	62.5	69.8	74.2	73.4	67.9	59.7	52.4	47.4
		MCWB	44.0	41.3	43.0	50.2	56.8	64.0	67.1	67.0	62.4	57.0	50.6	45.7
	5%	DB	44.6	42.1	44.0	53.0	60.4	67.4	72.2	71.2	66.0	58.2	51.2	45.9
		MCWB	42.7	40.5	41.6	48.5	55.1	61.7	66.5	65.4	61.4	55.7	49.2	44.3
	10%	DB	43.1	40.8	42.5	51.0	58.7	65.5	70.5	69.5	64.4	56.7	49.8	44.8
		MCWB	41.4	39.5	40.5	47.4	54.3	60.4	65.5	64.5	60.3	54.2	47.7	43.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	43.1	45.5	53.3	59.9	67.1	70.3	69.0	64.8	59.7	52.9	48.8
		MCDB	47.4	43.8	48.5	57.6	63.9	71.9	72.9	73.4	68.8	60.9	53.8	50.0
	2%	WB	44.6	41.8	43.3	51.0	57.7	64.5	68.6	67.7	63.3	57.6	51.0	45.9
		MCDB	45.6	42.8	45.5	54.8	61.2	68.8	72.4	72.1	66.8	59.3	52.3	46.8
	5%	WB	43.1	40.8	42.1	49.3	56.3	62.8	67.5	66.5	62.0	56.2	49.8	44.8
		MCDB	44.4	41.9	43.8	52.4	59.6	66.5	71.4	70.5	65.2	57.9	51.3	45.7
	10%	WB	41.3	39.5	41.1	48.0	54.8	61.3	66.1	65.4	60.9	54.8	48.3	43.6
		MCDB	42.7	40.8	42.3	50.6	58.0	64.8	70.2	69.1	63.8	56.6	49.6	44.6
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.1	5.3	6.9	7.3	7.4	7.1	6.3	5.6	4.7	4.2	4.3
		MCDBR	4.3	4.1	7.2	9.6	9.3	9.4	9.0	8.2	7.8	6.0	4.6	4.2
		MCWBR	4.6	3.7	5.2	6.4	6.6	6.6	6.3	5.7	5.3	5.0	4.9	4.4
	5% WB	MCDBR	4.2	4.0	6.8	8.5	8.7	8.7	8.3	7.5	7.1	5.7	4.5	4.0
MCWBR		4.7	3.9	5.1	6.0	6.7	6.8	6.3	5.4	5.4	5.3	4.9	4.5	
Clear-Sky Solar Irradiance	taub	0.314	0.336	0.357	0.391	0.386	0.378	0.401	0.401	0.372	0.354	0.333	0.302	
	taud	2.281	2.319	2.331	2.293	2.381	2.429	2.381	2.383	2.443	2.414	2.322	2.254	
	Ebn at Noon	184	228	254	262	271	275	265	256	248	220	174	156	
	Edh at Noon	17	24	30	36	35	34	35	33	27	22	16	14	
All-Sky Solar Radiation	RadAvg	133	318	769	1294	1690	1816	1682	1335	937	457	173	95	
	RadStd	26	54	73	154	154	140	180	101	95	60	29	11	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (65 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-299	N/A	N/A

Nomenclature: See separate page