

HESSELOE, Denmark

WMO: 061650

Lat: 56.196N

Lon: 11.710E

Elev: 18

StdP: 101.11

Time Zone: 1.00 (EUC)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.6	-4.2	-10.0	1.6	-3.4	-8.2	1.9	-3.3	26.8	4.1	24.0	4.1	6.7	60	0.746

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	23.2	19.4	22.0	18.8	21.0	18.2	20.1	22.4	19.3	21.6	18.6	20.8	4.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	13.9	21.4	18.4	13.3	20.8	17.6	12.7	20.3	57.4	22.4	55.1	21.6	52.9	20.9	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.2	15.6	13.4	DB	-5.6	25.6	1.9	0.7	-7.0	26.1	-8.1	26.6	-9.2	27.0	-10.6	27.5	(4)
(5)			WB	-6.5	20.9	1.5	0.6	-7.6	21.4	-8.5	21.7	-9.4	22.1	-10.5	22.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.7	1.0	2.9	7.3	11.6	15.3	18.1	18.1	15.2	10.4	6.4	3.2
	DBStd	6.61	3.24	2.76	2.52	2.33	2.24	2.18	2.20	1.94	2.05	2.66	2.62	3.25
	HDD10.0	1173	257	251	221	87	9	0	0	0	0	28	109	212
	HDD18.3	3342	515	484	479	332	208	94	33	29	95	246	357	470
	CDD10.0	924	0	0	0	5	60	159	251	250	157	41	2	0
	CDD18.3	50	0	0	0	0	0	3	25	20	2	0	0	0
	CDH23.3	24	0	0	0	0	0	3	14	7	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.9	8.1	7.7	6.9	5.9	5.9	5.9	5.2	5.8	6.6	7.8	8.7	8.1
Precipitation	PrecAvg	561	41	31	32	32	38	59	54	66	53	56	49	50
	PrecMax	756	92	64	69	80	62	121	138	146	145	120	104	102
	PrecMin	361	3	6	5	6	13	1	8	24	8	13	10	10
	PrecStd	90	21	14	17	19	15	32	31	33	31	25	21	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	6.8	9.7	15.1	19.2	22.9	24.8	24.2	21.4	16.5	12.3	9.9
		MCWB	7.7	5.6	7.4	11.2	14.7	19.2	19.5	19.6	17.8	14.7	11.3	9.0
	2%	DB	7.7	6.2	7.8	12.9	16.9	21.0	23.5	23.0	20.0	15.4	11.3	8.6
		MCWB	6.7	5.2	6.1	10.1	13.8	17.8	19.5	19.4	16.9	13.9	10.3	7.6
	5%	DB	7.0	5.6	6.7	11.7	15.8	19.6	22.3	21.8	18.9	14.6	10.7	7.7
		MCWB	6.0	4.7	5.3	9.2	12.8	16.5	19.2	18.6	16.3	13.2	9.6	6.8
	10%	DB	6.2	4.9	5.8	10.6	14.8	18.6	21.4	20.8	18.0	13.7	9.9	7.1
		MCWB	5.2	4.2	4.7	8.5	12.4	15.8	18.6	18.1	15.7	12.3	8.7	6.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	6.1	7.5	11.9	15.5	19.5	21.3	20.6	18.2	15.4	11.6	9.3
		MCDB	8.6	6.6	9.2	14.2	17.7	22.2	22.7	23.0	20.4	16.1	12.1	10.0
	2%	WB	7.0	5.5	6.3	10.5	14.3	18.1	20.3	19.8	17.4	14.2	10.6	7.7
		MCDB	7.6	6.0	7.5	12.7	16.2	20.4	22.4	22.3	19.4	15.2	11.3	8.2
	5%	WB	6.2	4.9	5.6	9.6	13.5	17.1	19.7	19.2	16.6	13.4	9.9	7.1
		MCDB	6.9	5.5	6.6	11.4	15.4	19.2	21.9	21.4	18.5	14.4	10.7	7.6
	10%	WB	5.2	4.2	5.0	8.9	12.6	16.3	19.0	18.6	16.0	12.7	9.1	6.4
		MCDB	6.0	4.9	5.7	10.3	14.4	18.2	21.2	20.6	17.7	13.7	9.8	7.0
Mean Daily Temperature Range	5% DB	MDBR	2.4	2.3	2.9	3.8	4.0	4.1	3.9	3.5	3.1	2.6	2.3	2.4
		MCDBR	2.4	2.3	4.0	5.4	5.2	5.2	5.0	4.5	4.3	3.3	2.6	2.3
		MCWBR	2.6	2.1	2.9	3.6	3.7	3.7	3.5	3.2	2.9	2.8	2.7	2.5
	5% WB	MCDBR	2.3	2.2	3.8	4.7	4.8	4.8	4.6	4.2	4.0	3.1	2.5	2.2
		MCWBR	2.6	2.1	2.8	3.3	3.7	3.8	3.5	3.0	3.0	3.0	2.7	2.5
Clear-Sky Solar Irradiance	taub	0.314	0.336	0.357	0.391	0.386	0.378	0.401	0.401	0.372	0.354	0.333	0.302	
	taud	2.281	2.319	2.331	2.293	2.381	2.429	2.381	2.383	2.443	2.414	2.322	2.254	
	Ebn at Noon	579	720	801	825	855	866	835	808	782	694	550	491	
	Edh at Noon	53	75	94	113	110	106	110	103	85	69	52	43	
All-Sky Solar Radiation	RadAvg	0.42	1.00	2.42	4.08	5.33	5.73	5.30	4.21	2.95	1.44	0.55	0.30	
	RadStd	0.08	0.17	0.23	0.48	0.49	0.44	0.57	0.32	0.30	0.19	0.09	0.04	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (65 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-166	N/A	N/A

Nomenclature: See separate page