

TESSEBOELLE, Denmark

WMO: 061740

Lat: 55.3956N

Lon: 12.1492E

Elev: 22

StdP: 101.06

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.0	-5.8	-10.6	1.5	-6.5	-8.7	1.8	-4.3	11.4	4.3	10.7	3.9	2.3	0	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	26.3	18.5	24.5	18.1	22.9	17.3	20.0	24.2	19.0	22.7	18.1	21.4	3.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.4	21.5	17.6	12.7	20.5	16.7	12.0	19.7	57.4	24.1	54.0	22.7	51.2	21.3	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.5	8.5	7.6	DB	-10.5	29.0	4.2	1.9	-13.5	30.3	-16.0	31.5	-18.3	32.5	-21.3	33.9	
			WB	-10.8	22.0	4.1	1.0	-13.8	22.7	-16.2	23.3	-18.5	23.8	-21.5	24.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	1.0	1.1	3.5	7.5	11.5	14.7	17.5	16.9	13.9	9.8	5.8	3.1		
	DBStd	6.55	3.69	3.60	3.60	3.08	3.18	2.52	2.56	2.27	2.37	2.93	3.21	3.73		
	HDD10.0	1221	278	248	203	87	21	1	0	0	2	41	128	213		
	HDD18.3	3480	536	481	461	326	213	113	49	56	133	266	376	472		
	CDD10.0	821	0	0	1	12	66	141	232	215	119	33	3	0		
	CDD18.3	39	0	0	0	0	1	3	22	13	1	0	0	0		
	CDH23.3	283	0	0	0	1	2	30	183	64	3	0	0	0		
	CDH26.7	33	0	0	0	0	0	3	22	8	0	0	0	0		
(14) Wind	WSAvg	3.7	4.4	4.2	4.1	3.6	3.3	3.2	3.0	3.2	3.4	3.6	3.9	4.2		
(15) Precipitation	PrecAvg	632	51	38	38	35	43	57	58	67	67	61	60	56		
	PrecMax	818	90	88	87	83	85	133	131	178	180	128	128	108		
	PrecMin	403	3	6	8	10	7	0	3	13	11	31	15	25		
	PrecStd	97	24	16	18	16	21	31	33	43	43	27	27	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	10.1	14.4	20.1	23.4	26.2	28.8	27.9	23.6	18.4	13.9	11.2		
		MCWB	9.0	7.5	9.8	13.3	16.8	18.5	19.7	19.5	17.4	15.4	12.9	10.1		
	2%	DB	8.1	8.1	11.7	17.2	21.6	23.9	27.0	25.1	21.2	16.1	12.3	9.9		
		MCWB	7.2	6.6	8.5	11.7	15.8	17.8	18.6	18.1	16.7	14.0	11.3	9.2		
	5%	DB	7.1	7.0	9.7	14.9	19.6	21.9	25.5	23.2	19.4	15.0	11.1	8.9		
		MCWB	6.2	5.7	7.1	10.1	14.4	16.6	18.5	17.3	15.8	13.5	10.2	8.0		
	10%	DB	6.2	5.8	8.3	13.0	17.8	20.3	23.7	21.8	18.1	13.9	10.1	7.7		
		MCWB	5.4	4.8	6.4	9.1	13.3	15.5	17.9	16.7	14.9	12.5	9.2	6.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	8.2	10.6	14.2	18.4	20.7	21.4	20.8	18.3	16.1	13.2	10.7		
		MCDB	9.8	9.3	13.2	19.1	21.9	24.4	26.0	25.4	21.5	17.7	13.6	11.1		
	2%	WB	7.5	6.9	8.8	12.2	16.6	18.7	20.3	19.5	17.2	14.6	11.5	9.3		
		MCDB	8.0	7.7	11.0	16.1	20.1	22.3	24.9	22.6	20.1	15.6	12.0	9.7		
	5%	WB	6.4	5.9	7.6	10.9	15.2	17.4	19.4	18.4	16.4	13.6	10.3	8.1		
		MCDB	7.0	6.8	9.2	14.2	18.4	20.7	23.6	21.4	18.8	14.7	10.9	8.8		
	10%	WB	5.4	4.8	6.6	9.6	13.8	16.2	18.5	17.6	15.6	12.7	9.3	7.0		
		MCDB	6.1	5.8	8.0	12.5	16.8	19.5	22.2	20.5	17.5	13.7	9.9	7.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	4.0	5.8	8.2	9.0	9.1	9.5	8.5	7.1	5.5	3.9	3.6		
		MCDBR	4.1	5.1	8.2	11.3	11.7	11.9	12.7	10.6	8.9	6.4	4.2	3.9		
	5% WB	MCWBR	4.0	3.9	5.5	6.7	6.8	6.7	5.8	4.9	5.2	4.7	3.8	3.8		
		MCDWR	3.9	5.0	7.6	10.5	10.2	10.5	11.2	9.2	8.2	6.1	4.2	3.9		
(40) Clear-Sky Solar Irradiance	taub		0.316	0.338	0.362	0.396	0.390	0.385	0.406	0.407	0.376	0.357	0.338	0.307		
		taud	2.293	2.310	2.296	2.260	2.337	2.378	2.338	2.345	2.411	2.402	2.335	2.268		
	Ebn at Noon		599	728	800	823	852	861	832	805	781	700	566	514		
		Edh at Noon	56	78	99	118	116	112	115	108	88	71	54	46		
(44) All-Sky Solar Radiation	RadAvg		0.46	1.06	2.46	4.19	5.37	5.74	5.33	4.28	3.04	1.51	0.58	0.31		
	RadStd		0.08	0.17	0.26	0.50	0.53	0.43	0.62	0.30	0.29	0.21	0.10	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (67 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-163	N/A	N/A

Nomenclature: See separate page