

DROGDEN FYR, Denmark

WMO: 061830

Lat: 55.5365N

Lon: 12.7115E

Elev: 20

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.6	25.0	15.2	11.9	25.3	17.9	13.6	27.1	42.9	38.4	40.3	36.2	21.3	40	0.833

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.8	73.0	65.6	71.0	64.7	69.2	63.4	67.2	71.3	65.8	69.5	64.4	67.8	13.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	94.5	69.6	64.2	89.9	68.1	62.9	85.9	66.8	31.7	71.2	30.6	69.6	29.5	67.9	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
38.6	34.0	31.0	DB	22.2	77.3	3.2	2.8	19.9	79.3	18.0	80.9	16.2	82.5	13.9	84.5
			WB	20.0	68.6	2.8	1.8	18.0	69.9	16.4	70.9	14.9	71.9	12.9	73.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	34.9	34.7	37.6	44.8	52.7	59.2	63.6	64.1	58.6	51.0	44.2	39.3
	DBStd	11.46	5.50	5.03	5.10	4.39	4.91	4.06	4.05	3.44	3.51	4.54	4.68	5.39
	HDD50	2026	469	429	384	167	25	0	0	0	0	43	177	332
	HDD65	5982	934	849	849	607	381	180	78	58	193	433	623	797
	CDD50	1593	0	0	0	10	110	275	422	438	259	75	4	0
	CDD65	74	0	0	0	0	1	5	35	31	2	0	0	0
	CDH74	35	0	0	0	0	0	1	21	13	0	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	17.0	20.1	18.4	16.7	14.2	13.7	15.0	14.1	15.1	17.2	19.0	19.8	20.5
Precipitation	PrecAvg	24.5	1.9	1.3	1.3	1.2	1.9	2.5	2.4	3.1	2.3	2.6	2.1	2.1
	PrecMax	32.9	3.4	3.0	2.5	2.9	3.3	5.4	6.9	7.2	6.1	5.1	5.7	3.8
	PrecMin	16.3	0.0	0.2	0.3	0.3	0.4	0.1	0.1	0.7	0.5	1.0	0.2	0.8
	PrecStd	3.9	0.9	0.6	0.7	0.6	0.7	1.1	1.6	1.9	1.5	1.1	1.1	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.0	46.4	50.9	59.4	69.1	72.2	76.5	75.6	69.4	61.4	54.8	50.0
		MCWB	45.9	43.5	46.5	51.1	59.7	63.2	66.8	66.9	63.6	57.8	53.2	48.2
	2%	DB	45.4	44.0	47.4	55.9	64.8	69.2	73.4	73.0	66.3	59.4	52.8	48.5
		MCWB	43.6	42.1	43.7	48.8	56.9	61.8	66.2	65.5	61.7	56.1	51.0	46.8
	5%	DB	43.9	42.6	45.1	53.0	61.8	66.6	71.5	70.8	64.8	58.1	51.4	47.2
		MCWB	42.3	41.0	42.5	47.5	55.9	60.5	65.5	64.6	60.6	55.1	49.6	45.6
	10%	DB	42.4	41.3	43.6	50.7	59.4	64.7	69.5	69.0	63.5	56.7	50.0	45.9
		MCWB	41.0	39.9	41.5	46.2	54.3	59.4	64.1	63.3	59.5	54.1	48.2	44.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.6	44.0	47.2	52.2	61.7	66.3	69.5	69.0	65.2	58.5	54.0	48.8
		MCDB	47.9	44.6	49.8	55.8	67.1	68.6	74.1	73.7	67.8	60.4	54.7	49.5
	2%	WB	44.3	42.4	44.7	49.9	59.0	63.4	67.8	66.8	63.0	56.6	51.6	47.2
		MCDB	45.4	43.3	46.5	53.5	62.6	67.8	71.9	70.8	65.4	58.5	52.6	48.0
	5%	WB	42.8	41.0	43.2	48.2	57.1	61.8	66.5	65.2	61.5	55.6	50.0	45.7
		MCDB	43.9	42.0	44.9	51.6	60.7	65.6	70.5	68.6	64.1	57.6	51.3	46.7
	10%	WB	41.3	39.6	41.9	46.6	55.4	60.3	65.1	64.0	60.2	54.6	48.6	44.2
		MCDB	42.5	40.8	43.4	49.6	58.8	63.9	69.0	67.1	62.9	56.5	49.9	45.4
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.2	5.3	6.8	7.2	6.6	6.3	5.8	5.0	4.3	3.9	4.1
		MCDBR	4.8	5.4	7.4	10.0	10.7	8.9	8.9	8.0	6.0	4.9	4.0	4.4
		MCWBR	5.0	4.2	5.1	6.0	6.2	5.4	5.2	4.8	4.5	4.2	4.3	4.6
	5% WB	MCDBR	4.8	5.1	6.9	9.2	10.1	7.8	7.4	6.7	5.5	4.4	4.1	4.2
MCWBR		5.1	4.4	5.3	6.2	6.7	5.7	5.1	5.1	4.9	4.4	4.5	4.6	
Clear-Sky Solar Irradiance	taub	0.316	0.338	0.361	0.392	0.388	0.383	0.404	0.405	0.374	0.358	0.339	0.307	
	taud	2.289	2.307	2.298	2.277	2.346	2.387	2.346	2.354	2.422	2.399	2.333	2.263	
	Ebn at Noon	189	230	254	262	271	273	264	256	249	221	178	161	
	Edh at Noon	17	25	31	37	36	35	36	34	28	23	17	14	
All-Sky Solar Radiation	RadAvg	143	336	773	1332	1713	1824	1694	1363	966	475	182	96	
	RadStd	27	53	87	161	171	140	206	99	94	69	32	9	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (63 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-304	+112	N/A

Nomenclature: See separate page