

CHRISTIANSO FYR, Denmark

WMO: 061910

Lat: 55.3206N

Lon: 15.1869E

Elev: 49

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 86-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.6	24.9	17.3	13.2	22.6	20.3	15.2	26.5	53.1	41.0	49.7	40.0	19.1	130	0.861

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	73.7	69.0	71.4	67.6	69.2	65.9	69.9	73.0	68.1	70.8	66.2	68.6	11.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.6	105.1	72.1	66.9	99.2	70.3	65.1	92.9	68.1	33.8	73.1	32.4	71.0	30.9	68.7	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.7	43.1	38.8	DB	23.3	77.4	5.8	3.7	19.1	80.0	15.7	82.2	12.5	84.3	8.3	87.0	(4)
(5)			WB	22.4	71.8	5.2	2.3	18.6	73.5	15.6	74.8	12.6	76.1	8.8	77.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.6	35.8	35.1	37.3	40.9	49.0	57.1	62.4	63.8	57.1	50.4	43.2	38.5	(6)
(7)		DBStd	11.06	5.29	5.63	5.01	3.98	4.26	4.35	4.35	4.25	3.78	4.63	4.15	4.25	(7)
(8)		HDD50	2212	441	416	395	273	71	2	0	0	1	52	205	356	(8)
(9)		HDD65	6405	906	836	860	723	496	240	104	74	238	453	654	821	(9)
(10)		CDD50	1350	0	0	0	0	40	214	386	429	214	65	2	0	(10)
(11)		CDD65	67	0	0	0	0	0	2	25	38	2	0	0	0	(11)
(12)		CDH74	44	0	0	0	0	0	3	21	20	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	18.7	23.2	23.2	19.8	16.3	14.2	13.9	15.2	15.2	19.2	19.4	21.9	23.4	(14)
(15)	Precipitation	PrecAvg	23.3	1.7	1.5	1.5	1.1	1.5	1.7	1.9	2.6	2.6	2.5	2.5	2.2	(15)
(16)		PrecMax	30.4	3.7	3.1	3.1	2.2	4.2	4.2	5.2	8.3	6.0	6.3	6.5	5.1	(16)
(17)		PrecMin	17.5	0.1	0.4	0.2	0.1	0.3	0.0	0.0	0.5	0.8	0.6	1.1	0.9	(17)
(18)		PrecStd	3.5	0.9	0.6	0.8	0.6	0.9	1.1	1.1	1.9	1.3	1.4	1.3	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.4	49.1	49.7	53.4	64.1	71.1	76.3	76.9	71.7	61.1	54.7	48.7	(19)
(20)			MCWB	45.2	47.1	46.6	49.8	58.6	66.0	71.1	70.7	69.5	59.8	53.3	48.1	(20)
(21)		2%	DB	44.4	45.3	45.9	49.9	59.8	67.1	73.5	74.2	65.8	59.0	51.1	46.8	(21)
(22)			MCWB	43.3	43.6	44.4	47.5	56.6	63.3	68.6	69.5	62.8	57.9	49.7	45.9	(22)
(23)		5%	DB	43.1	43.2	44.1	47.9	57.5	64.9	70.9	72.3	63.3	57.5	49.6	45.3	(23)
(24)			MCWB	42.2	42.2	42.9	46.3	54.9	61.8	67.1	68.3	60.9	56.4	48.7	44.4	(24)
(25)		10%	DB	41.9	41.8	42.6	46.3	55.4	62.8	68.3	70.2	61.9	56.4	48.1	44.0	(25)
(26)			MCWB	41.1	41.0	41.5	44.8	53.1	60.1	65.1	67.0	59.6	55.1	47.2	43.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.5	47.6	47.2	50.4	59.3	66.7	72.0	71.9	69.6	60.2	53.7	48.2	(27)
(28)			MCDWB	46.0	49.1	48.8	52.5	63.1	69.6	75.7	74.7	71.7	60.6	54.5	48.4	(28)
(29)		2%	WB	43.6	43.8	44.7	48.1	57.0	63.9	69.4	70.3	63.3	58.2	50.3	46.3	(29)
(30)			MCDWB	44.1	44.9	45.5	49.4	59.5	66.3	72.6	73.4	64.8	58.6	50.8	46.7	(30)
(31)		5%	WB	42.3	42.3	43.1	46.4	55.2	62.1	67.5	68.9	61.5	56.8	48.8	44.6	(31)
(32)			MCDWB	42.8	43.1	43.9	47.6	57.1	64.3	70.0	71.8	62.8	57.3	49.3	45.2	(32)
(33)		10%	WB	41.3	41.2	41.6	45.0	53.4	60.4	65.6	67.3	60.1	55.4	47.3	43.2	(33)
(34)			MCDWB	41.7	41.7	42.4	46.1	55.1	62.4	67.9	69.9	61.6	56.3	47.8	43.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	3.9	4.4	5.1	6.0	5.9	5.6	5.4	4.3	4.1	3.9	4.2	(35)
(36)			MCDBR	4.2	5.0	6.0	7.0	9.4	8.7	8.4	7.2	6.0	5.4	5.4	5.0	(36)
(37)			MCWBR	4.2	4.6	5.1	5.5	6.9	6.4	5.8	5.0	4.7	4.9	5.4	5.0	(37)
(38)		5% WB	MCDWB	3.9	4.8	5.9	6.8	9.0	7.9	7.8	6.8	5.6	4.4	5.0	5.0	(38)
(39)			MCWBR	4.1	4.5	5.3	5.4	7.1	6.2	5.8	5.1	4.7	4.6	5.5	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.342	0.364	0.396	0.393	0.386	0.409	0.411	0.378	0.363	0.344	0.313	(40)	
(41)		taud	2.309	2.330	2.320	2.294	2.375	2.426	2.378	2.373	2.437	2.394	2.325	2.291	(41)	
(42)		Ebn at Noon	190	230	254	261	270	273	263	254	248	220	177	163	(42)	
(43)		Edh at Noon	17	24	31	36	36	34	35	33	28	23	17	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	132	330	778	1375	1806	1940	1765	1422	1001	476	183	94	(44)	
(45)		RadStd	25	60	72	134	174	117	191	105	97	78	32	12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-277	+108	N/A

Nomenclature: See separate page