

K14-FA-1C, Netherlands

WMO: 062040

Lat: 53.269N

Lon: 3.628E

Elev: 89

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	30.8	33.0	19.5	14.7	32.8	22.7	17.1	34.5	46.2	45.3	43.6	45.5	20.7	80	0.840

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.9	69.5	64.6	67.6	63.5	66.5	62.7	65.6	68.6	64.3	67.1	63.3	66.0	15.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.0	89.7	67.7	62.9	86.1	66.4	61.9	83.2	65.6	30.4	68.9	29.5	67.3	28.8	65.9	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
41.7	37.8	34.1	DB	30.3	74.9	4.3	3.1	27.2	77.1	24.7	78.9	22.3	80.7	19.2	82.9
			WB	27.3	67.3	5.2	2.4	23.6	69.0	20.5	70.4	17.6	71.8	13.9	73.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	42.9	41.6	43.4	46.8	51.8	56.7	61.7	63.6	61.0	56.4	50.6	46.4	
	DBStd	8.38	4.26	4.75	4.07	3.76	3.87	3.18	2.98	2.64	3.01	3.50	4.03	4.33	
	HDD50	962	220	237	206	109	24	0	0	0	0	3	40	123	
	HDD65	4786	684	656	669	546	410	249	110	58	125	268	433	578	
	CDD50	1678	0	0	1	13	80	202	364	421	329	200	57	11	
	CDD65	29	0	0	0	0	0	1	9	14	5	0	0	0	
	CDH74	6	0	0	0	0	0	0	5	1	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	17.9	21.2	20.5	18.4	16.4	16.3	14.7	14.5	15.2	16.5	18.8	20.3	22.6	
Precipitation	PrecAvg	38.4	3.7	2.8	2.6	1.8	2.0	2.5	2.9	3.7	3.7	4.1	4.3	4.3	
	PrecMax	49.7	6.5	5.7	5.5	3.9	3.5	5.3	6.8	8.2	7.6	7.5	7.6	7.2	
	PrecMin	28.5	0.5	0.9	0.4	0.1	0.9	0.7	0.5	0.8	0.7	1.5	0.7	2.0	
	PrecStd	5.2	1.5	1.2	1.2	0.9	0.7	1.2	1.4	1.8	1.7	1.7	1.5	1.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	51.8	52.7	60.1	64.7	68.6	73.7	72.1	71.0	66.1	60.3	56.0	
		MCWB	49.8	47.8	48.4	51.8	58.2	63.6	66.5	65.0	66.2	61.5	57.2	53.1	
	2%	DB	51.0	49.6	50.6	55.4	59.7	64.2	68.8	69.6	67.8	63.8	58.9	54.7	
		MCWB	48.4	46.4	47.4	50.2	55.2	60.7	64.6	64.6	63.8	60.6	56.0	52.1	
	5%	DB	49.5	48.3	49.1	53.0	57.8	62.0	67.1	67.9	66.2	62.2	57.5	53.2	
		MCWB	47.0	45.5	46.3	49.0	54.3	58.9	63.5	63.4	62.3	59.0	54.4	50.6	
	10%	DB	48.3	47.3	47.6	51.3	56.5	60.5	65.5	66.6	64.9	61.1	56.2	51.8	
		MCWB	45.8	44.7	45.0	48.1	53.3	57.4	62.1	62.7	61.2	57.9	52.9	49.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.6	48.8	49.2	52.5	58.9	64.6	67.2	66.6	66.7	62.0	58.6	53.8
			MCDB	51.9	50.4	52.0	58.7	61.6	69.0	71.2	70.0	70.2	64.5	60.2	55.1
2%		WB	48.9	47.0	48.0	50.4	56.1	61.2	65.4	65.3	64.6	60.9	56.5	52.6	
		MCDB	50.6	48.7	50.1	54.4	58.9	63.7	68.7	68.3	66.9	63.6	58.3	54.2	
5%		WB	47.4	46.0	46.7	49.4	54.9	59.4	64.0	64.2	63.2	59.7	55.0	51.1	
		MCDB	49.3	47.9	48.7	52.6	57.3	61.7	66.8	67.0	65.6	62.1	57.3	52.9	
10%		WB	46.1	45.0	45.6	48.4	53.7	57.9	62.6	63.4	62.0	58.4	53.2	49.7	
		MCDB	47.9	47.0	47.3	51.1	56.1	60.2	65.1	66.2	64.6	60.8	55.8	51.8	
Mean Daily Temperature Range	5% DB	MDBR	4.4	4.0	4.3	4.5	4.2	4.0	3.9	3.9	3.9	4.2	4.3	4.4	
		MCDBR	5.2	4.6	5.6	6.9	6.2	6.0	5.6	5.2	4.6	5.0	5.1	4.9	
		MCWBR	5.9	4.4	4.7	4.2	4.0	4.8	4.0	4.2	4.6	5.2	5.8	5.8	
	5% WB	MCDBR	5.1	4.6	5.4	6.3	6.1	6.1	5.4	4.7	4.3	5.0	5.1	4.7	
		MCWBR	5.9	4.4	4.9	4.4	4.4	5.1	4.2	4.3	4.4	5.6	6.1	5.9	
Clear-Sky Solar Irradiance	taub	0.333	0.349	0.378	0.403	0.401	0.402	0.409	0.399	0.385	0.364	0.340	0.322		
	taud	2.319	2.358	2.310	2.280	2.362	2.369	2.361	2.399	2.428	2.419	2.358	2.311		
	Ebn at Noon	200	237	254	262	269	270	265	261	250	228	195	179		
	Edh at Noon	19	25	32	37	36	36	36	33	29	23	19	16		
All-Sky Solar Radiation	RadAvg	202	428	853	1406	1754	1831	1767	1484	1024	551	244	152		
	RadStd	19	70	72	133	112	102	182	104	78	43	22	15		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page