

K14-FA-1C, Netherlands

WMO: 062040

Lat: 53.269N

Lon: 3.628E

Elev: 27

StdP: 101.00

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.7	0.5	-6.9	2.1	0.4	-5.2	2.4	1.4	20.7	7.4	19.5	7.5	9.3	80	0.840

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.2	20.8	18.1	19.8	17.5	19.2	17.0	18.6	20.3	17.9	19.5	17.4	18.9	6.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	12.8	19.8	17.2	12.3	19.1	16.6	11.9	18.6	52.9	20.5	50.8	19.6	49.0	18.9	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	16.9	15.2	-0.9	23.8	2.4	1.7	-2.6	25.1	-4.0	26.1	-5.4	27.0	-7.1	28.3
			-2.6	19.6	2.9	1.3	-4.7	20.6	-6.4	21.3	-8.0	22.1	-10.1	23.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	6.1	5.3	6.3	8.2	11.0	13.7	16.5	17.5	16.1	13.5	10.3	8.0
	DBStd	4.65	2.37	2.64	2.26	2.09	2.15	1.77	1.66	1.46	1.67	1.95	2.24	2.40
	HDD10.0	534	122	132	114	61	13	0	0	0	0	2	22	68
	HDD18.3	2659	380	364	372	303	228	138	61	32	69	149	241	321
	CDD10.0	932	0	0	1	7	44	112	202	234	183	111	32	6
	CDD18.3	16	0	0	0	0	0	1	5	8	3	0	0	0
	CDH23.3	3	0	0	0	0	0	0	3	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.0	9.5	9.1	8.2	7.4	7.3	6.6	6.5	6.8	7.4	8.4	9.1	10.1
Precipitation	PrecAvg	975	94	72	66	46	52	63	74	93	95	104	108	108
	PrecMax	1262	165	146	139	99	88	135	172	209	192	191	192	182
	PrecMin	724	12	23	10	3	24	19	13	20	19	37	18	50
	PrecStd	132	39	31	31	24	19	30	36	46	43	43	39	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.3	11.0	11.5	15.6	18.2	20.3	23.2	22.3	21.7	18.9	15.7	13.4
		MCWB	9.9	8.8	9.1	11.0	14.5	17.6	19.2	18.3	19.0	16.4	14.0	11.7
	2%	DB	10.5	9.8	10.3	13.0	15.4	17.9	20.5	20.9	19.9	17.7	14.9	12.6
		MCWB	9.1	8.0	8.5	10.1	12.9	15.9	18.1	18.1	17.7	15.9	13.3	11.2
	5%	DB	9.7	9.1	9.5	11.7	14.3	16.7	19.5	19.9	19.0	16.8	14.1	11.8
		MCWB	8.3	7.5	8.0	9.4	12.4	14.9	17.5	17.5	16.8	15.0	12.4	10.4
	10%	DB	9.0	8.5	8.7	10.7	13.6	15.9	18.6	19.2	18.3	16.2	13.5	11.0
		MCWB	7.7	7.1	7.2	9.0	11.8	14.1	16.7	17.1	16.2	14.4	11.6	9.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	9.3	9.6	11.4	15.0	18.1	19.5	19.2	19.3	16.7	14.8	12.1
		MCDB	11.1	10.2	11.1	14.9	16.4	20.6	21.8	21.1	21.2	18.0	15.7	12.8
	2%	WB	9.4	8.3	8.9	10.2	13.4	16.2	18.6	18.5	18.1	16.0	13.6	11.4
		MCDB	10.3	9.3	10.1	12.4	14.9	17.6	20.4	20.1	19.4	17.5	14.6	12.3
	5%	WB	8.6	7.8	8.2	9.7	12.7	15.2	17.8	17.9	17.4	15.4	12.8	10.6
		MCDB	9.6	8.8	9.3	11.4	14.0	16.5	19.3	19.5	18.7	16.7	14.1	11.6
	10%	WB	7.9	7.2	7.5	9.1	12.0	14.4	17.0	17.4	16.7	14.7	11.8	9.8
		MCDB	8.8	8.4	8.5	10.6	13.4	15.7	18.4	19.0	18.1	16.0	13.2	11.0
Mean Daily Temperature Range	5% DB	MDBR	2.4	2.2	2.4	2.5	2.3	2.2	2.2	2.2	2.2	2.3	2.4	2.4
		MCDBR	2.9	2.6	3.1	3.8	3.4	3.3	3.1	2.9	2.6	2.8	2.8	2.7
		MCWBR	3.3	2.4	2.6	2.3	2.2	2.7	2.2	2.4	2.5	2.9	3.2	3.2
	5% WB	MCDBR	2.8	2.6	3.0	3.5	3.4	3.4	3.0	2.6	2.4	2.8	2.8	2.6
		MCWBR	3.3	2.5	2.7	2.5	2.4	2.8	2.3	2.4	2.5	3.1	3.4	3.3
Clear-Sky Solar Irradiance	taub	0.333	0.349	0.378	0.403	0.401	0.402	0.409	0.399	0.385	0.364	0.340	0.322	
	taud	2.319	2.358	2.310	2.280	2.362	2.369	2.361	2.399	2.428	2.419	2.358	2.311	
	Ebn at Noon	629	747	800	826	849	850	836	824	788	720	615	564	
	Edh at Noon	61	79	101	118	115	115	114	104	90	74	59	52	
All-Sky Solar Radiation	RadAvg	0.64	1.35	2.69	4.43	5.53	5.77	5.57	4.68	3.23	1.74	0.77	0.48	
	RadStd	0.06	0.22	0.23	0.42	0.35	0.32	0.57	0.33	0.25	0.14	0.07	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page