

A12-CPP HP, Netherlands

WMO: 062050

Lat: 55.399N

Lon: 3.810E

Elev: 33

StdP: 100.93

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.1	0.8	-6.5	2.2	0.8	-5.3	2.4	1.5	20.7	6.2	19.1	6.2	10.3	70	0.883

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.7	19.4	17.6	18.6	16.9	18.0	16.4	18.0	18.9	17.2	18.2	16.6	17.7	6.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.6	18.7	16.8	12.0	18.1	16.1	11.5	17.5	51.0	19.1	48.8	18.3	46.8	17.8	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	16.7	15.2	-0.2	20.7	1.5	2.5	-1.3	22.5	-2.2	24.0	-3.0	25.4	-4.1	27.2		
(5)			-2.0	18.3	1.8	1.4	-3.3	19.3	-4.4	20.0	-5.4	20.8	-6.7	21.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	5.4	4.8	5.5	7.1	9.9	12.7	15.5	16.2	14.7	12.3	9.4	7.1
	DBStd	4.39	1.99	2.09	2.00	1.78	2.00	1.58	1.78	1.46	1.53	1.75	2.22	2.13
	HDD10.0	673	142	146	141	87	27	1	0	0	0	4	36	91
	HDD18.3	3016	400	379	399	336	262	169	90	66	108	188	269	349
	CDD10.0	702	0	0	0	1	23	81	171	193	142	74	16	1
	CDD18.3	4	0	0	0	0	0	0	2	1	1	0	0	0
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	8.2	9.7	9.2	8.4	7.3	7.3	6.7	6.6	6.9	7.7	9.2	9.2	9.8
(15) Precipitation	PrecAvg	1134	139	111	95	56	45	62	70	88	100	110	130	129
	PrecMax	1404	244	185	166	99	69	108	101	145	165	158	205	251
	PrecMin	918	49	49	33	24	23	24	33	37	46	44	81	63
	PrecStd	113	48	38	31	17	13	18	20	24	28	31	31	43
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	9.0	9.6	12.2	15.6	17.5	21.6	20.1	19.5	16.7	14.5	11.2
		MCWB	8.3	7.5	8.0	9.1	13.4	15.4	19.4	18.2	17.9	15.0	13.1	9.7
	2%	DB	9.0	8.2	8.7	10.8	14.3	16.2	19.7	19.2	18.5	15.9	13.5	10.5
		MCWB	7.7	7.0	7.5	8.8	12.6	14.7	18.0	17.2	16.9	14.5	12.2	9.3
	5%	DB	8.4	7.7	8.1	10.0	13.2	15.5	18.6	18.6	17.5	15.2	12.8	10.0
		MCWB	7.1	6.6	7.0	8.5	11.8	14.1	16.9	16.8	16.0	13.7	11.5	8.9
	10%	DB	7.9	7.3	7.6	9.4	12.4	14.7	17.8	18.2	16.8	14.5	12.2	9.5
		MCWB	6.6	6.2	6.5	8.2	11.0	13.3	16.3	16.4	15.3	13.0	10.8	8.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	8.1	8.2	9.8	14.1	15.8	19.6	18.8	18.1	15.5	13.2	10.2
		MCDB	9.3	8.5	9.1	11.2	15.0	16.9	20.9	19.6	18.7	16.3	14.0	10.6
	2%	WB	8.1	7.3	7.7	9.2	13.0	15.0	18.4	17.8	17.2	14.8	12.5	9.7
		MCDB	8.7	7.9	8.5	10.3	13.8	15.9	19.6	18.7	18.0	15.8	13.3	10.2
	5%	WB	7.5	6.8	7.2	8.7	12.0	14.4	17.3	17.2	16.3	14.1	11.7	9.2
		MCDB	8.2	7.5	7.9	9.7	13.0	15.3	18.3	18.2	17.2	15.0	12.6	9.9
	10%	WB	6.9	6.4	6.7	8.2	11.2	13.6	16.5	16.7	15.7	13.4	10.9	8.6
		MCDB	7.7	7.1	7.5	9.2	12.1	14.6	17.6	17.9	16.6	14.4	12.0	9.4
(35) Mean Daily Temperature Range	5% DB	MDBR	2.0	1.9	1.8	1.9	1.8	1.6	1.7	1.7	1.7	1.9	2.1	2.1
		MCDBR	2.3	2.1	2.1	2.6	2.9	2.3	2.3	2.1	2.2	2.3	2.4	2.1
	5% WB	MCWBR	2.9	2.0	2.0	1.7	2.1	2.0	2.0	2.4	2.6	2.6	2.9	2.6
		MCWBR	2.2	2.0	2.0	2.4	2.8	2.2	2.2	1.9	2.1	2.4	2.4	2.1
(40) Clear-Sky Solar Irradiance	taub		0.335	0.348	0.369	0.401	0.383	0.389	0.393	0.391	0.380	0.356	0.336	0.316
		taud	2.240	2.316	2.313	2.260	2.402	2.402	2.404	2.414	2.426	2.399	2.296	2.234
	Ebn at Noon		564	716	793	818	860	857	845	823	779	701	562	494
		Edh at Noon	59	78	98	118	108	110	108	100	87	71	55	47
(44) All-Sky Solar Radiation	RadAvg		0.49	1.16	2.50	4.24	5.59	5.62	5.38	4.47	2.97	1.55	0.64	0.36
	RadStd		0.06	0.17	0.23	0.36	0.39	0.36	0.54	0.31	0.35	0.11	0.08	0.04

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page