

F16-A, Netherlands

WMO: 062060

Lat: 54.117N

Lon: 4.012E

Elev: 92

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	31.5	33.4	20.1	15.1	33.3	23.1	17.5	34.9	49.5	45.6	45.1	44.4	23.5	80	0.855

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.2	68.3	64.8	66.8	63.4	65.6	62.3	65.5	67.8	64.1	66.4	62.9	65.1	15.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	90.7	67.2	63.0	86.4	65.9	61.8	82.7	64.9	30.4	68.0	29.4	66.6	28.5	65.1	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.9	37.7	33.8	31.1	70.8	3.2	2.4	28.8	72.5	26.9	73.9	25.1	75.3	22.8	77.1
			27.2	66.3	4.0	2.0	24.4	67.7	22.0	68.9	19.8	70.0	16.9	71.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	42.3	41.2	42.5	46.0	51.0	56.3	61.3	62.5	60.0	55.5	49.8	45.6
	DBStd	8.20	3.88	4.15	3.59	3.58	3.76	2.97	3.21	2.43	2.72	3.26	3.84	4.00
	HDD50	1070	237	246	232	128	33	0	0	0	0	4	48	142
	HDD65	5047	702	666	697	570	434	261	125	85	153	296	456	602
	CDD50	1515	0	0	0	8	64	189	349	386	299	173	42	5
	CDD65	17	0	0	0	0	0	0	9	6	2	0	0	0
	CDH74	2	0	0	0	0	0	0	2	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	18.0	21.4	20.2	19.2	16.6	16.6	15.0	15.0	15.3	16.3	19.2	20.0	21.2
Precipitation	PrecAvg	38.4	3.7	2.8	2.6	1.8	2.0	2.5	2.9	3.7	3.7	4.1	4.3	4.3
	PrecMax	49.7	6.5	5.7	5.5	3.9	3.5	5.3	6.8	8.2	7.6	7.5	7.6	7.2
	PrecMin	28.5	0.5	0.9	0.4	0.1	0.9	0.7	0.5	0.8	0.7	1.5	0.7	2.0
	PrecStd	5.2	1.5	1.2	1.2	0.9	0.7	1.2	1.4	1.8	1.7	1.7	1.5	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	49.5	49.7	56.6	61.1	66.1	73.0	70.2	68.6	64.4	59.2	53.9
		MCWB	48.3	46.0	46.2	51.9	56.6	62.5	67.4	66.1	65.1	60.5	56.5	51.3
	2%	DB	49.2	47.8	48.2	53.5	58.8	62.8	68.9	68.0	66.2	62.3	57.6	52.7
		MCWB	47.1	45.3	45.7	50.2	55.4	59.7	65.4	64.1	63.6	59.4	55.2	50.4
	5%	DB	48.0	46.8	47.3	51.9	57.2	61.2	67.2	66.6	64.7	60.8	56.4	51.6
		MCWB	46.0	44.6	45.0	49.1	54.2	58.6	64.0	63.1	61.6	58.0	53.7	49.5
	10%	DB	47.1	46.1	46.5	50.4	55.9	59.9	65.7	65.6	63.5	59.6	55.0	50.3
		MCWB	44.9	44.0	44.4	48.1	53.3	57.2	62.4	62.2	60.2	56.7	51.9	48.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	47.4	47.0	52.9	58.1	62.8	67.9	66.8	65.7	61.1	57.4	52.2
		MCDB	49.9	48.3	48.7	55.6	59.6	65.9	70.9	69.4	67.5	63.4	58.5	53.1
	2%	WB	47.5	46.0	46.2	50.7	56.0	60.3	65.8	65.0	63.9	59.8	55.8	51.1
		MCDB	48.6	47.1	47.5	52.7	57.8	62.2	68.4	67.2	65.8	61.7	57.3	52.3
	5%	WB	46.5	45.1	45.5	49.5	54.7	59.0	64.6	63.7	62.5	58.7	54.1	49.9
		MCDB	47.6	46.4	46.9	51.4	56.6	61.0	67.0	65.9	64.4	60.3	56.2	51.4
	10%	WB	45.5	44.3	44.7	48.3	53.5	57.7	62.9	62.8	61.0	57.4	52.3	48.5
		MCDB	46.8	45.7	46.2	50.4	55.6	59.6	65.2	65.0	63.2	59.4	54.5	50.3
Mean Daily Temperature Range	5% DB	MDBR	3.9	3.6	3.5	3.6	3.3	3.0	3.3	3.2	3.4	3.9	3.9	4.0
		MCDBR	4.4	3.8	4.0	5.1	4.6	4.6	4.6	4.1	3.9	4.7	4.5	4.3
		MCWBR	5.2	3.7	3.6	3.4	3.6	4.5	3.8	4.6	4.5	5.3	5.6	5.5
	5% WB	MCDBR	4.2	3.8	3.9	4.7	4.5	4.5	4.4	3.8	3.5	4.3	4.6	4.5
		MCWBR	5.3	3.8	3.8	3.4	3.8	4.6	3.8	4.6	4.4	5.1	6.1	6.0
Clear-Sky Solar Irradiance	taub	0.333	0.348	0.374	0.403	0.393	0.398	0.402	0.396	0.383	0.361	0.338	0.320	
	taud	2.287	2.344	2.311	2.269	2.381	2.381	2.379	2.405	2.428	2.412	2.333	2.278	
	Ebn at Noon	192	233	253	261	271	270	266	261	249	226	189	170	
	Edh at Noon	19	25	32	37	36	36	35	33	28	23	18	16	
All-Sky Solar Radiation	RadAvg	181	397	828	1377	1755	1803	1742	1457	978	522	220	134	
	RadStd	20	61	69	134	115	122	172	104	90	44	20	15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-212	+88	N/A

Nomenclature: See separate page