

F16-A, Netherlands

WMO: 062060

Lat: 54.117N

Lon: 4.012E

Elev: 28

StdP: 100.99

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.3	0.8	-6.6	2.2	0.7	-4.9	2.5	1.6	22.1	7.6	20.1	6.9	10.5	80	0.855

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.8	20.2	18.2	19.3	17.5	18.7	16.8	18.6	19.9	17.9	19.1	17.2	18.4	7.1	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.0	19.6	17.2	12.3	18.8	16.5	11.8	18.3	52.7	20.0	50.6	19.2	48.3	18.4	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	16.8	15.1	DB	-0.5	21.5	1.8	1.3	-1.8	22.5	-2.8	23.3	-3.8	24.0	-5.1	25.0	(4)
(5)			WB	-2.7	19.1	2.2	1.1	-4.2	19.8	-5.5	20.5	-6.8	21.1	-8.4	21.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	5.7	5.1	5.9	7.8	10.6	13.5	16.3	16.9	15.5	13.0	9.9	7.5	(6)	
	DBStd	4.56	2.16	2.30	2.00	1.99	2.09	1.65	1.78	1.35	1.51	1.81	2.14	2.22	(7)	
	HDD10.0	594	132	137	129	71	18	0	0	0	0	2	27	79	(8)	
	HDD18.3	2804	390	370	387	317	241	145	69	47	85	164	253	334	(9)	
	CDD10.0	842	0	0	0	4	36	105	194	214	166	96	23	3	(10)	
	CDD18.3	9	0	0	0	0	0	0	5	3	1	0	0	0	(11)	
	CDH23.3	1	0	0	0	0	0	0	1	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	8.0	9.6	9.0	8.6	7.4	7.4	6.7	6.7	6.8	7.3	8.6	8.9	9.5	(14)	
(15) Precipitation	PrecAvg	975	94	72	66	46	52	63	74	93	95	104	108	108	(15)	
	PrecMax	1262	165	146	139	99	88	135	172	209	192	191	192	182	(16)	
	PrecMin	724	12	23	10	3	24	19	13	20	19	37	18	50	(17)	
	PrecStd	132	39	31	31	24	19	30	36	46	43	43	39	35	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	9.7	9.8	13.7	16.1	19.0	22.8	21.2	20.3	18.0	15.1	12.1	(19)	
		MCWB	9.1	7.8	7.9	11.0	13.7	17.0	19.7	19.0	18.4	15.8	13.6	10.7	(20)	
	2%	DB	9.5	8.8	9.0	12.0	14.9	17.1	20.5	20.0	19.0	16.8	14.2	11.5	(21)	
		MCWB	8.4	7.4	7.6	10.1	13.0	15.4	18.5	17.8	17.5	15.2	12.9	10.2	(22)	
	5%	DB	8.9	8.2	8.5	11.1	14.0	16.2	19.5	19.2	18.2	16.0	13.5	10.9	(23)	
		MCWB	7.8	7.0	7.2	9.5	12.4	14.8	17.8	17.3	16.4	14.4	12.1	9.7	(24)	
	10%	DB	8.4	7.8	8.0	10.2	13.3	15.5	18.7	18.7	17.5	15.3	12.8	10.2	(25)	
		MCWB	7.2	6.7	6.9	8.9	11.8	14.0	16.9	16.8	15.7	13.7	11.1	8.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	8.5	8.4	11.6	14.5	17.1	20.0	19.3	18.7	16.1	14.1	11.2	(27)	
		MCDB	9.9	9.1	9.3	13.1	15.3	18.9	21.6	20.8	19.7	17.5	14.7	11.7	(28)	
	2%	WB	8.6	7.8	7.9	10.4	13.4	15.7	18.8	18.3	17.7	15.5	13.2	10.6	(29)	
		MCDB	9.2	8.4	8.6	11.5	14.3	16.8	20.2	19.5	18.8	16.5	14.0	11.3	(30)	
	5%	WB	8.0	7.3	7.5	9.7	12.6	15.0	18.1	17.6	17.0	14.8	12.3	10.0	(31)	
		MCDB	8.7	8.0	8.3	10.8	13.7	16.1	19.5	18.9	18.0	15.7	13.4	10.8	(32)	
	10%	WB	7.5	6.8	7.1	9.1	12.0	14.3	17.2	17.1	16.1	14.1	11.3	9.2	(33)	
		MCDB	8.2	7.6	7.9	10.2	13.1	15.3	18.5	18.3	17.3	15.2	12.5	10.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	2.2	2.0	1.9	2.0	1.8	1.7	1.8	1.8	1.9	2.2	2.2	2.2	(35)	
		MCDBR	2.4	2.1	2.2	2.8	2.6	2.6	2.5	2.3	2.1	2.6	2.5	2.4	(36)	
	5% WB	MCWBR	2.9	2.1	2.0	1.9	2.0	2.5	2.1	2.6	2.5	2.9	3.1	3.1	(37)	
		MCWBR	2.4	2.1	2.2	2.6	2.5	2.5	2.4	2.1	1.9	2.4	2.6	2.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.333	0.348	0.374	0.403	0.393	0.398	0.402	0.396	0.383	0.361	0.338	0.320	(40)	
		taud	2.287	2.344	2.311	2.269	2.381	2.381	2.379	2.405	2.428	2.412	2.333	2.278	(41)	
	Edh at Noon		604	736	797	822	855	852	840	823	784	713	595	536	(42)	
			60	79	100	118	112	113	111	103	89	73	57	50	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.57	1.25	2.61	4.34	5.53	5.68	5.49	4.59	3.08	1.65	0.69	0.42	(44)	
	RadStd		0.06	0.19	0.22	0.42	0.36	0.39	0.54	0.33	0.28	0.14	0.06	0.05	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-118	+49	N/A

Nomenclature: See separate page