

AWG-1, Netherlands

WMO: 062080

Lat: 53.4917N

Lon: 5.9417E

Elev: 89

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.6	27.0	16.0	12.4	27.5	19.9	15.0	28.2	39.9	44.0	36.7	43.5	13.6	110	0.762

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	76.6	66.1	72.8	64.4	70.1	63.9	67.7	74.1	66.2	71.0	64.8	69.0	13.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	94.1	70.8	64.0	89.5	69.3	62.7	85.4	68.2	32.2	74.3	30.9	71.3	29.8	69.2	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
35.1	31.5	28.3	DB	22.2	87.6	3.1	3.7	20.0	90.3	18.2	92.5	16.4	94.5	14.2	97.2
			WB	20.7	72.0	3.8	1.3	18.0	72.9	15.7	73.7	13.6	74.5	10.8	75.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.1	38.5	38.4	42.3	48.4	54.3	58.9	63.9	64.5	60.5	54.1	46.7	41.9	(6)
	DBStd	10.49	5.72	5.77	5.07	5.41	5.79	4.54	4.71	3.98	3.84	4.30	4.82	5.69	(7)
	HDD50	1422	358	324	244	92	20	0	0	0	0	13	118	253	(8)
	HDD65	5181	823	744	705	498	338	190	78	56	146	337	550	716	(9)
	CDD50	1822	0	0	4	44	151	268	432	448	314	141	18	2	(10)
	CDD65	108	0	0	0	0	5	9	45	39	10	0	0	0	(11)
	CDH74	257	0	0	0	2	13	34	114	73	21	0	0	0	(12)
	CDH80	49	0	0	0	0	1	5	26	15	2	0	0	0	(13)
(14) Wind	WSAvg	15.4	17.8	17.1	15.5	13.9	14.1	13.4	13.1	13.3	14.5	16.6	17.1	18.7	(14)
(15) Precipitation	PrecAvg	34.4	2.8	2.2	1.9	1.7	2.2	2.8	3.3	3.8	3.5	3.4	3.5	3.3	(15)
	PrecMax	41.6	5.4	5.4	4.0	4.1	4.4	4.8	6.7	8.1	7.6	6.6	6.3	7.4	(16)
	PrecMin	23.5	0.2	0.7	0.3	0.0	0.6	1.1	1.2	0.7	0.5	1.3	0.5	1.1	(17)
	PrecStd	5.1	1.3	1.0	1.0	0.9	1.0	1.2	1.5	2.0	1.7	1.3	1.4	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.1	52.4	59.2	69.2	75.6	79.9	83.4	81.8	76.8	69.1	59.5	54.5	(19)
		MCWB	48.9	44.8	51.5	57.1	61.9	67.9	69.4	68.3	67.3	61.2	55.9	51.6	(20)
	2%	DB	48.8	49.1	53.1	62.3	68.7	70.2	76.6	75.0	71.7	64.7	56.7	51.8	(21)
		MCWB	46.7	45.2	48.4	53.9	59.9	63.5	67.1	65.4	64.6	59.9	54.3	49.4	(22)
	5%	DB	46.8	47.0	49.9	58.4	64.0	67.0	71.9	72.0	67.3	61.5	54.9	49.9	(23)
		MCWB	44.7	44.4	46.8	52.4	58.1	61.9	65.1	64.5	62.2	57.9	52.6	47.9	(24)
	10%	DB	45.8	45.3	47.8	55.0	61.4	64.4	69.5	69.6	65.3	59.8	53.0	48.4	(25)
		MCWB	43.6	43.1	45.3	50.8	56.7	60.1	64.5	63.7	61.2	56.6	50.3	45.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	47.4	52.4	57.7	63.9	68.0	70.6	69.7	68.1	62.1	56.7	52.1	(27)
		MCDB	50.7	49.7	57.7	67.0	70.4	77.1	80.8	77.7	75.4	66.8	58.1	53.8	(28)
	2%	WB	47.0	45.8	49.3	54.8	60.7	64.8	68.0	67.4	64.7	60.3	54.7	49.9	(29)
		MCDB	48.1	48.1	52.4	60.1	66.3	69.4	74.0	73.2	69.1	64.1	56.4	51.5	(30)
	5%	WB	45.5	44.6	47.1	52.9	58.8	62.4	66.4	65.7	63.2	58.5	52.8	48.2	(31)
		MCDB	46.8	46.8	49.4	57.3	63.7	66.2	70.8	70.5	66.6	61.1	54.7	49.7	(32)
	10%	WB	44.2	43.3	45.5	51.3	57.0	60.5	65.1	64.3	61.7	57.0	50.7	46.6	(33)
		MCDB	45.5	45.1	47.5	54.9	61.1	63.6	69.2	68.5	65.0	59.5	52.5	48.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.3	5.7	6.8	6.5	5.9	6.2	6.7	5.7	6.0	5.5	5.6	(35)
		MCDBR	5.7	7.5	9.8	13.8	12.8	11.6	11.8	12.3	9.7	8.7	6.1	5.3	(36)
	5% WB	MCWBR	5.6	6.0	6.9	8.2	6.9	7.2	6.4	6.7	6.2	5.9	6.1	5.1	(37)
		MCWBR	5.8	6.7	9.0	11.9	12.3	11.0	9.8	10.2	8.1	8.1	6.1	5.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.330	0.347	0.375	0.403	0.400	0.399	0.409	0.403	0.387	0.362	0.341	0.322	(40)
		taud	2.314	2.344	2.294	2.266	2.332	2.353	2.334	2.364	2.401	2.413	2.348	2.308	(41)
	Ebn at Noon		199	236	254	262	269	271	265	259	248	228	193	177	(42)
		Edh at Noon	19	25	32	38	37	37	37	34	29	23	19	16	(43)
(44) All-Sky Solar Radiation	RadAvg		184	386	806	1337	1667	1736	1658	1381	958	526	222	139	(44)
	RadStd		17	62	76	128	117	117	175	104	87	50	20	16	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (48 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page