

AWG-1, Netherlands

WMO: 062080

Lat: 53.4917N

Lon: 5.9417E

Elev: 27

StdP: 101.00

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.1	-2.8	-8.9	1.8	-2.5	-6.7	2.1	-2.1	17.8	6.7	16.4	6.4	6.1	110	0.762

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.7	24.8	18.9	22.6	18.0	21.2	17.7	19.9	23.4	19.0	21.7	18.2	20.6	6.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	21.6	17.8	12.8	20.7	17.0	12.2	20.1	57.0	23.5	54.1	21.8	51.5	20.6	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 15.7	14.1	12.6	DB	-5.4	30.9	1.7	2.1	-6.7	32.4	-7.7	33.6	-8.7	34.7	-9.9	36.2	(4)
(5)			WB	-6.3	22.2	2.1	0.7	-7.8	22.7	-9.0	23.2	-10.2	23.6	-11.8	24.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	3.6	3.6	5.7	9.1	12.4	15.0	17.7	18.0	15.8	12.3	8.1	5.5
	DBStd	5.83	3.18	3.20	2.82	3.00	3.22	2.52	2.61	2.21	2.13	2.39	2.68	3.16
	HDD10.0	790	199	180	136	51	11	0	0	0	0	7	66	141
	HDD18.3	2878	457	413	392	277	188	106	43	31	81	187	306	398
	CDD10.0	1012	0	0	2	24	84	149	240	249	174	78	10	1
	CDD18.3	60	0	0	0	0	3	5	25	22	6	0	0	0
	CDH23.3	143	0	0	0	1	7	19	63	41	12	0	0	0
	CDH26.7	27	0	0	0	0	1	3	14	8	1	0	0	0
Wind	WSAvg	6.9	8.0	7.7	6.9	6.2	6.3	6.0	5.8	6.0	6.5	7.4	7.6	8.4
Precipitation	PrecAvg	873	70	57	48	42	56	71	83	97	90	87	89	84
	PrecMax	1056	137	136	102	103	111	123	171	206	193	167	159	187
	PrecMin	597	5	19	7	1	16	28	30	18	12	32	13	29
	PrecStd	129	34	26	26	23	26	31	39	50	42	33	35	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	11.4	15.1	20.7	24.2	26.6	28.6	27.7	24.9	20.6	15.3	12.5
		MCWB	9.4	7.1	10.8	14.0	16.6	19.9	20.8	20.2	19.6	16.2	13.3	10.9
	2%	DB	9.3	9.5	11.7	16.8	20.4	21.2	24.8	23.9	22.1	18.2	13.7	11.0
		MCWB	8.2	7.4	9.1	12.2	15.5	17.5	19.5	18.6	18.1	15.5	12.4	9.7
	5%	DB	8.2	8.4	9.9	14.7	17.8	19.4	22.1	22.2	19.6	16.4	12.7	10.0
		MCWB	7.1	6.9	8.2	11.3	14.5	16.6	18.4	18.0	16.8	14.4	11.4	8.8
	10%	DB	7.7	7.4	8.8	12.8	16.3	18.0	20.8	20.9	18.5	15.4	11.7	9.1
		MCWB	6.4	6.2	7.4	10.4	13.7	15.6	18.0	17.6	16.2	13.7	10.1	7.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	8.5	11.3	14.3	17.7	20.0	21.4	21.0	20.0	16.7	13.7	11.2
		MCDB	10.4	9.8	14.3	19.4	21.4	25.1	27.1	25.4	24.1	19.3	14.5	12.1
	2%	WB	8.3	7.7	9.6	12.7	16.0	18.2	20.0	19.6	18.2	15.7	12.6	10.0
		MCDB	9.0	8.9	11.3	15.6	19.1	20.8	23.3	22.9	20.6	17.9	13.6	10.8
	5%	WB	7.5	7.0	8.4	11.6	14.9	16.9	19.1	18.7	17.3	14.7	11.5	9.0
		MCDB	8.2	8.2	9.6	14.0	17.6	19.0	21.6	21.4	19.2	16.2	12.6	9.8
	10%	WB	6.8	6.3	7.5	10.7	13.9	15.8	18.4	17.9	16.5	13.9	10.4	8.1
		MCDB	7.5	7.3	8.6	12.7	16.2	17.5	20.6	20.3	18.3	15.3	11.4	8.9
Mean Daily Temperature Range	5% DB	MDBR	3.0	3.0	3.2	3.8	3.6	3.3	3.4	3.7	3.2	3.3	3.0	3.1
		MCDBR	3.2	4.1	5.4	7.7	7.1	6.4	6.6	6.8	5.4	4.8	3.4	2.9
		MCWBR	3.1	3.4	3.9	4.6	3.9	4.0	3.6	3.7	3.4	3.3	3.4	2.8
	5% WB	MCDBR	3.2	3.7	5.0	6.6	6.8	6.1	5.4	5.6	4.5	4.5	3.4	3.1
		MCWBR	3.3	3.1	3.8	4.2	3.9	4.3	3.4	3.9	3.3	3.4	3.5	3.2
Clear-Sky Solar Irradiance	taub	0.330	0.347	0.375	0.403	0.400	0.399	0.409	0.403	0.387	0.362	0.341	0.322	
	taud	2.314	2.344	2.294	2.266	2.332	2.353	2.334	2.364	2.401	2.413	2.348	2.308	
	Ebn at Noon	627	745	800	825	849	853	834	817	783	719	607	558	
	Edh at Noon	61	80	102	119	118	117	117	107	92	74	59	51	
All-Sky Solar Radiation	RadAvg	0.58	1.22	2.54	4.21	5.25	5.47	5.23	4.36	3.02	1.66	0.70	0.44	
	RadStd	0.05	0.20	0.24	0.40	0.37	0.37	0.55	0.33	0.28	0.16	0.06	0.05	

Historical Trends

		Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page