

DE KOOIJ AP, Netherlands

WMO: 062350

Lat: 52.9269N

Lon: 4.7811E

Elev: 1

StdP: 101.31

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.2	(c) -3.4	(d) -8.7	(e) 1.8	(f) -4.0	(g) -6.5	(h) 2.2	(i) -2.8	(j) 16.9	(k) 8.4	(l) 15.5	(m) 8.2	(n) 5.7	(o) 90	(p) 0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.8	(c) 25.9	(d) 20.0	(e) 23.8	(f) 19.1	(g) 22.0	(h) 18.2	(i) 20.7	(j) 24.6	(k) 19.7	(l) 22.9	(m) 18.8	(n) 21.4	(o) 4.2	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.3	14.1	22.7	18.4	13.3	21.6	17.6	12.6	20.6	59.7	24.8	56.2	23.1	53.2	21.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.1	(b) 12.5	(c) 11.2	(e) -7.5	(f) 30.6	(g) 3.2	(h) 1.7	(i) -9.7	(j) 31.8	(k) -11.6	(l) 32.8	(m) -13.4	(n) 33.8	(o) -15.7	(p) 35.0		
(a) 14.1	(b) 12.5	(c) 11.2	(e) -7.9	(f) 23.0	(g) 3.1	(h) 1.1	(i) -10.2	(j) 23.7	(k) -12.0	(l) 24.4	(m) -13.7	(n) 25.0	(o) -16.0	(p) 25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	3.8	3.9	5.8	9.0	12.4	15.1	17.5	17.8	15.4	11.8	7.9	4.9
	DBStd	5.84	3.66	3.35	2.76	3.05	3.04	2.60	2.65	2.39	2.27	2.77	2.96	3.72
	HDD10.0	807	193	171	131	54	9	0	0	0	0	14	75	160
	HDD18.3	2926	451	404	387	280	186	103	48	39	93	204	314	417
	CDD10.0	978	0	0	2	24	83	153	233	241	161	69	11	2
	CDD18.3	57	0	0	0	0	2	7	23	22	4	0	0	0
	CDH23.3	224	0	0	0	2	7	36	89	79	11	0	0	0
	CDH26.7	39	0	0	0	0	1	7	17	13	2	0	0	0
Wind	WSAvg	5.4	6.4	6.1	5.9	5.1	5.2	4.9	4.7	4.6	4.9	5.6	5.5	6.2
Precipitation	PrecAvg	768	64	44	49	41	43	51	62	72	86	89	91	76
	PrecMax	1023	129	108	116	83	92	128	141	161	205	191	156	167
	PrecMin	510	4	2	10	4	9	10	5	10	5	22	38	21
	PrecStd	127	30	26	24	21	22	31	35	42	48	45	33	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	11.7	15.0	20.8	24.1	27.6	28.7	28.5	24.7	20.3	15.2	12.4
		MCWB	9.8	8.7	10.6	14.3	17.1	19.8	21.8	20.6	19.4	16.8	13.8	11.3
	2%	DB	9.7	9.9	12.3	17.6	21.1	23.5	25.6	25.6	21.5	17.7	13.9	11.4
		MCWB	8.7	8.6	9.8	13.2	16.2	18.5	20.3	19.9	18.0	15.5	12.8	10.4
	5%	DB	9.0	8.9	10.6	15.4	19.0	21.0	23.6	23.2	20.0	16.5	12.9	10.5
		MCWB	8.1	7.8	8.7	12.1	15.3	17.2	19.4	19.0	17.3	14.8	11.7	9.5
	10%	DB	8.2	8.1	9.4	13.5	17.2	19.2	21.8	21.5	18.8	15.6	11.9	9.5
		MCWB	7.3	7.1	8.0	10.9	14.1	16.0	18.4	18.2	16.4	14.0	10.6	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	9.5	11.7	15.2	18.7	21.0	22.5	21.9	20.1	17.1	14.2	11.6
		MCDB	10.8	10.4	14.0	19.4	22.2	25.4	26.5	26.3	23.2	19.3	14.7	12.1
	2%	WB	9.0	8.7	10.1	13.6	16.9	19.1	20.9	20.5	18.7	15.9	13.0	10.6
		MCDB	9.5	9.6	11.7	17.0	20.1	22.5	24.7	24.3	20.9	17.4	13.8	11.3
	5%	WB	8.3	8.0	9.0	12.3	15.6	17.6	19.8	19.5	17.7	15.1	11.9	9.7
		MCDB	8.8	8.8	10.2	14.9	18.5	20.7	23.1	22.5	19.5	16.3	12.8	10.3
	10%	WB	7.5	7.2	8.2	11.2	14.3	16.3	18.7	18.6	16.8	14.3	10.8	8.7
		MCDB	8.1	7.9	9.3	13.2	16.8	18.7	21.3	21.0	18.6	15.4	11.7	9.4
Mean Daily Temperature Range	5% DB	MDBR	3.7	4.1	4.9	6.1	6.0	5.9	5.7	5.8	5.3	4.9	4.1	3.8
		MCDBR	3.4	4.8	7.0	9.1	8.8	9.3	8.7	8.4	6.9	5.7	4.3	3.5
		MCWBR	3.5	4.1	5.1	5.6	5.2	5.4	4.7	4.3	4.4	4.4	4.1	3.6
	5% WB	MCDBR	3.4	4.6	6.1	8.5	8.0	8.4	7.9	7.4	6.2	5.5	4.3	3.5
		MCWBR	3.6	4.1	4.8	5.5	5.1	5.4	4.7	4.2	4.2	4.6	4.2	3.7
Clear-Sky Solar Irradiance	taub	0.337	0.355	0.384	0.408	0.409	0.406	0.416	0.409	0.391	0.370	0.348	0.329	
	taud	2.308	2.325	2.270	2.253	2.319	2.341	2.322	2.358	2.397	2.390	2.337	2.302	
	Ebn at Noon	629	740	793	822	842	847	829	815	783	715	609	561	
	Edh at Noon	63	83	106	122	120	118	119	109	93	77	61	53	
All-Sky Solar Radiation	RadAvg	0.64	1.30	2.60	4.25	5.25	5.51	5.27	4.39	3.08	1.71	0.74	0.47	
	RadStd	0.06	0.22	0.26	0.40	0.32	0.35	0.52	0.33	0.26	0.15	0.07	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-114	N/A	N/A
(47) Regional (56 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page