

F3-FB-1, Netherlands

WMO: 062390

Lat: 54.854N

Lon: 4.696E

Elev: 24

StdP: 101.04

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.6	0.3	-6.8	2.1	0.4	-5.4	2.4	1.4	21.3	6.7	19.8	6.7	10.0	90	0.850

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	1.8	20.6	18.6	19.7	17.9	18.9	17.1	18.9	20.3	18.1	19.4	17.4	18.6	5.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	13.2	19.9	17.4	12.5	19.1	16.7	11.9	18.5	53.8	20.3	51.2	19.5	49.0	18.7	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.4	17.3	15.5	DB	-1.1	20.8	1.4	1.5	-2.1	21.8	-2.9	22.7	-3.7	23.5	-4.6	24.5	(4)
(5)			WB	-2.9	19.0	1.6	1.2	-4.0	19.8	-4.9	20.5	-5.8	21.1	-6.9	22.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	5.5	4.7	5.0	7.0	9.9	12.9	15.7	16.8	15.2	12.5	9.4	7.1	(6)
(7)		DBStd	4.67	2.26	2.29	2.05	1.85	2.01	1.75	2.00	1.83	1.62	2.02	2.20	2.34	(7)
(8)		HDD10.0	696	141	149	156	92	27	1	0	0	0	4	35	92	(8)
(9)		HDD18.3	2992	399	383	414	340	261	163	85	54	95	182	267	349	(9)
(10)		CDD10.0	757	0	0	0	2	23	88	177	211	156	81	17	2	(10)
(11)		CDD18.3	12	0	0	0	0	0	0	4	7	1	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	8.0	9.5	9.1	8.8	7.3	7.1	7.0	6.3	6.5	7.4	8.9	9.0	9.4	(14)
(15)	Precipitation	PrecAvg	975	94	72	66	46	52	63	74	93	95	104	108	108	(15)
(16)		PrecMax	1262	165	146	139	99	88	135	172	209	192	191	192	182	(16)
(17)		PrecMin	724	12	23	10	3	24	19	13	20	19	37	18	50	(17)
(18)		PrecStd	132	39	31	31	24	19	30	36	46	43	43	39	35	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	9.5	9.2	12.3	15.9	17.9	21.5	21.7	19.9	17.2	14.9	12.0	(19)
(20)			MCWB	8.9	8.2	7.9	9.9	13.6	16.0	19.0	19.5	17.9	15.4	13.3	10.6	(20)
(21)		2%	DB	9.4	8.6	8.3	11.0	14.2	16.7	20.3	20.9	18.7	16.4	13.7	11.2	(21)
(22)			MCWB	8.2	7.6	7.3	9.2	12.6	15.1	18.3	19.1	16.9	14.7	12.3	10.0	(22)
(23)		5%	DB	8.7	8.0	7.8	10.1	13.3	15.9	19.4	20.1	18.1	15.8	13.0	10.6	(23)
(24)			MCWB	7.5	7.0	6.9	8.8	11.8	14.5	17.6	18.4	16.4	14.2	11.4	9.3	(24)
(25)		10%	DB	8.2	7.3	7.3	9.4	12.4	15.1	18.5	19.3	17.4	15.2	12.3	10.0	(25)
(26)			MCWB	7.0	6.4	6.3	8.3	11.1	13.7	16.8	17.6	15.8	13.7	10.6	8.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	8.6	8.2	10.5	14.2	16.3	19.6	20.2	18.2	15.7	13.7	11.1	(27)
(28)			MDCB	9.8	9.1	8.7	11.5	15.2	17.4	21.0	21.2	19.4	16.7	14.5	11.7	(28)
(29)		2%	WB	8.5	7.8	7.6	9.6	12.9	15.5	18.6	19.4	17.3	15.1	12.6	10.3	(29)
(30)			MDCB	9.1	8.4	8.1	10.6	13.8	16.4	20.0	20.6	18.4	16.1	13.6	11.1	(30)
(31)		5%	WB	7.8	7.2	7.1	9.0	12.1	14.7	17.8	18.5	16.7	14.6	11.7	9.6	(31)
(32)			MDCB	8.5	7.8	7.6	9.9	13.0	15.7	19.1	19.9	17.7	15.6	12.8	10.4	(32)
(33)		10%	WB	7.2	6.6	6.6	8.4	11.3	14.0	17.0	17.7	16.1	14.0	10.8	8.9	(33)
(34)			MDCB	8.0	7.2	7.2	9.3	12.2	15.0	18.3	19.1	17.3	15.1	12.0	9.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	2.1	2.0	1.9	1.9	1.8	1.8	1.9	2.1	2.2	2.3		(35)	
(36)			MCDBR	2.3	2.2	2.3	2.8	2.8	2.7	2.5	2.4	2.1	2.3	2.4	2.4	(36)
(37)			MCWBR	2.7	2.4	2.2	2.0	2.1	2.3	2.1	2.2	2.3	2.6	2.9	3.0	(37)
(38)		5% WB	MCDBR	2.2	2.1	2.2	2.5	2.6	2.7	2.3	2.2	2.1	2.3	2.4	2.3	(38)
(39)			MCWBR	2.7	2.3	2.3	2.0	2.2	2.4	2.1	2.3	2.4	2.8	3.1	3.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.349	0.372	0.403	0.387	0.394	0.397	0.396	0.383	0.360	0.339	0.319	(40)	
(41)		taud	2.253	2.325	2.311	2.266	2.393	2.391	2.394	2.404	2.423	2.394	2.304	2.250	(41)	
(42)		Ebn at Noon	579	724	794	819	858	854	842	820	779	703	572	511	(42)	
(43)		Edh at Noon	60	78	99	118	110	111	109	102	88	73	57	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.51	1.17	2.54	4.29	5.59	5.73	5.47	4.55	2.98	1.56	0.63	0.37	(44)	
(45)		RadStd	0.07	0.18	0.23	0.42	0.38	0.41	0.53	0.35	0.30	0.16	0.07	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-140	+54	N/A

Nomenclature: See separate page