

BERKHOUT, Netherlands

WMO: 062490

Lat: 52.6428N

Lon: 4.9789E

Elev: -3

StdP: 101.36

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-4.1	-9.6	1.7	-4.9	-6.9	2.1	-3.7	16.2	9.0	14.9	9.7	4.4	80	0.629

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	27.0	20.2	24.8	19.1	23.1	18.2	21.0	25.6	20.0	23.7	19.0	22.1	4.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.1	23.3	18.5	13.4	22.0	17.7	12.7	20.8	60.8	25.7	57.2	23.8	53.9	22.3	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.1	11.4	10.0	-8.8	31.1	4.9	1.8	-12.3	32.3	-15.2	33.4	-18.0	34.4	-21.6	35.7		
			-9.1	23.4	4.8	1.0	-12.5	24.1	-15.3	24.7	-18.0	25.2	-21.5	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	3.3	3.7	5.8	9.3	12.5	15.4	17.6	17.2	14.7	11.1	7.3	4.4
	DBStd	6.03	4.01	3.76	3.41	3.52	3.36	2.80	2.79	2.42	2.61	3.12	3.12	3.87
	HDD10.0	874	208	176	133	56	12	0	0	0	0	25	89	175
	HDD18.3	3013	466	409	388	272	183	95	48	51	114	225	329	432
	CDD10.0	961	1	1	4	33	89	163	235	224	140	58	10	2
	CDD18.3	57	0	0	0	0	3	8	25	17	4	0	0	0
	CDH23.3	353	0	0	0	2	18	64	171	82	15	0	0	0
	CDH26.7	74	0	0	0	0	1	13	44	14	2	0	0	0
Wind	WSAvg	4.8	5.9	5.6	5.4	4.7	4.8	4.4	4.2	4.1	4.1	4.7	4.9	5.5
Precipitation	PrecAvg	913	77	61	51	43	55	64	79	102	91	100	98	87
	PrecMax	1229	156	126	123	103	104	159	164	236	198	197	176	165
	PrecMin	661	8	19	10	0	22	22	18	24	11	22	11	24
	PrecStd	137	36	29	30	25	21	34	39	56	45	46	39	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	13.6	16.9	22.9	25.5	28.6	30.5	28.7	25.3	20.8	15.7	13.2
		MCWB	10.7	10.4	11.9	15.3	18.1	20.9	21.3	21.4	19.8	16.9	14.3	12.0
	2%	DB	10.6	10.8	14.1	20.0	23.0	25.1	27.5	25.6	22.8	18.1	14.1	11.7
		MCWB	9.6	9.2	10.6	14.3	16.6	19.2	20.5	20.0	18.7	15.7	12.9	10.7
	5%	DB	9.6	9.7	12.0	17.4	20.8	22.6	25.0	23.4	20.8	16.7	12.9	10.6
		MCWB	8.5	8.3	9.5	12.8	15.6	18.0	19.4	18.8	17.4	14.8	11.7	9.5
	10%	DB	8.6	8.6	10.6	15.1	18.6	20.7	22.9	21.7	19.2	15.6	11.8	9.4
		MCWB	7.6	7.5	8.7	11.6	14.6	16.9	18.4	17.9	16.4	14.0	10.6	8.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	10.7	12.6	16.4	19.5	21.7	22.6	22.2	20.6	17.4	14.4	12.1
		MCDB	11.8	12.1	15.7	21.5	23.6	26.5	28.4	27.3	24.1	20.1	15.2	12.8
	2%	WB	9.8	9.6	11.0	14.6	17.6	20.0	21.2	20.6	19.0	16.0	13.1	10.9
		MCDB	10.5	10.6	13.2	19.0	21.5	23.8	26.2	24.5	22.1	17.8	14.0	11.6
	5%	WB	8.7	8.5	9.8	13.2	16.1	18.6	20.2	19.4	17.9	15.1	11.9	9.6
		MCDB	9.4	9.5	11.7	16.8	19.9	21.9	24.3	22.5	20.2	16.5	12.8	10.4
	10%	WB	7.7	7.6	8.8	11.9	14.8	17.3	19.0	18.5	16.9	14.2	10.8	8.5
		MCDB	8.6	8.6	10.3	14.7	18.2	20.2	22.1	21.1	18.9	15.4	11.6	9.3
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.0	6.8	8.9	8.5	8.3	8.1	7.9	7.8	6.4	4.9	4.3
		MCDBR	4.3	5.9	9.1	12.2	11.8	11.5	11.6	10.5	9.7	7.1	5.0	4.1
		MCWBR	4.2	4.7	6.2	7.2	6.4	6.5	5.8	5.6	5.9	5.1	4.3	3.9
	5% WB	MCDBR	4.3	5.3	8.4	11.5	10.7	10.2	10.7	9.3	8.7	6.9	4.8	4.1
		MCWBR	4.3	4.5	6.1	7.2	6.1	6.4	5.8	5.4	5.6	5.3	4.3	4.0
Clear-Sky Solar Irradiance	taub	0.341	0.360	0.391	0.412	0.414	0.411	0.422	0.414	0.394	0.374	0.352	0.334	
	taud	2.301	2.303	2.237	2.232	2.285	2.311	2.290	2.328	2.373	2.367	2.323	2.295	
	Ebn at Noon	628	735	786	819	837	843	825	810	780	711	608	562	
	Edh at Noon	64	85	110	125	124	122	123	112	96	79	63	55	
All-Sky Solar Radiation	RadAvg	0.66	1.34	2.60	4.23	5.19	5.48	5.23	4.35	3.09	1.74	0.77	0.49	
	RadStd	0.06	0.24	0.27	0.40	0.31	0.34	0.52	0.34	0.26	0.15	0.07	0.05	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page