

WEST-Terschelling, Netherlands

WMO: 062500

Lat: 53.367N

Lon: 5.217E

Elev: 89

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.0	24.4	15.5	12.1	23.3	18.8	14.2	25.5	50.4	43.1	47.6	43.8	17.0	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	76.0	66.3	72.9	64.6	70.0	62.8	67.7	74.1	65.7	71.0	64.0	68.4	12.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	93.6	71.0	63.6	88.2	68.5	62.2	84.0	66.9	32.1	74.5	30.5	71.0	29.3	68.6	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.2	38.1	33.3	DB	21.0	82.5	7.3	3.9	15.7	85.3	11.4	87.6	7.3	89.8	1.9	92.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	38.9	36.9	41.4	46.1	54.1	58.3	62.6	62.5	58.2	51.9	44.4	41.4	(6)	
	DBStd	10.28	6.40	6.69	5.29	4.82	6.01	4.98	4.01	3.72	3.57	4.46	5.34	4.71	(7)	
	HDD50	1614	343	368	268	138	20	2	0	0	0	34	173	268	(8)	
	HDD65	5603	808	788	732	566	345	209	98	95	205	405	619	733	(9)	
	CDD50	1546	0	0	1	22	146	252	392	388	247	94	4	0	(10)	
	CDD65	62	0	0	0	0	7	9	25	18	3	0	0	0	(11)	
	CDH74	171	0	0	0	0	24	28	73	40	6	0	0	0	(12)	
	CDH80	20	0	0	0	0	1	4	9	6	0	0	0	0	(13)	
(14) Wind	WSAvg	17.8	21.4	19.6	19.2	16.3	15.9	14.7	15.9	15.9	16.3	19.0	19.3	19.8	(14)	
(15) Precipitation	PrecAvg	32.8	2.7	2.2	1.8	1.5	2.0	2.2	2.8	3.3	3.6	3.8	3.7	3.3	(15)	
	PrecMax	40.0	5.2	4.9	3.8	3.2	3.7	3.9	6.1	7.9	7.6	9.0	6.3	7.0	(16)	
	PrecMin	23.7	0.3	0.8	0.2	0.0	0.7	0.9	0.9	0.6	0.4	1.1	0.5	1.2	(17)	
	PrecStd	4.8	1.3	0.9	1.0	0.8	0.7	0.9	1.4	2.0	1.8	1.8	1.4	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.1	51.0	55.2	65.4	76.9	77.1	81.4	78.8	73.3	62.5	54.5	50.9	(19)	
		MCWB	48.0	49.4	51.1	56.6	64.5	67.0	70.1	67.2	66.2	58.2	52.2	49.2	(20)	
	2%	DB	47.6	48.0	51.8	60.5	72.3	72.8	76.6	73.4	67.3	60.3	52.9	49.4	(21)	
		MCWB	46.3	46.5	49.0	54.3	61.9	63.7	67.8	65.2	61.7	56.9	50.9	48.0	(22)	
	5%	DB	46.7	45.9	49.3	56.3	67.4	69.2	73.3	70.7	65.1	58.7	51.7	48.2	(23)	
		MCWB	45.5	44.3	47.2	51.8	59.3	61.8	65.4	63.9	60.6	55.8	49.9	46.6	(24)	
	10%	DB	45.7	44.4	47.5	53.2	63.4	66.1	69.7	68.1	63.4	57.4	50.6	47.2	(25)	
		MCWB	44.4	43.0	45.9	49.8	57.3	60.2	63.6	62.5	59.4	54.9	48.5	45.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	49.6	51.7	58.2	66.0	69.2	71.1	69.4	65.3	59.8	53.1	49.9	(27)	
		MCDB	48.5	50.8	54.8	63.0	75.5	74.5	79.8	76.0	71.0	62.0	53.8	50.3	(28)	
	2%	WB	46.9	46.8	49.4	55.0	62.6	64.8	68.6	66.2	63.3	57.9	51.5	48.4	(29)	
		MCDB	47.3	47.7	51.3	59.9	70.7	71.7	75.4	70.9	66.4	59.4	52.3	49.2	(30)	
	5%	WB	45.9	44.8	47.7	52.2	60.3	62.6	66.7	64.8	61.7	56.8	50.5	47.1	(31)	
		MCDB	46.5	45.7	49.0	55.2	67.4	68.2	72.2	69.0	64.3	58.2	51.5	47.9	(32)	
	10%	WB	44.6	43.4	46.3	50.2	57.8	60.6	64.5	63.6	60.1	55.6	49.0	46.2	(33)	
		MCDB	45.6	44.3	47.4	52.7	63.9	65.8	68.2	67.4	62.8	56.8	50.3	47.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.6	7.1	9.1	11.1	9.9	9.9	9.3	7.6	6.5	5.7	5.3	(35)	
		MCDBR	5.4	5.9	8.8	14.1	18.3	14.9	15.1	13.1	9.7	7.6	5.8	5.3	(36)	
	5% WB	MCWBR	5.5	5.3	6.5	8.5	9.6	8.0	8.1	7.0	6.5	5.6	5.4	5.5	(37)	
		MCWBR	5.4	5.8	8.4	14.2	18.2	14.1	13.8	11.4	9.6	7.0	6.0	5.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.331	0.348	0.375	0.402	0.400	0.399	0.408	0.402	0.386	0.363	0.342	0.322	(40)	
		taud	2.314	2.349	2.304	2.275	2.348	2.368	2.348	2.380	2.414	2.413	2.351	2.309	(41)	
	Ebn at Noon	Ebn at Noon	199	237	254	262	269	271	265	260	249	228	193	178	(42)	
		Edh at Noon	19	25	32	37	37	36	36	34	29	23	19	16	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	188	390	826	1360	1695	1759	1691	1411	970	529	224	142	(44)	
	RadStd	RadStd	18	65	74	128	104	113	167	102	82	48	20	16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page