

WEST-Terschelling, Netherlands

WMO: 062500

Lat: 53.367N

Lon: 5.217E

Elev: 27

StdP: 101.00

Time Zone: 1.00 (EUC)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.1	-4.2	-9.1	1.7	-4.9	-7.4	2.0	-3.6	22.5	6.2	21.3	6.6	7.6	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	24.5	19.1	22.7	18.1	21.1	17.1	19.9	23.4	18.7	21.7	17.8	20.2	5.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	21.7	17.5	12.6	20.3	16.8	12.0	19.4	56.8	23.6	53.1	21.7	50.3	20.3	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.3	17.0	14.9	DB	-6.1	28.1	4.1	2.2	-9.1	29.6	-11.5	30.9	-13.7	32.1	-16.7	33.7	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	3.9	2.7	5.2	7.8	12.3	14.6	17.0	17.0	14.6	11.1	6.9	5.2		
	DBStd	5.71	3.56	3.72	2.94	2.68	3.34	2.76	2.23	2.07	1.98	2.48	2.97	2.62		
	HDD10.0	897	191	204	149	77	11	0	0	0	0	19	96	149		
	HDD18.3	3113	449	438	407	314	192	116	54	53	114	225	344	407		
	CDD10.0	859	0	0	1	12	81	140	218	216	137	52	2	0		
	CDD18.3	34	0	0	0	0	4	5	14	10	2	0	0	0		
	CDH23.3	95	0	0	0	0	13	16	41	22	3	0	0	0		
	CDH26.7	11	0	0	0	0	1	2	5	3	0	0	0	0		
(14) Wind	WSAvg	7.9	9.6	8.8	8.6	7.3	7.1	6.6	7.1	7.1	7.3	8.5	8.6	8.9		
(15) Precipitation	PrecAvg	832	68	55	46	37	50	56	71	83	91	97	94	84		
	PrecMax	1016	133	125	97	82	94	100	155	201	193	228	160	179		
	PrecMin	601	8	21	5	1	18	23	23	15	10	29	13	31		
	PrecStd	121	32	24	25	20	19	22	35	50	46	45	35	37		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	10.5	12.9	18.5	24.9	25.0	27.4	26.0	23.0	17.0	12.5	10.5		
		MCWB	8.9	9.7	10.6	13.7	18.1	19.5	21.2	19.6	19.0	14.6	11.2	9.6		
	2%	DB	8.6	8.9	11.0	15.9	22.4	22.7	24.8	23.0	19.6	15.7	11.6	9.7		
		MCWB	8.0	8.1	9.5	12.4	16.6	17.6	19.9	18.5	16.5	13.8	10.5	8.9		
	5%	DB	8.2	7.7	9.6	13.5	19.7	20.7	22.9	21.5	18.4	14.8	10.9	9.0		
		MCWB	7.5	6.9	8.5	11.0	15.2	16.6	18.6	17.7	15.9	13.2	9.9	8.1		
	10%	DB	7.6	6.9	8.6	11.8	17.5	19.0	21.0	20.1	17.4	14.1	10.3	8.4		
		MCWB	6.9	6.1	7.7	9.9	14.1	15.7	17.5	16.9	15.2	12.7	9.2	7.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	9.8	10.9	14.5	18.9	20.7	21.7	20.8	18.5	15.5	11.7	10.0		
		MCDB	9.2	10.4	12.7	17.2	24.2	23.6	26.5	24.5	21.7	16.7	12.1	10.2		
	2%	WB	8.3	8.2	9.7	12.8	17.0	18.2	20.3	19.0	17.4	14.4	10.8	9.1		
		MCDB	8.5	8.7	10.7	15.5	21.5	22.0	24.1	21.6	19.1	15.2	11.3	9.6		
	5%	WB	7.7	7.1	8.7	11.2	15.7	17.0	19.3	18.2	16.5	13.8	10.3	8.4		
		MCDB	8.1	7.6	9.4	12.9	19.7	20.1	22.3	20.5	17.9	14.6	10.8	8.8		
	10%	WB	7.0	6.3	7.9	10.1	14.3	15.9	18.0	17.6	15.6	13.1	9.5	7.9		
		MCDB	7.6	6.8	8.6	11.5	17.7	18.8	20.1	19.7	17.1	13.8	10.2	8.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.9	3.1	4.0	5.1	6.2	5.5	5.5	5.2	4.2	3.6	3.2	3.0		
		MCDBR	3.0	3.3	4.9	7.8	10.2	8.3	8.4	7.3	5.4	4.2	3.2	2.9		
	5% WB	MCWBR	3.1	3.0	3.6	4.7	5.4	4.5	4.5	3.9	3.6	3.1	3.0	3.1		
		MCWBR	3.0	3.2	4.7	7.9	10.1	7.8	7.7	6.3	5.3	3.9	3.3	3.2		
(40) Clear-Sky Solar Irradiance	taub		0.331	0.348	0.375	0.402	0.400	0.399	0.408	0.402	0.386	0.363	0.342	0.322		
	taud		2.314	2.349	2.304	2.275	2.348	2.368	2.348	2.380	2.414	2.413	2.351	2.309		
	Ebn at Noon		628	746	801	826	849	853	836	820	785	720	610	561		
	Edh at Noon		61	80	102	118	116	115	115	106	91	74	59	51		
(44) All-Sky Solar Radiation	RadAvg		0.59	1.23	2.60	4.29	5.34	5.55	5.33	4.45	3.06	1.67	0.70	0.45		
	RadStd		0.06	0.20	0.23	0.40	0.33	0.36	0.53	0.32	0.26	0.15	0.06	0.05		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page