

TERSCHELLING HOORN, Netherlands

WMO: 062510

Lat: 53.3911N

Lon: 5.3458E

Elev: 2

StdP: 101.30

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.2	-2.9	-7.5	2.0	-3.4	-5.6	2.3	-2.2	17.7	7.2	16.3	6.8	6.3	80	0.731

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	25.0	20.2	22.9	19.1	21.3	18.1	20.7	23.9	19.5	22.2	18.6	20.8	4.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.1	22.9	18.4	13.3	21.3	17.6	12.6	20.2	59.6	24.1	55.7	22.3	52.7	20.9	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.0	13.4	12.1	-6.4	29.2	2.2	1.4	-7.9	30.2	-9.2	31.0	-10.5	31.8	-12.1	32.8		
(5)			-6.8	23.3	2.3	0.9	-8.5	23.9	-9.9	24.5	-11.2	25.0	-12.9	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	3.6	3.5	5.4	8.7	11.8	14.5	16.9	17.1	15.0	11.3	7.5	4.7
	DBStd	5.67	3.24	3.01	2.83	2.93	2.85	2.59	2.59	2.40	2.31	2.61	2.73	3.38
	HDD10.0	863	200	183	143	59	13	0	0	0	0	17	82	166
	HDD18.3	3068	458	416	401	290	202	118	61	53	103	217	325	424
	CDD10.0	876	0	0	1	19	70	136	215	220	151	58	7	1
	CDD18.3	40	0	0	0	0	1	4	17	16	3	0	0	0
	CDH23.3	146	0	0	0	0	2	18	74	47	5	0	0	0
	CDH26.7	21	0	0	0	0	0	2	13	5	1	0	0	0
Wind	WSAvg	6.3	7.3	7.0	6.6	5.9	6.0	5.6	5.5	5.4	5.8	6.6	6.7	7.1
Precipitation	PrecAvg	843	68	56	46	38	53	62	74	87	89	93	91	84
	PrecMax	1073	131	126	97	85	97	123	157	200	192	181	157	177
	PrecMin	598	7	21	6	1	22	26	21	17	10	30	13	31
	PrecStd	122	32	25	25	21	22	26	36	50	44	38	35	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	10.1	13.6	19.9	22.2	25.9	28.5	27.3	23.5	18.5	14.2	11.3
		MCWB	9.3	8.9	10.8	15.0	17.0	21.0	21.9	21.4	19.9	16.4	13.2	10.4
	2%	DB	9.2	8.9	11.2	16.5	20.0	22.4	25.3	24.5	21.2	16.9	13.2	10.3
		MCWB	8.3	8.1	9.4	13.0	16.0	18.6	20.2	20.2	18.2	15.4	12.2	9.5
	5%	DB	8.5	8.1	9.9	14.6	18.1	20.4	23.1	22.3	19.7	15.8	12.2	9.6
		MCWB	7.7	7.3	8.6	12.1	15.0	17.2	19.2	18.9	17.3	14.5	11.0	8.7
	10%	DB	7.8	7.4	8.9	12.9	16.5	18.8	21.2	20.9	18.6	15.0	11.2	8.8
		MCWB	6.9	6.6	7.7	10.9	13.8	16.2	18.2	18.1	16.6	13.7	10.0	7.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	9.1	11.1	15.4	18.1	21.2	22.6	22.2	20.2	16.7	13.5	10.8
		MCDB	10.3	9.7	12.8	19.0	20.8	24.8	28.0	25.9	23.0	18.0	13.9	11.2
	2%	WB	8.6	8.3	9.7	13.5	16.4	19.1	20.7	20.5	18.6	15.6	12.4	9.7
		MCDB	9.1	8.8	10.9	16.1	19.2	21.7	24.1	23.6	20.5	16.6	13.1	10.1
	5%	WB	7.8	7.4	8.7	12.2	15.2	17.6	19.5	19.4	17.7	14.8	11.2	8.9
		MCDB	8.4	8.0	9.7	14.2	17.8	20.0	22.4	21.8	19.2	15.6	12.0	9.4
	10%	WB	7.1	6.7	8.0	11.1	14.1	16.4	18.5	18.4	16.9	13.9	10.2	8.1
		MCDB	7.7	7.3	8.8	12.7	16.1	18.3	20.9	20.4	18.3	14.7	11.1	8.7
Mean Daily Temperature Range	5% DB	MDBR	3.4	3.7	4.8	6.1	6.3	6.4	6.4	6.4	5.7	4.6	3.7	3.6
		MCDBR	3.2	3.9	6.1	8.5	8.9	9.1	9.5	8.3	7.1	5.1	3.8	3.3
		MCWBR	3.4	3.5	4.9	5.9	5.9	6.0	5.4	5.1	4.9	4.3	3.7	3.4
	5% WB	MCDBR	3.3	3.8	5.6	8.1	8.1	8.2	8.5	7.6	6.6	4.9	3.9	3.3
		MCWBR	3.5	3.5	4.7	5.8	5.6	5.7	5.2	5.0	4.8	4.4	3.9	3.5
Clear-Sky Solar Irradiance	taub	0.332	0.349	0.377	0.404	0.402	0.401	0.410	0.404	0.388	0.364	0.343	0.324	
	taud	2.311	2.344	2.297	2.268	2.341	2.362	2.342	2.373	2.407	2.409	2.347	2.306	
	Ebn at Noon	626	744	799	824	847	851	834	818	783	718	607	558	
	Edh at Noon	61	80	102	119	117	116	116	107	92	75	59	52	
All-Sky Solar Radiation	RadAvg	0.59	1.23	2.60	4.29	5.35	5.55	5.33	4.45	3.06	1.67	0.70	0.45	
	RadStd	0.06	0.20	0.23	0.40	0.33	0.36	0.53	0.32	0.26	0.15	0.06	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page