

WIJK AAN ZEE, Netherlands

WMO: 062570

Lat: 52.5053N

Lon: 4.6029E

Elev: 33

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.2	25.6	14.9	11.7	25.1	19.6	14.7	27.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	81.0	66.6	76.4	64.6	72.8	63.4	68.5	77.5	66.6	73.6	65.1	70.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.4	94.0	71.7	64.0	89.5	69.9	62.8	85.5	68.4	32.7	77.8	31.3	73.9	30.1	71.1	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
N/A	N/A	N/A	DB	16.2	90.4	5.3	3.7	12.4	93.0	9.3	95.2	6.3	97.3	2.5	100.0
			WB	15.4	72.4	5.1	1.6	11.7	73.6	8.8	74.6	5.9	75.5	2.3	76.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	39.9	39.4	42.8	48.9	54.4	59.4	63.6	63.8	59.7	53.6	46.8	41.5	(6)
	DBStd	10.53	6.48	6.59	5.96	6.49	6.16	5.08	5.01	4.30	4.63	5.87	5.76	6.79	(7)
	HDD50	1387	314	299	230	97	22	1	0	0	0	33	125	266	(8)
	HDD65	5143	779	718	688	485	336	182	85	73	169	354	546	728	(9)
	CDD50	1830	0	1	7	62	157	282	423	428	292	145	29	4	(10)
	CDD65	110	0	0	0	0	5	14	43	36	11	1	0	0	(11)
	CDH74	679	0	0	0	8	53	107	283	184	43	1	0	0	(12)
	CDH80	178	0	0	0	1	6	25	93	45	8	0	0	0	(13)
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)
(15) Precipitation	PrecAvg	35.0	3.0	2.3	1.9	1.6	2.0	2.4	2.9	3.9	3.6	4.0	3.9	3.4	(15)
	PrecMax	47.2	6.0	4.8	4.8	3.9	3.5	6.1	6.8	9.3	7.9	7.7	7.1	6.2	(16)
	PrecMin	26.7	0.3	0.7	0.4	0.0	0.7	0.8	0.5	0.8	0.4	1.1	0.4	0.9	(17)
	PrecStd	5.2	1.4	1.1	1.1	0.9	0.7	1.3	1.5	2.1	1.9	1.9	1.5	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.9	56.6	63.3	74.4	79.2	84.0	89.9	85.4	78.6	70.7	61.2	55.2	(19)
		MCWB	50.0	46.7	52.5	57.7	62.9	66.4	70.1	69.0	66.8	62.4	56.6	52.0	(20)
	2%	DB	50.3	51.9	57.5	68.5	74.6	76.7	81.4	79.0	73.3	66.3	57.8	52.8	(21)
		MCWB	48.0	47.0	49.7	55.5	60.5	64.9	67.2	66.5	64.2	60.2	54.9	50.3	(22)
	5%	DB	48.6	49.2	53.3	63.7	69.5	71.3	75.5	73.9	69.7	63.1	56.2	51.1	(23)
		MCWB	46.6	46.2	47.9	54.0	58.7	62.2	65.5	64.9	62.8	58.9	53.1	48.8	(24)
	10%	DB	47.3	47.2	50.3	59.1	64.3	67.8	71.5	70.6	67.0	61.2	54.5	49.4	(25)
		MCWB	45.4	44.9	46.5	51.9	56.7	60.7	64.3	63.5	61.5	57.3	51.3	47.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.7	49.5	53.7	59.8	66.0	69.6	71.2	70.6	68.4	63.5	57.6	52.8	(27)
		MCDB	52.4	51.9	60.9	71.0	76.5	80.5	83.2	81.3	77.1	69.1	59.4	54.4	(28)
	2%	WB	48.5	48.0	50.8	56.9	62.1	66.0	68.6	68.0	65.6	61.0	55.5	50.9	(29)
		MCDB	49.7	50.5	55.5	66.3	70.7	74.2	77.8	76.4	71.2	65.2	57.6	52.5	(30)
	5%	WB	47.1	46.6	48.6	54.5	59.5	63.5	66.7	66.1	64.0	59.5	53.8	49.2	(31)
		MCDB	48.3	49.1	52.1	61.9	67.3	69.7	73.7	71.9	68.6	62.7	55.9	50.8	(32)
	10%	WB	45.8	45.1	47.0	52.4	57.4	61.5	65.0	64.7	62.4	58.0	51.8	47.5	(33)
		MCDB	47.2	47.1	50.0	58.4	63.7	66.6	70.7	69.4	66.3	60.9	53.8	49.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	8.1	11.0	14.0	13.3	12.8	12.6	12.0	11.9	10.0	8.1	7.2	(35)
		MCDBR	5.9	10.1	16.2	21.5	22.2	20.9	21.0	19.0	16.6	11.5	8.0	6.1	(36)
	5% WB	MCWBR	5.9	7.3	10.1	11.2	10.3	10.9	9.6	9.3	9.5	7.8	6.9	5.8	(37)
		MCWBR	5.9	8.6	13.5	19.7	19.3	17.4	18.1	15.1	14.4	10.8	7.7	6.1	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.341	0.360	0.392	0.412	0.416	0.412	0.422	0.414	0.394	0.375	0.353	0.335	(40)
		taud	2.307	2.310	2.244	2.237	2.292	2.319	2.301	2.339	2.382	2.374	2.331	2.301	(41)
	Ebn at Noon	Ebn at Noon	200	234	250	260	265	267	262	257	248	226	194	179	(42)
		Edh at Noon	20	27	35	39	39	38	38	35	30	25	20	17	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	214	432	826	1338	1637	1735	1654	1374	983	556	246	158	(44)
	RadStd	RadStd	21	77	89	125	98	108	165	108	82	49	23	17	(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page