

DE BILT, Netherlands

WMO: 062600

Lat: 52.0989N

Lon: 5.1797E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.9	23.7	13.3	10.8	23.2	17.7	13.5	25.2	25.0	48.7	22.5	48.8	6.1	70	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	84.1	68.2	80.1	66.8	76.5	64.8	70.1	80.2	68.2	77.0	66.4	74.2	7.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	98.2	73.9	64.9	92.3	71.7	63.4	87.5	70.1	34.0	80.4	32.4	77.4	31.1	74.4	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.1	17.5	15.4	DB	14.3	91.2	6.2	2.8	9.9	93.3	6.3	94.9	2.9	96.5	-1.6	98.5	(4)
(5)			WB	13.6	74.5	5.9	2.0	9.3	75.9	5.9	77.1	2.5	78.2	-1.8	79.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	38.2	39.2	43.5	49.5	55.9	60.7	64.7	63.9	58.6	52.2	44.8	39.5	(6)
(7)		DBStd	11.26	7.42	7.03	6.08	6.49	6.42	5.46	5.52	4.94	4.84	5.90	6.12	7.50	(7)
(8)		HDD50	1538	366	304	213	87	17	0	0	0	1	45	174	331	(8)
(9)		HDD65	5277	830	722	667	464	292	153	74	81	199	398	605	792	(9)
(10)		CDD50	1886	1	2	11	73	198	320	455	430	260	113	19	4	(10)
(11)		CDD65	150	0	0	0	0	9	23	64	46	8	0	0	0	(11)
(12)		CDH74	1365	0	0	0	17	107	227	564	388	60	2	0	0	(12)
(13)		CDH80	353	0	0	0	1	14	55	167	108	8	0	0	0	(13)
(14)	Wind	WSAvg	7.5	8.9	8.7	8.5	7.5	7.3	6.9	6.4	6.1	6.3	7.3	7.5	8.4	(14)
(15)	Precipitation	PrecAvg	32.2	2.7	2.1	2.3	1.9	2.4	2.6	3.2	3.1	2.9	3.1	3.2	3.1	(15)
(16)		PrecMax	48.8	5.2	5.5	5.3	4.3	5.4	7.1	7.5	7.8	8.3	7.4	6.6	7.5	(16)
(17)		PrecMin	21.1	0.2	0.0	0.4	0.0	0.2	0.7	0.6	0.2	0.4	0.5	0.4	0.5	(17)
(18)		PrecStd	5.8	1.3	1.2	1.1	1.0	1.3	1.3	1.8	1.8	1.6	1.7	1.4	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	57.5	64.7	76.3	81.9	86.3	90.1	87.9	80.4	71.2	61.4	56.3	(19)
(20)			MCWB	51.9	50.0	54.5	59.3	66.0	69.3	69.6	68.1	67.5	63.5	57.0	53.3	(20)
(21)		2%	DB	52.3	53.0	59.6	70.5	76.8	80.1	84.5	83.1	74.8	66.0	58.1	54.0	(21)
(22)			MCWB	49.8	49.1	51.6	57.2	61.4	66.5	68.5	68.1	65.3	60.6	55.1	51.7	(22)
(23)		5%	DB	50.0	50.9	55.6	65.5	72.7	75.6	80.1	78.2	70.6	63.1	56.0	51.9	(23)
(24)			MCWB	47.9	47.7	49.7	54.7	60.0	64.1	67.2	66.9	63.0	58.8	53.2	49.7	(24)
(25)		10%	DB	47.9	48.8	52.8	61.1	68.4	71.6	76.0	73.9	67.3	60.8	53.6	49.5	(25)
(26)			MCWB	45.7	46.1	48.3	52.7	58.3	62.2	65.3	64.4	61.0	57.3	51.2	47.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	52.0	55.5	61.2	67.7	71.3	72.7	72.4	69.0	63.9	57.9	54.1	(27)
(28)			MCDWB	54.3	55.4	61.5	72.4	78.6	82.6	83.6	83.7	77.7	68.8	59.7	55.5	(28)
(29)		2%	WB	50.2	49.9	52.8	58.0	64.2	68.0	70.3	69.5	66.1	61.3	55.7	52.0	(29)
(30)			MCDWB	51.9	52.2	57.5	67.9	73.2	76.9	81.0	78.4	72.9	65.0	57.9	53.7	(30)
(31)		5%	WB	48.0	48.2	50.7	55.8	61.3	65.5	68.3	67.5	64.1	59.6	53.5	50.0	(31)
(32)			MCDWB	49.7	50.4	54.7	63.8	69.1	73.2	77.5	75.5	69.0	62.6	55.5	51.7	(32)
(33)		10%	WB	46.0	46.4	48.8	53.7	59.2	63.4	66.4	65.7	62.2	57.8	51.4	47.6	(33)
(34)			MCDWB	47.7	48.8	52.2	59.9	66.9	70.2	74.4	72.5	66.4	60.3	53.2	49.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	10.3	13.2	16.7	16.9	16.6	16.6	16.8	15.4	12.8	9.7	8.4	(35)
(36)			MCDBR	8.8	11.9	18.6	24.0	24.5	23.8	24.0	23.8	20.1	14.6	10.5	8.3	(36)
(37)			MCWBR	8.0	9.1	12.0	12.8	12.1	12.2	10.8	11.2	11.4	9.8	8.4	7.5	(37)
(38)		5% WB	MCDWR	8.9	10.7	15.9	21.1	20.9	20.7	21.2	20.8	17.5	13.9	10.0	8.6	(38)
(39)			MCWBR	8.5	8.9	11.0	11.9	11.2	11.7	10.5	10.9	10.7	9.9	8.5	8.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.366	0.400	0.420	0.426	0.421	0.432	0.423	0.398	0.379	0.355	0.339	(40)	
(41)		taud	2.290	2.268	2.187	2.183	2.216	2.247	2.226	2.271	2.327	2.332	2.305	2.280	(41)	
(42)		Ebn at Noon	201	232	247	258	262	265	259	254	246	225	194	180	(42)	
(43)		Edh at Noon	21	28	37	42	42	42	42	38	32	26	21	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	223	441	825	1331	1618	1728	1636	1374	996	572	259	167	(44)	
(45)		RadStd	24	82	101	132	111	120	176	113	87	48	24	19	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (86 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page