

DE BILT, Netherlands

WMO: 062600

Lat: 52.0989N

Lon: 5.1797E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.7	-4.6	-10.4	1.5	-4.9	-7.9	1.9	-3.8	11.2	9.3	10.1	9.3	2.7	70	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	29.0	20.1	26.7	19.3	24.7	18.2	21.1	26.8	20.1	25.0	19.1	23.5	3.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.0	23.3	18.3	13.2	22.0	17.5	12.5	21.1	61.2	26.9	57.5	25.2	54.4	23.5	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.0	7.8	6.9	-9.8	32.9	3.4	1.6	-12.3	34.0	-14.3	34.9	-16.2	35.8	-18.7	37.0
			-10.2	23.6	3.3	1.1	-12.6	24.4	-14.5	25.0	-16.4	25.6	-18.8	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	3.5	4.0	6.4	9.7	13.3	15.9	18.1	17.7	14.8	11.2	7.1	4.1
	DBStd	6.26	4.12	3.90	3.38	3.61	3.57	3.04	3.07	2.75	2.69	3.28	3.40	4.16
	HDD10.0	854	203	169	118	48	9	0	0	0	1	25	97	184
	HDD18.3	2932	461	401	371	258	162	85	41	45	111	221	336	440
	CDD10.0	1048	1	1	6	41	110	178	253	239	144	63	11	2
	CDD18.3	83	0	0	0	0	5	13	36	26	4	0	0	0
	CDH23.3	758	0	0	0	9	59	126	313	216	33	1	0	0
	CDH26.7	196	0	0	0	1	8	31	93	60	4	0	0	0
Wind	WSAvg	3.3	4.0	3.9	3.8	3.4	3.2	3.1	2.9	2.7	2.8	3.3	3.3	3.8
Precipitation	PrecAvg	819	68	54	59	47	62	67	82	78	73	78	81	79
	PrecMax	1240	133	139	134	108	138	181	191	198	211	188	167	190
	PrecMin	536	4	0	11	0	6	18	15	6	9	13	11	12
	PrecStd	148	32	30	28	26	32	32	46	45	40	42	35	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	14.2	18.2	24.6	27.7	30.2	32.3	31.0	26.9	21.8	16.4	13.5
		MCWB	11.0	10.0	12.5	15.2	18.9	20.7	20.9	20.1	19.7	17.5	13.9	11.9
	2%	DB	11.3	11.7	15.3	21.4	24.9	26.7	29.2	28.4	23.8	18.9	14.5	12.2
		MCWB	9.9	9.5	10.9	14.0	16.3	19.1	20.3	20.1	18.5	15.9	12.8	10.9
	5%	DB	10.0	10.5	13.1	18.6	22.6	24.2	26.7	25.6	21.5	17.3	13.3	11.1
		MCWB	8.8	8.7	9.8	12.6	15.5	17.8	19.6	19.4	17.2	14.9	11.8	9.8
	10%	DB	8.8	9.3	11.6	16.2	20.2	22.0	24.5	23.3	19.6	16.0	12.0	9.7
		MCWB	7.6	7.8	9.1	11.5	14.6	16.8	18.5	18.0	16.1	14.1	10.6	8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.1	13.1	16.2	19.8	21.9	22.6	22.4	20.5	17.7	14.4	12.3
		MCDB	12.4	13.0	16.4	22.5	25.9	28.1	28.7	28.7	25.4	20.5	15.4	13.0
	2%	WB	10.1	9.9	11.5	14.5	17.9	20.0	21.3	20.8	19.0	16.3	13.2	11.1
		MCDB	11.0	11.2	14.2	20.0	22.9	24.9	27.2	25.8	22.7	18.3	14.4	12.0
	5%	WB	8.9	9.0	10.4	13.2	16.3	18.6	20.2	19.7	17.8	15.3	11.9	10.0
		MCDB	9.8	10.2	12.6	17.7	20.6	22.9	25.3	24.2	20.6	17.0	13.0	10.9
	10%	WB	7.8	8.0	9.3	12.0	15.1	17.4	19.1	18.7	16.8	14.3	10.8	8.7
		MCDB	8.7	9.3	11.2	15.5	19.4	21.2	23.6	22.5	19.1	15.7	11.8	9.6
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.7	7.3	9.3	9.4	9.2	9.2	9.4	8.5	7.1	5.4	4.7
		MCDBR	4.9	6.6	10.3	13.3	13.6	13.2	13.3	13.2	11.2	8.1	5.8	4.6
		MCWBR	4.4	5.1	6.7	7.1	6.7	6.8	6.0	6.2	6.3	5.4	4.7	4.2
	5% WB	MCDBR	5.0	5.9	8.8	11.7	11.6	11.5	11.8	11.6	9.7	7.7	5.5	4.8
		MCWBR	4.7	4.9	6.1	6.6	6.2	6.5	5.9	6.0	5.9	5.5	4.7	4.5
Clear-Sky Solar Irradiance	taub	0.344	0.366	0.400	0.420	0.426	0.421	0.432	0.423	0.398	0.379	0.355	0.339	
	taud	2.290	2.268	2.187	2.183	2.216	2.247	2.226	2.271	2.327	2.332	2.305	2.280	
	Ebn at Noon	633	731	778	812	827	834	816	802	777	708	611	566	
	Edh at Noon	66	89	116	131	133	131	131	119	101	83	65	57	
All-Sky Solar Radiation	RadAvg	0.70	1.39	2.60	4.20	5.10	5.45	5.16	4.33	3.14	1.80	0.82	0.53	
	RadStd	0.07	0.26	0.32	0.41	0.35	0.38	0.56	0.36	0.27	0.15	0.08	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (86 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page