

SOESTERBERG, Netherlands

WMO: 062650

Lat: 52.127N

Lon: 5.276E

Elev: 66

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.9	22.1	11.8	10.1	20.8	16.4	12.6	23.8	26.8	48.1	24.1	48.6	5.3	80	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	85.1	67.7	81.0	66.7	77.2	64.8	69.8	80.4	68.1	77.6	66.5	74.9	8.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	97.7	73.1	64.7	91.9	71.4	63.2	87.0	69.9	33.8	80.3	32.4	77.6	31.1	75.2	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.4	18.8	16.6	DB	10.7	91.6	5.9	2.6	6.4	93.5	3.0	95.0	-0.4	96.5	-4.6	98.4	(4)
			WB	9.7	73.1	5.3	2.0	5.9	74.5	2.8	75.7	-0.2	76.8	-4.1	78.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.4	37.8	39.1	42.5	48.3	55.7	60.1	64.4	64.4	58.5	51.2	44.0	38.1
	DBStd	11.67	7.84	7.36	6.39	6.92	6.18	5.88	5.75	5.51	5.21	6.15	6.20	7.81
	HDD50	1692	380	309	243	114	16	0	0	0	2	61	193	374
	HDD65	5492	843	726	697	502	294	170	83	79	205	429	629	835
	CDD50	1837	1	3	10	62	193	303	447	447	256	97	14	4
	CDD65	165	0	0	0	1	6	23	65	60	10	0	0	0
	CDH74	1546	0	0	0	21	104	245	590	519	67	0	0	0
	CDH80	423	0	0	0	2	12	69	176	159	5	0	0	0
Wind	WSAvg	7.7	9.2	8.8	9.0	7.8	7.6	7.2	6.7	6.4	6.6	7.3	7.2	8.0
Precipitation	PrecAvg	32.2	2.7	2.1	2.3	1.9	2.4	2.6	3.2	3.1	2.9	3.1	3.2	3.1
	PrecMax	48.8	5.2	5.5	5.3	4.3	5.4	7.1	7.5	7.8	8.3	7.4	6.6	7.5
	PrecMin	21.1	0.2	0.0	0.4	0.0	0.2	0.7	0.6	0.2	0.4	0.5	0.4	0.5
	PrecStd	5.8	1.3	1.2	1.1	1.0	1.3	1.3	1.8	1.8	1.6	1.7	1.4	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	58.1	64.1	77.2	81.0	87.7	89.6	89.0	80.3	68.4	60.5	56.1
		MCWB	51.6	50.8	53.3	59.8	63.6	69.7	68.7	68.3	66.4	61.6	55.3	53.7
	2%	DB	52.4	53.6	59.1	69.7	76.6	81.2	85.2	84.7	75.5	64.7	57.3	53.6
		MCWB	50.1	49.3	50.7	56.8	60.2	66.3	68.2	67.2	65.0	59.8	54.6	51.6
	5%	DB	50.1	51.5	55.2	64.3	73.0	75.8	80.9	80.0	71.0	62.3	55.2	51.5
		MCWB	47.8	48.3	49.4	53.4	59.2	63.7	67.2	67.1	62.7	58.2	52.9	49.8
	10%	DB	48.0	49.3	52.5	60.1	68.4	71.8	76.6	75.2	67.6	60.3	52.9	49.2
		MCWB	46.0	46.5	48.3	51.8	57.5	62.0	65.7	65.2	61.0	56.9	50.7	47.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	52.2	55.6	61.4	66.0	70.8	72.7	71.8	68.5	63.5	57.2	54.3
		MCDB	54.0	55.3	61.6	73.0	78.1	83.2	82.4	84.2	76.4	67.6	59.0	55.4
	2%	WB	50.3	50.3	52.4	57.6	62.9	67.8	70.1	69.2	66.1	60.8	55.2	52.1
		MCDB	52.2	52.3	56.2	66.4	71.5	78.0	80.8	79.2	72.8	63.5	57.0	53.3
	5%	WB	48.2	48.5	50.5	55.0	60.5	65.3	68.4	67.5	63.9	59.1	53.3	50.0
		MCDB	49.7	50.8	54.1	61.9	68.6	73.5	78.1	76.5	69.4	61.5	55.0	51.4
	10%	WB	46.1	46.7	48.6	52.7	58.5	63.2	66.5	66.0	62.1	57.4	51.1	47.4
		MCDB	47.8	49.2	52.0	58.6	66.9	70.4	75.2	73.8	66.6	59.7	52.6	49.0
Mean Daily Temperature Range	5% DB	MDBR	9.4	11.3	13.7	17.2	17.5	17.5	16.9	17.0	15.9	13.6	10.5	9.0
		MCDBR	9.2	12.2	18.1	23.3	25.5	24.5	24.2	23.7	20.8	14.6	11.1	8.5
		MCWBR	8.3	9.1	11.8	12.6	12.3	12.5	10.9	10.0	11.6	10.3	9.0	7.9
	5% WB	MCDBR	9.5	10.1	14.3	20.5	22.0	21.3	21.4	21.1	16.8	13.5	10.0	8.8
MCWBR		9.1	8.3	10.4	12.1	12.1	11.9	10.8	9.8	10.1	10.5	8.8	8.3	
Clear-Sky Solar Irradiance	taub	0.342	0.364	0.398	0.418	0.423	0.419	0.430	0.421	0.396	0.378	0.354	0.337	
	taud	2.293	2.273	2.192	2.192	2.224	2.254	2.232	2.278	2.333	2.337	2.309	2.283	
	Ebn at Noon	201	233	247	258	263	265	259	255	247	225	194	180	
	Edh at Noon	21	28	37	41	42	41	41	37	32	26	21	18	
All-Sky Solar Radiation	RadAvg	223	440	825	1332	1619	1728	1637	1374	995	571	258	167	
	RadStd	24	81	100	131	110	119	175	113	86	48	24	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (84 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page