

STAVOREN, Netherlands

WMO: 062670

Lat: 52.8967N

Lon: 5.3833E

Elev: 10

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	24.7	15.4	12.0	23.3	20.0	15.0	25.6	37.2	45.5	33.7	45.4	10.1	80	0.678

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	79.4	68.4	75.5	66.2	72.4	64.9	69.8	76.7	67.9	73.9	66.1	71.0	9.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.3	100.5	73.7	65.5	94.3	71.4	64.0	89.2	69.2	33.8	76.7	32.3	74.1	30.8	71.1	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.3	27.5	24.6	DB	16.5	87.5	8.3	3.3	10.5	89.8	5.7	91.7	1.0	93.6	-5.0	96.0	(4)
(5)			WB	15.8	74.5	8.2	1.9	9.8	75.9	5.0	77.0	0.4	78.1	-5.6	79.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	37.3	38.2	42.3	48.8	55.5	60.2	63.9	63.8	59.3	52.1	45.0	39.2		
	DBStd	11.03	6.54	6.09	5.60	5.68	5.59	4.53	4.57	3.92	4.24	5.26	5.26	6.69		
	HDD50	1603	394	331	242	88	12	0	0	0	0	39	161	336		
	HDD65	5379	859	751	703	487	301	157	75	69	178	400	599	800		
	CDD50	1796	0	0	4	51	181	306	432	428	278	104	11	1		
	CDD65	99	0	0	0	0	5	13	43	32	6	0	0	0		
	CDH74	497	0	0	0	3	39	84	224	124	23	0	0	0		
	CDH80	102	0	0	0	0	4	15	57	23	3	0	0	0		
(14) Wind	WSAvg	12.7	14.4	13.7	13.3	12.3	12.8	12.2	11.8	11.2	11.4	13.1	13.2	13.7		
(15) Precipitation	PrecAvg	32.8	2.8	2.2	1.9	1.6	2.2	2.6	3.0	3.6	3.1	3.3	3.3	3.1		
	PrecMax	42.2	5.3	5.3	3.7	3.6	4.0	4.7	5.7	7.5	6.8	7.9	6.0	5.7		
	PrecMin	23.5	0.3	0.9	0.4	0.0	0.9	1.2	1.1	0.6	0.5	1.0	0.4	1.2		
	PrecStd	4.8	1.3	1.1	1.0	0.9	0.9	1.1	1.4	1.9	1.6	1.5	1.3	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	52.8	60.8	72.1	78.4	82.4	86.3	83.4	76.9	67.3	58.1	53.5		
		MCWB	49.5	48.5	52.8	58.9	65.2	68.6	71.1	69.5	66.9	61.5	55.6	52.0		
	2%	DB	48.6	49.5	54.8	66.2	73.7	75.6	79.7	77.3	71.6	63.1	55.8	51.2		
		MCWB	47.0	47.0	49.8	56.8	61.6	66.4	68.7	68.3	65.0	59.8	53.9	49.5		
	5%	DB	47.0	47.4	51.3	61.7	69.3	71.1	75.4	73.3	68.3	61.0	53.6	49.5		
		MCWB	45.5	45.4	48.2	54.7	60.6	64.2	67.1	66.0	63.1	58.1	51.8	48.1		
	10%	DB	45.3	45.7	49.3	57.5	64.7	67.9	71.9	70.6	65.7	59.2	51.9	47.3		
		MCWB	43.8	44.0	46.9	52.8	58.5	62.4	65.6	64.6	61.4	56.7	50.1	45.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	49.6	53.8	61.3	67.5	71.3	72.6	72.0	68.4	62.1	56.2	52.0		
		MCDB	51.0	51.8	58.3	69.1	75.3	79.7	81.2	78.8	74.5	65.5	57.5	53.1		
	2%	WB	47.4	47.6	50.5	57.8	63.7	67.7	70.0	69.1	65.8	60.2	54.0	50.0		
		MCDB	48.4	49.1	53.6	64.3	70.6	73.8	77.1	75.4	70.6	62.6	55.4	51.0		
	5%	WB	45.7	45.6	48.7	55.2	61.0	65.2	68.1	67.2	63.8	58.7	52.2	48.2		
		MCDB	46.8	47.0	51.1	60.5	67.3	70.0	74.2	72.2	67.2	60.6	53.3	49.4		
	10%	WB	44.0	44.1	47.1	53.1	58.8	63.0	66.2	65.4	62.3	57.1	50.4	46.0		
		MCDB	45.1	45.5	49.0	57.1	64.3	67.1	71.1	69.4	65.2	58.7	51.6	47.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.4	9.5	12.7	12.5	11.4	11.1	11.0	10.7	9.1	6.7	6.2		
		MCDBR	6.1	9.2	13.6	20.6	21.4	18.6	18.9	17.1	15.3	10.6	6.7	5.9		
	5% WB	MCWBR	6.0	7.4	9.7	12.7	11.8	11.6	10.3	9.9	9.5	8.0	6.1	5.9		
		MCWBR	6.3	8.2	12.3	18.4	18.3	16.4	16.8	15.0	13.7	10.2	6.6	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.334	0.354	0.382	0.406	0.407	0.404	0.416	0.409	0.389	0.368	0.346	0.328		
	taud		2.303	2.318	2.257	2.246	2.299	2.322	2.300	2.336	2.380	2.383	2.334	2.305		
	Ebn at Noon		200	235	252	261	267	269	263	258	249	227	194	179		
	Edh at Noon		20	26	34	39	39	38	38	35	30	24	19	17		
(44) All-Sky Solar Radiation	RadAvg		202	413	826	1348	1663	1746	1671	1391	977	544	236	151		
	RadStd		19	72	82	126	101	110	166	106	82	49	22	16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page