

STAVOREN, Netherlands

WMO: 062670

Lat: 52.8967N

Lon: 5.3833E

Elev: 3

StdP: 101.29

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.9	(c) -4.0	(d) -9.2	(e) 1.7	(f) -4.8	(g) -6.6	(h) 2.1	(i) -3.6	(j) 16.6	(k) 7.5	(l) 15.1	(m) 7.5	(n) 4.5	(o) 80	(p) 0.678

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.2	(c) 26.4	(d) 20.2	(e) 24.2	(f) 19.0	(g) 22.4	(h) 18.3	(i) 21.0	(j) 24.8	(k) 20.0	(l) 23.3	(m) 19.0	(n) 21.7	(o) 4.4	(p) 100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.4	23.2	18.6	13.5	21.9	17.8	12.7	20.7	60.8	24.9	57.1	23.4	53.9	21.7	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.0	(b) 12.3	(c) 11.0	(e) -8.6	(f) 30.8	(g) 4.6	(h) 1.8	(i) -11.9	(j) 32.1	(k) -14.6	(l) 33.2	(m) -17.2	(n) 34.2	(o) -20.6	(p) 35.5		
(4) 14.0	(5) 12.3	(6) 11.0	(7) -8.6	(8) 30.8	(9) 4.6	(10) 1.8	(11) -11.9	(12) 32.1	(13) -14.6	(14) 33.2	(15) -17.2	(16) 34.2	(17) -20.6	(18) 35.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	2.9	3.4	5.7	9.3	13.0	15.7	17.7	17.7	15.1	11.2	7.2	4.0
	DBStd	6.13	3.63	3.38	3.11	3.15	3.10	2.52	2.54	2.18	2.36	2.92	2.92	3.72
	HDD10.0	891	219	184	134	49	7	0	0	0	0	22	89	187
	HDD18.3	2988	477	417	391	271	167	87	42	38	99	222	333	444
	CDD10.0	998	0	0	2	28	101	170	240	238	154	58	6	1
	CDD18.3	55	0	0	0	0	3	7	24	18	3	0	0	0
	CDH23.3	276	0	0	0	2	22	47	124	69	13	0	0	0
	CDH26.7	57	0	0	0	0	2	8	32	13	2	0	0	0
Wind	WSAvg	5.7	6.4	6.1	5.9	5.5	5.7	5.5	5.3	5.0	5.1	5.8	5.9	6.1
Precipitation	PrecAvg	833	72	57	48	41	55	66	77	92	80	84	83	78
	PrecMax	1073	135	135	93	91	101	119	144	190	172	201	152	146
	PrecMin	596	7	22	10	1	24	30	27	14	12	25	10	30
	PrecStd	122	34	28	26	22	22	28	36	49	41	39	34	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	11.6	16.0	22.3	25.8	28.0	30.1	28.6	24.9	19.6	14.5	11.9
		MCWB	9.7	9.1	11.6	15.0	18.4	20.3	21.7	20.8	19.4	16.4	13.1	11.1
	2%	DB	9.2	9.7	12.7	19.0	23.2	24.2	26.5	25.2	22.0	17.3	13.2	10.7
		MCWB	8.3	8.3	9.9	13.8	16.4	19.1	20.4	20.2	18.4	15.4	12.2	9.7
	5%	DB	8.4	8.6	10.7	16.5	20.7	21.7	24.1	23.0	20.2	16.1	12.0	9.7
		MCWB	7.5	7.5	9.0	12.6	15.9	17.9	19.5	18.9	17.3	14.5	11.0	8.9
	10%	DB	7.4	7.6	9.6	14.2	18.2	20.0	22.1	21.4	18.7	15.1	11.0	8.5
		MCWB	6.6	6.7	8.3	11.5	14.7	16.9	18.7	18.1	16.4	13.7	10.1	7.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	9.8	12.1	16.3	19.7	21.8	22.5	22.2	20.2	16.7	13.4	11.1
		MCDB	10.5	11.0	14.6	20.6	24.1	26.5	27.3	26.0	23.6	18.6	14.1	11.7
	2%	WB	8.6	8.6	10.3	14.3	17.6	19.8	21.1	20.6	18.8	15.7	12.2	10.0
		MCDB	9.1	9.5	12.0	17.9	21.5	23.2	25.1	24.1	21.4	17.0	13.0	10.6
	5%	WB	7.6	7.6	9.3	12.9	16.1	18.5	20.0	19.6	17.7	14.8	11.2	9.0
		MCDB	8.2	8.3	10.6	15.9	19.6	21.1	23.5	22.4	19.6	15.9	11.8	9.7
	10%	WB	6.7	6.7	8.4	11.7	14.9	17.2	19.0	18.5	16.8	13.9	10.2	7.8
		MCDB	7.3	7.5	9.4	13.9	18.0	19.5	21.7	20.8	18.4	14.9	10.9	8.3
Mean Daily Temperature Range	5% DB	MDBR	3.5	4.1	5.3	7.0	6.9	6.3	6.2	6.1	5.9	5.1	3.7	3.5
		MCDBR	3.4	5.1	7.6	11.5	11.9	10.3	10.5	9.5	8.5	5.9	3.7	3.3
		MCWBR	3.3	4.1	5.4	7.1	6.6	6.4	5.7	5.5	5.3	4.4	3.4	3.3
	5% WB	MCDBR	3.5	4.5	6.8	10.2	10.2	9.1	9.3	8.4	7.6	5.7	3.7	3.3
		MCWBR	3.5	3.9	5.2	6.7	6.2	6.2	5.6	5.4	5.1	4.5	3.5	3.4
Clear-Sky Solar Irradiance	taub	0.334	0.354	0.382	0.406	0.407	0.404	0.416	0.409	0.389	0.368	0.346	0.328	
	taud	2.303	2.318	2.257	2.246	2.299	2.322	2.300	2.336	2.380	2.383	2.334	2.305	
	Ebn at Noon	632	742	794	824	843	848	829	814	784	717	611	565	
	Edh at Noon	63	83	107	122	122	121	121	111	95	77	61	53	
All-Sky Solar Radiation	RadAvg	0.64	1.30	2.60	4.25	5.24	5.50	5.27	4.38	3.08	1.72	0.74	0.47	
	RadStd	0.06	0.23	0.26	0.40	0.32	0.35	0.52	0.33	0.26	0.15	0.07	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page