

LELYSTAD AP, Netherlands

WMO: 062690

Lat: 52.457N

Lon: 5.520E

Elev: -4

StdP: 101.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.9	-4.7	-10.0	1.6	-5.6	-7.4	2.0	-4.0	14.7	9.6	13.2	9.7	3.7	70	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	28.2	20.0	26.0	19.2	24.1	18.1	21.2	26.5	20.1	24.4	19.1	22.8	4.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.0	23.4	18.4	13.2	22.2	17.5	12.5	21.0	61.2	26.6	57.4	24.5	54.1	22.9	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.1	8.9	DB	-9.5	32.8	4.5	1.7	-12.7	34.1	-15.3	35.1	-17.9	36.1	-21.1	37.3	(4)
(5)			WB	-9.7	23.5	4.1	0.9	-12.6	24.2	-15.0	24.8	-17.3	25.3	-20.3	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	3.1	3.6	6.0	9.6	13.4	15.8	17.8	17.3	14.9	11.0	7.0	4.0	(6)	
	DBStd	6.25	4.09	3.82	3.45	3.48	3.40	2.82	2.86	2.55	2.62	3.24	3.29	4.12	(7)	
	HDD10.0	892	213	180	130	48	7	0	0	0	1	27	98	189	(8)	
	HDD18.3	2986	471	413	383	262	158	86	45	50	107	227	339	446	(9)	
	CDD10.0	1017	1	1	4	37	112	175	242	228	149	59	9	2	(10)	
	CDD18.3	68	0	0	0	0	5	11	28	19	4	0	0	0	(11)	
	CDH23.3	587	0	0	0	8	62	100	232	148	37	1	0	0	(12)	
	CDH26.7	146	0	0	0	1	9	24	67	39	6	0	0	0	(13)	
(14) Wind	WSAvg	4.3	5.2	4.9	4.7	4.3	4.3	3.9	3.7	3.7	3.8	4.4	4.5	5.0	(14)	
(15) Precipitation	PrecAvg	878	75	63	57	46	61	76	96	87	79	77	80	80	(15)	
	PrecMax	1171	148	139	118	92	104	165	188	218	178	206	153	162	(16)	
	PrecMin	644	9	21	12	0	35	28	33	13	9	16	13	25	(17)	
	PrecStd	121	36	31	32	24	19	34	42	51	39	37	34	37	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	13.7	17.8	24.3	27.7	30.0	32.0	30.4	26.9	21.5	16.0	13.2	(19)	
		MCWB	10.9	9.9	12.2	14.8	17.9	21.2	21.2	20.5	19.8	17.0	14.0	11.9	(20)	
	2%	DB	11.0	11.4	14.8	21.0	24.9	26.1	28.3	27.2	23.9	18.5	14.2	11.9	(21)	
		MCWB	9.8	9.5	10.6	13.8	16.2	19.3	20.3	20.1	18.6	15.7	12.8	10.8	(22)	
	5%	DB	9.7	10.0	12.7	18.3	22.6	23.4	25.8	24.4	21.5	16.9	12.9	10.8	(23)	
		MCWB	8.6	8.4	9.8	12.7	15.6	18.0	19.6	18.9	17.4	14.6	11.5	9.8	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	8.5	8.8	11.1	15.8	20.1	21.5	23.6	22.4	19.6	15.7	11.7	9.4	(25)	
		MCWB	7.6	7.5	8.9	11.6	14.7	17.0	18.6	17.8	16.3	13.9	10.5	8.4	(26)	
	0.4%	WB	11.2	11.0	13.0	16.0	19.6	22.1	22.5	22.4	20.7	17.6	14.2	12.2	(27)	
		MCDB	12.2	12.4	15.8	22.3	25.3	28.4	28.0	28.5	25.1	20.4	15.3	12.9	(28)	
	2%	WB	10.0	9.8	11.4	14.4	17.8	20.1	21.3	20.6	19.0	16.0	13.0	11.0	(29)	
		MCDB	10.8	10.9	13.7	19.7	23.0	24.6	26.8	25.4	22.8	18.0	14.2	11.8	(30)	
(31) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	5%	WB	8.7	8.6	10.2	13.1	16.3	18.7	20.2	19.5	17.9	15.1	11.7	9.8	(31)	
		MCDB	9.5	9.8	12.3	17.3	20.8	22.3	24.8	23.3	20.9	16.6	12.7	10.6	(32)	
	10%	WB	7.6	7.5	9.1	12.0	15.1	17.5	19.1	18.4	16.9	14.1	10.6	8.5	(33)	
		MCDB	8.5	8.7	10.9	15.2	19.1	20.7	22.7	21.5	19.0	15.4	11.5	9.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.4	7.3	9.1	9.0	8.6	8.6	8.7	8.1	6.6	5.0	4.3	(35)	
		MCDBR	4.7	6.8	10.4	13.4	13.8	12.8	13.0	12.4	11.1	7.7	5.5	4.5	(36)	
	5% WB	MCWBR	4.5	5.3	7.1	7.4	6.8	7.1	6.4	6.3	6.4	5.2	4.6	4.2	(37)	
		MCWBR	4.9	6.1	9.1	11.9	11.5	11.1	11.6	10.9	9.9	7.2	5.3	4.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.339	0.360	0.390	0.413	0.416	0.413	0.424	0.416	0.393	0.373	0.351	0.333	(40)	
		taud	2.304	2.297	2.224	2.218	2.255	2.280	2.258	2.299	2.351	2.362	2.326	2.299	(41)	
	Ebn at Noon	Ebn at Noon	635	738	787	818	836	841	822	808	781	713	613	569	(42)	
		Edh at Noon	64	86	111	126	128	126	127	116	98	80	63	55	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.68	1.36	2.60	4.21	5.15	5.46	5.20	4.33	3.10	1.76	0.78	0.50	(44)	
	RadStd	RadStd	0.07	0.24	0.29	0.40	0.32	0.35	0.53	0.34	0.26	0.15	0.07	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (76 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)	

Nomenclature: See separate page