

DEELEN AP, Netherlands

WMO: 062750

Lat: 52.055N

Lon: 5.872E

Elev: 158

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.4	22.4	12.2	10.3	21.4	16.7	12.9	24.4	27.4	47.9	24.9	48.2	6.4	70	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	85.2	67.8	81.3	66.3	77.5	64.3	69.6	80.9	67.8	77.9	66.1	74.9	8.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	96.4	73.4	64.3	90.7	71.1	62.8	86.0	69.5	33.7	81.1	32.2	77.7	30.9	74.8	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.2	19.5	17.4		DB	11.4	92.2	6.5	3.1	6.7	94.4	2.8	96.2	-0.8	97.9	-5.6	100.2
				WB	10.7	73.6	6.4	1.8	6.1	74.9	2.4	76.0	-1.2	77.0	-5.9	78.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.3	36.7	37.8	42.5	49.0	55.4	60.5	64.7	63.7	58.4	51.5	43.8	38.5
	DBStd	11.88	7.63	7.26	6.56	7.21	6.93	6.10	6.16	5.68	5.28	6.23	6.25	7.50
	HDD50	1750	412	344	244	105	23	1	0	0	2	58	200	361
	HDD65	5547	876	762	698	482	306	162	82	92	209	420	635	823
	CDD50	1852	1	1	11	75	192	316	456	426	253	103	15	3
	CDD65	176	0	0	0	1	10	27	73	53	11	1	0	0
	CDH74	1640	0	0	0	26	111	282	689	455	74	3	0	0
	CDH80	458	0	0	0	2	16	68	221	139	12	0	0	0
Wind	WSAvg	8.3	9.8	9.6	9.2	8.3	8.1	7.5	7.0	6.8	7.0	8.1	8.2	9.5
Precipitation	PrecAvg	36.7	3.3	2.8	2.5	2.0	2.7	3.0	3.7	3.5	3.1	3.1	3.4	3.6
	PrecMax	57.3	5.9	5.6	5.4	3.6	4.9	6.2	8.8	8.7	7.3	8.3	6.0	8.9
	PrecMin	27.7	0.2	0.9	0.7	0.0	0.9	0.8	1.4	0.4	0.4	0.9	0.6	1.0
	PrecStd	6.1	1.6	1.3	1.3	1.0	0.9	1.2	1.9	2.0	1.8	1.4	1.4	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	57.3	65.5	77.8	82.6	87.6	91.7	89.3	81.1	71.6	60.7	55.7
		MCWB	51.3	49.5	53.4	58.4	64.5	69.1	68.9	69.5	66.0	63.4	56.4	52.9
	2%	DB	51.6	52.6	60.3	71.3	77.1	81.5	85.7	83.9	75.5	66.2	57.3	53.5
		MCWB	49.5	48.5	50.8	56.7	60.7	65.7	68.4	67.5	64.6	60.4	54.8	51.5
	5%	DB	49.2	50.3	55.7	66.2	73.3	76.9	81.5	79.3	71.1	62.8	55.0	51.3
		MCWB	47.4	47.4	49.3	54.2	59.5	64.0	66.9	66.3	62.4	58.4	52.6	49.3
	10%	DB	46.8	47.9	52.6	61.6	68.8	72.8	77.2	74.5	67.5	60.3	52.7	48.7
		MCWB	45.1	45.4	47.8	52.3	57.8	62.1	64.8	64.1	60.4	56.7	50.5	47.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	51.5	55.4	60.6	66.9	70.8	72.7	71.8	68.0	63.8	57.3	53.9
		MCDB	53.6	54.2	61.4	74.0	78.2	81.5	84.2	84.9	77.7	69.8	58.7	54.9
	2%	WB	49.8	49.4	52.6	57.5	63.6	67.7	69.9	69.0	65.5	61.0	55.1	51.8
		MCDB	51.3	51.7	57.7	67.9	73.4	77.5	81.6	79.3	73.3	65.0	57.1	53.3
	5%	WB	47.5	47.6	50.4	55.5	60.9	65.5	68.1	67.1	63.6	59.1	52.9	49.7
		MCDB	48.9	50.0	54.6	63.7	68.8	74.2	79.0	76.3	69.4	62.1	54.7	51.1
	10%	WB	45.3	45.6	48.4	53.4	58.7	63.3	66.2	65.4	61.8	57.4	50.7	47.1
		MCDB	46.7	47.8	52.0	60.2	66.9	71.1	75.1	73.1	66.4	60.0	52.3	48.6
Mean Daily Temperature Range	5% DB	MDBR	8.7	10.7	14.2	17.8	17.9	17.9	17.6	17.3	15.8	13.0	9.8	8.3
		MCDBR	9.1	12.5	20.0	24.1	24.0	24.3	24.2	23.6	20.0	14.8	10.5	8.8
		MCWBR	8.5	9.5	12.6	12.5	11.2	11.9	10.3	10.4	10.6	9.7	8.4	8.0
	5% WB	MCDBR	9.1	11.2	16.4	21.0	20.3	21.2	21.4	20.5	17.4	13.8	10.0	8.8
MCWBR		8.7	9.2	11.4	11.8	11.0	11.5	10.3	10.3	10.2	9.8	8.5	8.2	
Clear-Sky Solar Irradiance	taub	0.333	0.355	0.385	0.414	0.418	0.415	0.426	0.418	0.393	0.368	0.345	0.327	
	taud	2.333	2.315	2.238	2.202	2.230	2.255	2.233	2.278	2.336	2.378	2.349	2.317	
	Ebn at Noon	208	238	253	260	265	266	261	256	248	230	200	187	
	Edh at Noon	20	27	35	41	42	41	41	37	32	25	20	17	
All-Sky Solar Radiation	RadAvg	223	439	812	1311	1593	1702	1616	1361	988	572	262	170	
	RadStd	26	81	106	135	123	126	186	115	97	50	27	20	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (82 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page