

DEELEN AP, Netherlands

WMO: 062750

Lat: 52.055N

Lon: 5.872E

Elev: 48

StdP: 100.75

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.6	(c) -5.3	(d) -11.0	(e) 1.5	(f) -5.9	(g) -8.5	(h) 1.8	(i) -4.2	(j) 12.3	(k) 8.8	(l) 11.1	(m) 9.0	(n) 2.9	(o) 70	(p) 0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	29.6	19.9	27.4	19.0	25.3	17.9	20.9	27.2	19.9	25.5	19.0	23.8	3.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.8	23.0	17.9	13.0	21.7	17.1	12.3	20.8	60.5	27.3	57.1	25.4	54.0	23.8	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.9	(b) 8.7	(c) 7.8	(e) -11.5	(f) 33.4	(g) 3.6	(h) 1.7	(i) -14.1	(j) 34.7	(k) -16.2	(l) 35.7	(m) -18.2	(n) 36.6	(o) -20.9	(p) 37.9		
(a) 9.9	(b) 8.7	(c) 7.8	(e) -11.8	(f) 23.1	(g) 3.6	(h) 1.0	(i) -14.4	(j) 23.8	(k) -16.5	(l) 24.4	(m) -18.5	(n) 25.0	(o) -21.0	(p) 25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	2.6	3.2	5.8	9.4	13.0	15.8	18.2	17.6	14.7	10.8	6.6	3.6
	DBStd	6.60	4.24	4.03	3.65	4.00	3.85	3.39	3.42	3.15	2.93	3.46	3.47	4.17
	HDD10.0	972	229	191	136	58	13	1	0	0	1	32	111	201
	HDD18.3	3082	487	423	388	268	170	90	46	51	116	233	353	457
	CDD10.0	1029	1	1	6	42	107	176	253	237	141	57	8	2
	CDD18.3	98	0	0	0	1	6	15	41	29	6	1	0	0
	CDH23.3	911	0	0	0	14	62	157	383	253	41	2	0	0
	CDH26.7	254	0	0	0	1	9	38	123	77	7	0	0	0
Wind	WSAvg	3.7	4.4	4.3	4.1	3.7	3.6	3.4	3.1	3.0	3.1	3.6	3.7	4.2
Precipitation	PrecAvg	933	84	72	63	51	68	77	95	88	79	78	87	92
	PrecMax	1455	151	143	136	92	125	157	223	222	186	210	152	227
	PrecMin	704	6	23	18	0	24	21	36	10	9	24	15	26
	PrecStd	155	41	33	34	25	24	31	47	50	45	36	35	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	14.1	18.6	25.4	28.1	30.9	33.1	31.8	27.3	22.0	16.0	13.2
		MCWB	10.7	9.7	11.9	14.7	18.0	20.6	20.5	20.8	18.9	17.4	13.5	11.6
	2%	DB	10.9	11.4	15.7	21.8	25.0	27.5	29.9	28.8	24.2	19.0	14.1	11.9
		MCWB	9.7	9.2	10.5	13.7	16.0	18.7	20.2	19.7	18.1	15.8	12.6	10.8
	5%	DB	9.6	10.2	13.1	19.0	22.9	25.0	27.5	26.3	21.7	17.1	12.8	10.7
		MCWB	8.6	8.5	9.6	12.3	15.3	17.8	19.4	19.1	16.9	14.7	11.4	9.6
	10%	DB	8.2	8.8	11.4	16.4	20.4	22.7	25.1	23.6	19.7	15.7	11.5	9.3
		MCWB	7.3	7.4	8.8	11.3	14.3	16.7	18.2	17.9	15.8	13.7	10.3	8.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	10.9	13.0	15.9	19.4	21.6	22.6	22.1	20.0	17.6	14.1	12.2
		MCDB	12.0	12.4	16.3	23.3	25.7	27.5	29.0	29.4	25.4	21.0	14.8	12.7
	2%	WB	9.9	9.7	11.4	14.2	17.6	19.8	21.0	20.6	18.6	16.1	12.8	11.0
		MCDB	10.7	11.0	14.3	19.9	23.0	25.3	27.6	26.3	22.9	18.4	13.9	11.9
	5%	WB	8.6	8.7	10.2	13.0	16.1	18.6	20.1	19.5	17.6	15.1	11.6	9.8
		MCDB	9.4	10.0	12.6	17.6	20.5	23.4	26.1	24.6	20.8	16.7	12.6	10.6
	10%	WB	7.4	7.6	9.1	11.9	14.8	17.4	19.0	18.5	16.5	14.1	10.4	8.4
		MCDB	8.2	8.8	11.1	15.7	19.4	21.7	24.0	22.8	19.1	15.5	11.3	9.2
Mean Daily Temperature Range	5% DB	MDBR	4.9	6.0	7.9	9.9	10.0	10.0	9.8	9.6	8.8	7.2	5.4	4.6
		MCDBR	5.0	7.0	11.1	13.4	13.3	13.5	13.4	13.1	11.1	8.2	5.9	4.9
		MCWBR	4.7	5.3	7.0	7.0	6.2	6.6	5.7	5.8	5.9	5.4	4.7	4.4
	5% WB	MCDBR	5.1	6.2	9.1	11.7	11.3	11.8	11.9	11.4	9.7	7.7	5.5	4.9
		MCWBR	4.9	5.1	6.4	6.5	6.1	6.4	5.7	5.6	5.4	4.7	4.4	4.6
Clear-Sky Solar Irradiance	taub	0.333	0.355	0.385	0.414	0.418	0.415	0.426	0.418	0.393	0.368	0.345	0.327	
	taud	2.333	2.315	2.238	2.202	2.230	2.255	2.233	2.278	2.336	2.378	2.349	2.317	
	Ebn at Noon	655	749	797	819	835	840	822	807	783	726	632	589	
	Edh at Noon	64	85	111	129	131	130	130	118	100	79	62	55	
All-Sky Solar Radiation	RadAvg	0.70	1.38	2.56	4.13	5.02	5.36	5.09	4.29	3.12	1.80	0.82	0.54	
	RadStd	0.08	0.25	0.33	0.43	0.39	0.40	0.59	0.36	0.30	0.16	0.09	0.06	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (82 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page