

HOOGEVEEN, Netherlands

WMO: 062790

Lat: 52.7489N

Lon: 6.5731E

Elev: 52

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.5	22.7	13.7	11.0	22.2	18.0	13.7	23.7	29.6	48.5	26.9	48.2	7.6	70	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	83.7	67.7	79.3	66.5	75.8	64.6	69.8	80.2	67.9	76.7	66.1	73.6	8.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	97.6	73.8	64.7	91.7	71.4	63.2	86.8	69.6	33.8	80.2	32.3	76.9	30.8	73.5	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.5	20.7	18.3														
			DB		15.2	91.0	6.6	3.5	10.5	93.6	6.6	95.7	2.9	97.7	-1.9	100.2
			WB		14.6	73.8	6.5	1.9	9.9	75.2	6.1	76.3	2.5	77.3	-2.3	78.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	36.8	38.1	42.4	49.2	55.6	60.4	63.5	62.8	58.0	51.0	43.9	38.4
	DBStd	11.39	7.38	6.78	6.27	6.56	6.28	5.46	5.46	4.74	4.85	5.94	5.99	7.69
	HDD50	1722	411	335	242	94	17	0	0	0	2	61	197	363
	HDD65	5576	875	754	700	476	300	161	97	101	217	435	634	826
	CDD50	1741	1	1	7	69	190	311	418	397	241	91	12	3
	CDD65	120	0	0	0	1	8	22	50	33	6	0	0	0
	CDH74	1189	0	0	0	18	94	229	490	292	64	2	0	0
	CDH80	315	0	0	0	1	14	57	150	84	9	0	0	0
Wind	WSAvg	9.0	11.0	10.6	10.1	9.1	8.9	8.0	7.4	6.9	7.2	8.9	9.3	10.6
Precipitation	PrecAvg	34.1	3.0	2.5	2.3	1.9	2.5	2.9	3.7	3.3	3.0	2.9	3.0	3.1
	PrecMax	45.5	5.7	5.6	4.7	4.2	6.8	6.3	7.8	7.0	5.9	10.2	6.5	6.7
	PrecMin	25.1	0.3	0.9	0.5	0.0	0.9	0.6	1.3	0.4	0.4	0.9	0.3	0.9
	PrecStd	5.0	1.5	1.3	1.3	1.0	1.2	1.3	1.5	1.7	1.5	1.7	1.4	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	56.2	63.8	76.9	82.0	86.6	90.4	88.1	80.4	70.4	60.5	55.5
		MCWB	51.3	49.0	53.5	58.7	64.2	69.5	69.1	69.2	68.0	62.3	57.0	53.2
	2%	DB	51.3	52.0	58.9	70.1	76.1	80.0	84.0	81.4	75.1	64.8	57.0	53.2
		MCWB	49.2	48.5	51.1	56.6	61.0	66.4	68.2	67.9	65.4	59.9	54.7	51.3
	5%	DB	48.8	49.7	54.6	65.6	72.2	75.6	79.3	76.4	70.5	61.8	54.6	51.1
		MCWB	47.0	46.9	49.3	54.7	59.6	64.4	67.2	66.0	63.0	57.7	52.4	49.1
	10%	DB	46.7	47.4	51.6	61.1	68.1	71.5	75.2	72.7	66.9	59.4	52.3	48.3
		MCWB	44.9	45.0	47.5	53.1	57.8	62.2	65.3	63.9	60.9	56.3	50.3	46.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.9	51.6	55.1	60.9	66.9	71.8	72.5	71.7	68.8	63.3	57.4	53.8
		MCDB	53.7	54.1	60.6	71.6	77.0	82.5	83.4	81.9	78.1	68.8	59.1	55.0
	2%	WB	49.5	49.2	52.1	58.0	63.6	68.2	70.1	69.0	66.1	60.4	55.0	51.6
		MCDB	51.1	51.1	56.7	67.6	72.8	76.8	80.6	77.9	73.2	64.4	56.9	52.9
	5%	WB	47.2	47.2	50.1	55.8	61.1	65.8	68.1	66.9	63.8	58.5	52.6	49.3
		MCDB	48.6	49.5	54.0	63.5	69.2	73.6	77.7	74.5	69.3	61.1	54.4	50.9
	10%	WB	45.1	45.1	48.0	53.7	58.9	63.4	66.1	65.0	61.9	56.8	50.5	46.9
		MCDB	46.6	47.3	51.5	59.9	66.7	69.9	73.2	71.1	66.0	59.1	52.1	48.3
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.4	12.9	17.5	17.4	17.3	17.3	17.1	15.8	12.6	9.1	7.6
		MCDBR	8.2	12.2	19.0	25.1	24.4	24.5	25.1	23.8	21.5	14.9	10.1	8.4
		MCWBR	7.5	9.3	12.4	13.4	12.0	12.8	12.0	12.3	12.4	10.3	8.4	7.7
	5% WB	MCDBR	8.3	11.0	16.9	21.3	20.8	21.5	22.5	20.8	19.6	14.0	10.0	8.5
		MCWBR	7.8	9.1	11.7	12.3	11.4	12.3	11.7	11.7	12.0	10.3	8.7	7.9
Clear-Sky Solar Irradiance	taub	0.326	0.346	0.375	0.406	0.407	0.405	0.417	0.410	0.388	0.360	0.339	0.319	
	taud	2.332	2.335	2.268	2.225	2.258	2.280	2.258	2.297	2.352	2.401	2.357	2.320	
	Ebn at Noon	206	239	255	261	267	269	263	258	249	231	199	185	
	Edh at Noon	20	26	34	40	40	40	40	36	31	24	19	17	
All-Sky Solar Radiation	RadAvg	205	417	783	1280	1570	1659	1586	1326	957	550	247	160	
	RadStd	22	70	99	134	137	123	196	109	106	55	25	17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (61 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page