

NIEUW BEERTA, Netherlands

WMO: 062860

Lat: 53.1944N

Lon: 7.1492E

Elev: 0

StdP: 14.70

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.3	22.0	13.4	10.9	19.5	17.6	13.4	23.3	35.2	46.9	31.8	47.2	8.5	90	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	83.6	68.2	79.2	66.8	75.6	64.9	69.9	80.4	68.0	76.9	66.3	73.4	9.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	97.4	73.5	64.8	91.9	71.7	63.3	87.1	69.9	33.9	80.6	32.3	77.1	30.9	73.6	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.8	24.4	21.6	13.1	91.6	6.8	3.7	8.2	94.3	4.2	96.5	0.4	98.5	-4.5	101.2
			12.5	74.5	6.8	2.1	7.6	76.0	3.6	77.2	-0.2	78.4	-5.1	79.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.8	36.3	37.7	41.8	48.3	54.7	59.5	63.5	63.5	58.5	51.2	43.7	38.2	(6)
	DBStd	11.51	7.59	6.74	6.23	6.23	5.94	5.29	5.50	4.91	4.89	5.93	5.89	7.62	(7)
	HDD50	1784	426	347	259	105	20	1	0	0	1	57	201	367	(8)
	HDD65	5670	891	766	719	501	325	182	98	87	203	428	640	830	(9)
	CDD50	1711	0	1	5	54	165	285	417	420	257	94	11	2	(10)
	CDD65	123	0	0	0	0	5	16	51	41	9	1	0	0	(11)
	CDH74	1128	0	0	0	9	60	168	468	343	77	3	0	0	(12)
	CDH80	301	0	0	0	0	5	37	142	105	12	0	0	0	(13)
(14) Wind	WSAvg	10.9	13.1	12.6	12.2	10.6	10.0	9.2	8.9	9.1	9.9	11.5	11.3	12.8	(14)
(15) Precipitation	PrecAvg	31.2	2.6	2.1	1.9	1.6	2.4	2.8	3.4	3.2	3.0	2.6	2.8	2.9	(15)
	PrecMax	40.2	5.4	4.9	3.9	3.9	4.3	5.7	6.5	7.0	7.8	6.8	5.8	6.1	(16)
	PrecMin	22.3	0.2	0.6	0.4	0.0	0.5	0.3	1.8	0.6	0.6	0.6	0.1	0.9	(17)
	PrecStd	4.4	1.4	1.1	1.1	0.8	1.0	1.1	1.2	1.3	1.5	1.2	1.3	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	55.5	63.4	74.4	79.9	84.9	90.2	89.0	81.4	70.7	60.1	55.0	(19)
		MCWB	51.3	49.7	53.6	59.7	66.1	70.6	70.7	68.9	67.4	62.5	56.7	52.8	(20)
	2%	DB	50.7	51.4	57.8	68.8	74.8	78.8	84.0	82.6	75.5	64.8	56.6	52.8	(21)
		MCWB	48.9	48.1	51.0	56.8	62.0	67.3	68.6	67.4	64.9	59.9	54.3	50.9	(22)
	5%	DB	48.4	49.1	54.0	64.1	70.9	74.2	79.2	77.0	70.7	61.7	54.2	50.7	(23)
		MCWB	46.8	46.5	49.3	55.2	60.1	64.9	67.4	65.5	62.7	57.9	52.1	48.9	(24)
	10%	DB	46.3	46.8	51.1	60.0	66.7	70.0	74.9	73.5	67.0	59.4	51.9	48.0	(25)
		MCWB	44.6	44.7	47.4	53.1	58.7	62.6	65.5	63.9	60.7	56.4	50.0	46.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	51.6	55.2	61.7	68.1	72.3	72.6	71.1	68.6	63.0	57.3	53.4	(27)
		MCDB	53.4	54.4	60.1	71.6	76.6	81.9	83.8	82.3	78.1	68.8	59.1	54.9	(28)
	2%	WB	49.2	48.7	52.0	58.3	64.1	68.4	70.1	68.7	66.0	60.4	54.7	51.2	(29)
		MCDB	50.5	50.7	56.0	66.1	71.5	76.4	80.8	78.4	73.4	64.3	56.5	52.5	(30)
	5%	WB	46.8	46.8	50.1	55.9	61.3	66.0	68.3	66.8	63.7	58.5	52.2	49.0	(31)
		MCDB	48.1	48.8	53.6	62.5	68.1	72.5	77.8	74.8	69.4	61.1	53.9	50.5	(32)
	10%	WB	44.8	44.8	47.7	53.6	59.0	63.6	66.3	65.2	61.7	56.7	50.1	46.5	(33)
		MCDB	46.2	46.8	50.8	59.6	65.8	68.9	73.1	71.6	65.8	59.0	51.7	47.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	9.4	13.0	17.3	17.7	17.0	17.2	16.8	14.7	11.9	8.6	7.4	(35)
		MCDBR	8.2	11.9	18.8	24.8	24.9	24.4	25.3	23.4	20.6	14.2	9.8	8.1	(36)
	5% WB	MCWBR	7.6	9.6	12.9	14.9	13.9	14.3	12.3	11.2	11.3	9.7	8.3	7.7	(37)
		MCWBR	8.2	10.6	16.6	22.1	21.6	21.9	22.7	20.6	18.4	13.1	9.5	8.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.327	0.346	0.375	0.407	0.405	0.403	0.416	0.410	0.388	0.361	0.341	0.319	(40)
		taud	2.323	2.332	2.269	2.231	2.271	2.297	2.276	2.308	2.364	2.402	2.353	2.313	(41)
	Ebn at Noon		203	237	254	260	268	269	263	257	248	229	195	181	(42)
		Edh at Noon	19	26	33	39	40	39	39	36	30	24	19	16	(43)
(44) All-Sky Solar Radiation	RadAvg		192	400	781	1294	1601	1685	1601	1332	950	535	233	148	(44)
	RadStd		19	64	89	129	135	123	189	108	98	54	23	16	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-212	N/A	N/A

Nomenclature: See separate page