

NIEUW BEERTA, Netherlands

WMO: 062860

Lat: 53.1944N

Lon: 7.1492E

Elev: 0

StdP: 101.33

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.6	-5.5	-10.3	1.6	-6.9	-8.0	1.9	-4.8	15.7	8.3	14.2	8.4	3.8	90	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	28.7	20.1	26.2	19.3	24.2	18.3	21.1	26.9	20.0	24.9	19.0	23.0	4.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	13.9	23.1	18.2	13.1	22.0	17.4	12.4	21.1	60.9	27.0	57.3	25.0	54.1	23.1	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	10.9	9.6	-10.5	33.1	3.8	2.0	-13.2	34.6	-15.4	35.8	-17.5	37.0	-20.3	38.4
			-10.9	23.6	3.8	1.1	-13.6	24.5	-15.8	25.1	-17.9	25.8	-20.6	26.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	2.4	3.1	5.5	9.1	12.6	15.3	17.5	17.5	14.7	10.7	6.5	3.5
	DBStd	6.40	4.22	3.75	3.46	3.46	3.30	2.94	3.06	2.73	2.71	3.29	3.27	4.24
	HDD10.0	991	237	193	144	58	11	1	0	0	1	32	112	204
	HDD18.3	3150	495	426	399	278	181	101	54	48	113	238	356	461
	CDD10.0	951	0	1	3	30	92	158	232	233	143	52	6	1
	CDD18.3	68	0	0	0	0	3	9	28	23	5	1	0	0
	CDH23.3	627	0	0	0	5	33	93	260	191	43	2	0	0
	CDH26.7	167	0	0	0	0	3	21	79	58	7	0	0	0
Wind	WSAvg	4.9	5.9	5.6	5.5	4.7	4.5	4.1	4.0	4.1	4.4	5.1	5.1	5.7
Precipitation	PrecAvg	792	66	53	49	40	60	70	87	81	75	65	72	73
	PrecMax	1020	138	125	99	98	110	145	165	178	197	172	148	154
	PrecMin	567	4	14	9	1	12	8	46	15	15	15	3	23
	PrecStd	112	35	27	28	21	25	29	31	32	37	30	33	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	13.1	17.5	23.6	26.6	29.4	32.3	31.7	27.5	21.5	15.6	12.8
		MCWB	10.7	9.8	12.0	15.4	18.9	21.4	21.5	20.5	19.7	17.0	13.7	11.5
	2%	DB	10.4	10.8	14.3	20.4	23.8	26.0	28.9	28.1	24.2	18.2	13.7	11.5
		MCWB	9.4	9.0	10.5	13.8	16.7	19.6	20.3	19.7	18.3	15.5	12.4	10.5
	5%	DB	9.1	9.5	12.2	17.8	21.6	23.4	26.2	25.0	21.5	16.5	12.3	10.4
		MCWB	8.2	8.1	9.6	12.9	15.6	18.3	19.6	18.6	17.0	14.4	11.2	9.4
	10%	DB	8.0	8.2	10.6	15.6	19.3	21.1	23.9	23.0	19.4	15.2	11.0	8.9
		MCWB	7.0	7.1	8.6	11.7	14.8	17.0	18.6	17.7	15.9	13.6	10.0	8.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.0	10.9	12.9	16.5	20.0	22.4	22.5	21.7	20.4	17.2	14.0	11.9
		MCDB	11.9	12.4	15.6	22.0	24.8	27.7	28.8	27.9	25.6	20.4	15.1	12.7
	2%	WB	9.5	9.3	11.1	14.6	17.8	20.2	21.2	20.4	18.9	15.8	12.6	10.7
		MCDB	10.3	10.4	13.3	19.0	21.9	24.7	27.1	25.8	23.0	17.9	13.6	11.4
	5%	WB	8.2	8.2	10.0	13.3	16.3	18.9	20.2	19.3	17.6	14.7	11.2	9.4
		MCDB	8.9	9.4	12.0	16.9	20.1	22.5	25.4	23.8	20.8	16.2	12.2	10.3
	10%	WB	7.1	7.1	8.7	12.0	15.0	17.5	19.1	18.4	16.5	13.7	10.1	8.1
		MCDB	7.9	8.2	10.4	15.4	18.8	20.5	22.8	22.0	18.8	15.0	11.0	8.8
Mean Daily Temperature Range	5% DB	MDBR	4.2	5.2	7.2	9.6	9.8	9.5	9.6	9.3	8.1	6.6	4.8	4.1
		MCDBR	4.6	6.6	10.5	13.8	13.8	13.5	14.0	13.0	11.5	7.9	5.4	4.5
		MCWBR	4.2	5.3	7.2	8.3	7.7	8.0	6.8	6.2	6.3	5.4	4.6	4.3
	5% WB	MCDBR	4.5	5.9	9.2	12.3	12.0	12.2	12.6	11.5	10.2	7.3	5.3	4.5
		MCWBR	4.3	5.1	6.7	7.8	7.4	7.6	6.6	5.9	6.1	5.3	4.7	4.3
Clear-Sky Solar Irradiance	taub	0.327	0.346	0.375	0.407	0.405	0.403	0.416	0.410	0.388	0.361	0.341	0.319	
	taud	2.323	2.332	2.269	2.231	2.271	2.297	2.276	2.308	2.364	2.402	2.353	2.313	
	Ebn at Noon	639	748	800	821	844	848	828	811	782	723	615	570	
	Edh at Noon	61	81	105	124	125	123	124	114	96	75	59	52	
All-Sky Solar Radiation	RadAvg	0.60	1.26	2.46	4.08	5.05	5.31	5.05	4.20	3.00	1.69	0.74	0.47	
	RadStd	0.06	0.20	0.28	0.41	0.43	0.39	0.60	0.34	0.31	0.17	0.07	0.05	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-118	N/A	N/A

Nomenclature: See separate page