

WESTDORPE, Netherlands

WMO: 063190

Lat: 51.2247N

Lon: 3.8611E

Elev: 7

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.0	(c) 26.0	(d) 16.3	(e) 12.5	(f) 24.2	(g) 20.8	(h) 15.6	(i) 27.2	(j) 31.8	(k) 47.9	(l) 29.2	(m) 49.6	(n) 7.0	(o) 70	(p) 0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 17.4	(c) 84.1	(d) 68.1	(e) 79.8	(f) 66.4	(g) 76.4	(h) 64.7	(i) 70.0	(j) 81.0	(k) 68.1	(l) 77.3	(m) 66.4	(n) 74.1	(o) 7.8	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	96.7	73.9	64.7	91.5	71.6	63.3	87.0	70.2	33.9	81.6	32.4	77.6	31.0	74.0	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 25.2	(b) 22.1	(c) 19.5	(e) 18.0	(f) 92.0	(g) 7.0	(h) 4.2	(i) 13.0	(j) 94.9	(k) 8.8	(l) 97.4	(m) 4.9	(n) 99.7	(o) -0.2	(p) 102.7		
			DB	17.2	74.2	6.8	1.7	12.4	75.4	8.4	76.4	4.6	77.4	-0.4	78.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	39.3	40.5	44.7	50.3	56.5	61.1	64.4	64.2	59.9	53.1	45.9	40.7		
	DBStd	10.79	7.13	6.74	5.89	6.26	5.85	5.18	4.95	4.41	4.67	5.80	5.91	7.16		
	HDD50	1340	333	270	179	72	10	0	0	0	0	35	147	294		
	HDD65	4959	795	687	628	441	272	141	71	68	163	368	573	752		
	CDD50	1994	3	3	16	81	211	332	448	439	299	132	24	6		
	CDD65	140	0	0	0	0	8	23	53	43	12	1	0	0		
	CDH74	1325	0	0	0	18	93	245	513	361	91	4	0	0		
	CDH80	347	0	0	0	1	12	62	154	104	14	0	0	0		
(14) Wind	WSAvg	9.2	11.2	10.8	10.1	9.0	8.9	8.0	7.8	7.7	7.7	8.9	9.6	10.9		
(15) Precipitation	PrecAvg	32.1	2.7	2.4	1.9	1.7	2.3	2.7	3.1	3.5	2.7	2.8	3.2	3.2		
	PrecMax	38.1	5.5	4.9	5.0	3.5	4.1	5.0	6.3	10.3	8.1	5.5	5.7	7.1		
	PrecMin	24.1	0.2	0.6	0.1	0.0	0.8	0.8	0.7	1.0	0.5	0.9	0.2	0.7		
	PrecStd	3.7	1.3	1.1	1.1	1.0	0.9	1.2	1.5	2.2	1.7	1.0	1.3	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.5	58.0	65.9	76.5	81.5	87.1	90.1	88.6	81.6	72.6	62.6	57.0		
		MCWB	52.4	50.0	54.2	58.6	65.7	70.2	70.2	70.2	67.6	63.2	58.3	53.9		
	2%	DB	53.3	54.3	60.9	71.0	76.3	80.3	84.2	82.7	76.6	66.9	59.0	55.0		
		MCWB	50.8	49.8	52.5	57.2	62.4	66.6	67.9	68.4	65.4	60.9	55.6	52.4		
	5%	DB	51.0	51.9	56.8	66.0	72.0	75.9	79.6	77.6	72.2	63.7	56.6	53.0		
		MCWB	48.6	48.6	50.8	55.3	60.6	65.1	66.9	66.0	63.5	59.0	53.7	50.5		
	10%	DB	48.9	49.8	53.8	61.3	67.8	72.0	75.6	73.7	68.7	61.4	54.5	50.5		
		MCWB	46.7	47.1	49.2	52.9	58.7	62.9	65.3	63.8	61.4	57.7	51.9	48.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.1	52.4	55.6	61.4	68.0	72.0	71.8	72.5	69.1	63.9	59.2	54.6		
		MCDB	54.8	55.7	61.9	73.2	79.0	82.9	84.3	84.3	78.9	70.2	61.3	56.2		
	2%	WB	51.0	50.6	53.5	58.2	64.3	68.3	70.0	69.4	66.7	61.5	56.1	52.7		
		MCDB	52.9	53.4	58.7	68.4	72.3	77.8	81.6	79.5	74.0	66.0	58.5	54.8		
	5%	WB	48.8	49.1	51.7	56.0	61.7	65.9	68.0	67.2	64.6	59.9	54.1	50.8		
		MCDB	50.8	51.6	56.0	64.2	69.7	74.3	77.1	75.2	69.8	63.2	56.5	52.9		
	10%	WB	46.9	47.1	49.8	53.9	59.4	63.8	66.2	65.3	62.8	58.2	52.0	48.5		
		MCDB	48.8	49.7	53.4	60.2	66.6	70.5	73.6	71.7	67.5	61.0	54.2	50.4		
(35) Mean Daily Temperature Range	MDBR		7.9	9.6	12.8	16.2	16.1	17.1	17.4	16.8	15.6	12.3	9.2	7.7		
	5% DB	MCDBR	8.9	12.2	19.0	24.3	24.1	25.0	25.9	24.3	21.3	14.6	10.4	8.5		
		MCWBR	8.1	9.1	12.1	12.5	12.1	13.5	12.0	11.7	11.4	9.5	8.4	7.6		
	5% WB	MCDBR	8.9	10.7	16.0	21.1	20.9	22.1	22.3	21.0	18.5	13.4	10.0	8.4		
		MCWBR	8.3	8.7	11.1	11.6	11.6	12.8	11.6	11.0	10.8	9.4	8.6	7.8		
(40) Clear-Sky Solar Irradiance	taub		0.335	0.355	0.390	0.417	0.427	0.423	0.427	0.418	0.394	0.371	0.347	0.330		
	taud		2.369	2.342	2.244	2.201	2.221	2.251	2.247	2.292	2.348	2.398	2.378	2.340		
	Ebn at Noon		213	241	253	260	263	265	261	257	250	233	206	193		
	Edh at Noon		20	27	35	41	42	42	41	37	32	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		243	462	844	1368	1614	1748	1650	1409	1042	602	284	186		
	RadStd		24	86	111	134	128	141	177	123	80	50	29	23		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (78 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page