

WESTDORPE, Netherlands

WMO: 063190

Lat: 51.2247N

Lon: 3.8611E

Elev: 2

StdP: 101.30

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	-3.3	-8.7	1.8	-4.4	-6.2	2.2	-2.7	14.2	8.9	13.0	9.8	3.1	70	0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	28.9	20.1	26.6	19.1	24.7	18.2	21.1	27.2	20.1	25.2	19.1	23.4	3.5	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	23.3	18.2	13.1	22.0	17.4	12.4	21.2	61.1	27.6	57.4	25.3	54.2	23.3	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.9	8.7	-7.8	33.3	3.9	2.3	-10.6	35.0	-12.9	36.3	-15.1	37.6	-17.9	39.3		
(5)			-8.2	23.4	3.8	1.0	-10.9	24.1	-13.1	24.7	-15.2	25.2	-18.0	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	4.1	4.7	7.1	10.2	13.6	16.1	18.0	17.9	15.5	11.7	7.7	4.9	(6)
(7)		DBStd	5.99	3.96	3.74	3.27	3.48	3.25	2.88	2.75	2.45	2.60	3.22	3.29	3.98	(7)
(8)		HDD10.0	744	185	150	99	40	6	0	0	0	0	19	82	163	(8)
(9)		HDD18.3	2755	442	382	349	245	151	78	39	38	91	204	318	418	(9)
(10)		CDD10.0	1108	2	2	9	45	117	184	249	244	166	73	13	3	(10)
(11)		CDD18.3	78	0	0	0	0	4	13	29	24	7	1	0	0	(11)
(12)		CDH23.3	736	0	0	0	10	52	136	285	201	51	2	0	0	(12)
(13)		CDH26.7	193	0	0	0	1	7	34	86	58	8	0	0	0	(13)
(14)	Wind	WSAvg	4.1	5.0	4.8	4.5	4.0	3.6	3.5	3.4	3.5	4.0	4.3	4.9	(14)	
(15)	Precipitation	PrecAvg	816	68	61	48	42	58	68	79	89	69	71	81	81	(15)
(16)		PrecMax	968	139	124	127	90	104	126	160	261	205	140	146	180	(16)
(17)		PrecMin	611	4	14	3	0	20	21	19	26	13	22	4	18	(17)
(18)		PrecStd	95	34	27	27	25	24	30	38	57	44	26	33	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	14.4	18.8	24.7	27.5	30.6	32.3	31.5	27.6	22.5	17.0	13.9	(19)
(20)			MCWB	11.4	10.0	12.3	14.8	18.7	21.2	21.2	21.2	19.8	17.3	14.6	12.2	(20)
(21)		2%	DB	11.8	12.4	16.1	21.7	24.6	26.8	29.0	28.2	24.8	19.4	15.0	12.8	(21)
(22)			MCWB	10.5	9.9	11.4	14.0	16.9	19.2	19.9	20.2	18.6	16.0	13.1	11.3	(22)
(23)		5%	DB	10.6	11.1	13.8	18.9	22.2	24.4	26.5	25.3	22.3	17.6	13.7	11.7	(23)
(24)			MCWB	9.2	9.2	10.4	13.0	15.9	18.4	19.4	18.9	17.5	15.0	12.1	10.3	(24)
(25)		10%	DB	9.4	9.9	12.1	16.3	19.9	22.2	24.2	23.1	20.4	16.3	12.5	10.3	(25)
(26)			MCWB	8.2	8.4	9.6	11.6	14.8	17.2	18.5	17.7	16.3	14.3	11.1	9.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.4	13.1	16.3	20.0	22.2	22.1	22.5	20.6	17.7	15.1	12.6	(27)
(28)			MCDWB	12.7	13.2	16.6	22.9	26.1	28.3	29.1	29.1	26.1	21.2	16.3	13.4	(28)
(29)		2%	WB	10.5	10.4	11.9	14.6	17.9	20.1	21.1	20.8	19.3	16.4	13.4	11.5	(29)
(30)			MCDWB	11.6	11.9	14.8	20.2	22.4	25.4	27.5	26.4	23.3	18.9	14.7	12.7	(30)
(31)		5%	WB	9.3	9.5	10.9	13.3	16.5	18.9	20.0	19.6	18.1	15.5	12.3	10.4	(31)
(32)			MCDWB	10.4	10.9	13.4	17.9	20.9	23.5	25.1	24.0	21.0	17.3	13.6	11.6	(32)
(33)		10%	WB	8.3	8.4	9.9	12.2	15.2	17.7	19.0	18.5	17.1	14.5	11.1	9.2	(33)
(34)			MCDWB	9.3	9.8	11.9	15.7	19.2	21.4	23.1	22.0	19.7	16.1	12.3	10.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.4	7.1	9.0	8.9	9.5	9.7	9.3	8.6	6.8	5.1	4.3	(35)
(36)			MCDBR	4.9	6.8	10.5	13.5	13.4	13.9	14.4	13.5	11.8	8.1	5.8	4.7	(36)
(37)			MCWBR	4.5	5.1	6.7	7.0	6.7	7.5	6.7	6.5	6.4	5.3	4.7	4.2	(37)
(38)		5% WB	MCDWB	4.9	6.0	8.9	11.7	11.6	12.3	12.4	11.7	10.3	7.5	5.6	4.7	(38)
(39)			MCWBR	4.6	4.9	6.2	6.4	6.4	7.1	6.4	6.1	6.0	5.2	4.8	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.355	0.390	0.417	0.427	0.423	0.427	0.418	0.394	0.371	0.347	0.330	(40)	
(41)		taud	2.369	2.342	2.244	2.201	2.221	2.251	2.247	2.292	2.348	2.398	2.378	2.340	(41)	
(42)		Ebn at Noon	673	761	797	819	829	835	823	811	788	734	649	609	(42)	
(43)		Edh at Noon	64	85	111	130	133	131	129	118	100	79	63	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.77	1.46	2.66	4.31	5.09	5.51	5.20	4.44	3.29	1.90	0.90	0.59	(44)	
(45)		RadStd	0.08	0.27	0.35	0.42	0.40	0.45	0.56	0.39	0.25	0.16	0.09	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (78 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page